

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	CTC EcoAir 510M 1x230V	Reg. No.	012-061
Certificate Holder			
Name	Enertech CTC AB		
Address	Box 309, Näsvägen	Zip	SE-381 26
City	Ljungby	Country	Sweden
Certification Body	RISE CERT		
Name of testing laboratory	RISE		
Subtype title	CTC EcoAir 510M 1x230V		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	2.2 kg		

Model: CTC EcoAir 510M 1x230V

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	6.21 kW	5.76 kW
El input	1.39 kW	2.07 kW
COP	4.46	2.79
Indoor water flow rate	1.08 m ³ /h	0.61 m ³ /h

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	171 %	125 %
Prated	9.30 kW	9.20 kW
SCOP	4.40	3.20
Tbiv	-10 °C	-8 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.90 kW	7.00 kW
COP Tj = -7°C	2.92	7.95
Pdh Tj = +2°C	2.50 kW	4.40 kW
COP Tj = +2°C	4.70	3.14
Pdh Tj = +7°C	2.60 kW	2.80 kW
COP Tj = +7°C	5.93	4.63
Pdh Tj = 12°C	1.30 kW	2.90 kW
COP Tj = 12°C	7.59	6.17
Pdh Tj = Tbiv	4.30 kW	7.20 kW
COP Tj = Tbiv	2.62	1.84

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	4.30 kW	6.10 kW
COP Tj = TOL	2.62	1.71
Cdh	0.97	0.98
WTOL	65 °C	65 °C
Poff	15 W	15 W
PTO	9 W	9 W
PSB	15 W	15 W
PCK	23 W	23 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	1.90 kW
Annual energy consumption Qhe	2005 kWh	5155 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	154 %	116 %
Prated	6.00 kW	5.80 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

SCOP	3.90	3.00
Tbiv	-17 °C	-17 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	3.70 kW	3.60 kW
COP Tj = -7°C	3.16	2.45
Pdh Tj = +2°C	2.20 kW	2.10 kW
COP Tj = +2°C	5.08	3.80
Pdh Tj = +7°C	2.60 kW	2.50 kW
COP Tj = +7°C	6.27	4.95
Pdh Tj = 12°C	2.90 kW	2.90 kW
COP Tj = 12°C	7.59	6.44
Pdh Tj = Tbiv	5.10 kW	4.70 kW
COP Tj = Tbiv	2.49	1.80
Pdh Tj = TOL	2.90 kW	4.80 kW
COP Tj = TOL	1.91	1.56
Cdh	0.97	0.98
WTOL	65 °C	65 °C
Poff	15 W	15 W
PTO	9 W	9 W
PSB	15 W	15 W
PCK	23 W	23 W

This information was generated by the HP KEYMARK database on 17 Dec 2020

Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	3.10 kW	5.80 kW
Annual energy consumption Q _{he}	3780 kWh	4791 kWh