

This information was generated by the HP KEYMARK database on 22 Jun 2022

[Login](#)

Summary of	HMI140 / DHWT300	Reg. No.	041-K011-06
Certificate Holder			
Name	AERMEC S.p.A.		
Address	Via Roma 996	Zip	37040
City	Bevilacqua (VR)	Country	Italy
Certification Body	BRE Global Limited		
Subtype title	HMI140 / DHWT300		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	2.2 kg		
Certification Date	25.03.2021		
Testing basis	Heat Pump Keymark Scheme Rules Rev 08		

Model: HMI140 / DHWT300X

Configure model	
Model name	HMI140 / DHWT300X
Application	Heating + DHW
Units	Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2	
	Medium temperature
Heat output	13.50 kW
El input	5.19 kW
COP	2.60

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1

Medium temperature

Sound power level outdoor

70 dB(A)

EN 14825

Medium temperature

 η_s

127 %

Prated

11.00 kW

SCOP

3.25

Tbiv

-7 °C

TOL

-10 °C

Pdh Tj = -7°C

10.34 kW

COP Tj = -7°C

2.13

Cdh Tj = -7 °C

0.98

Pdh Tj = +2°C

6.00 kW

COP Tj = +2°C

3.15

Cdh Tj = +2 °C

0.98

Pdh Tj = +7°C

5.76 kW

COP Tj = +7°C

4.24

Cdh Tj = +7 °C

0.98

Pdh Tj = 12°C

6.36 kW

This information was generated by the HP KEYMARK database on 22 Jun 2022

COP Tj = 12°C	5.06
Cdh Tj = +12 °C	0.98
Pdh Tj = Tbiv	10.34 kW
COP Tj = Tbiv	2.13
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.41 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.78
WTOL	55 °C
Poff	18 W
PTO	18 W
PSB	18 W
PCK	0 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.59 kW
Annual energy consumption Qhe	6993 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	110 %
COP	2.62
Heating up time	1:52 h:min
Standby power input	62.6 W
Reference hot water temperature	52.8 °C
Mixed water at 40°C	372 l

Model: HMI140T / DHWT300XT

Configure model	
Model name	HMI140T / DHWT300XT
Application	Heating + DHW
Units	Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2	
	Medium temperature
Heat output	13.50 kW
El input	5.19 kW
COP	2.60

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

Medium temperature

Sound power level outdoor

70 dB(A)

EN 14825

Medium temperature

 η_s

127 %

Prated

11.00 kW

SCOP

3.25

Tbiv

-7 °C

TOL

-10 °C

Pdh Tj = -7°C

10.34 kW

COP Tj = -7°C

2.13

Cdh Tj = -7 °C

0.98

Pdh Tj = +2°C

6.00 kW

COP Tj = +2°C

3.15

Cdh Tj = +2 °C

0.98

Pdh Tj = +7°C

5.76 kW

COP Tj = +7°C

4.24

Cdh Tj = +7 °C

0.98

Pdh Tj = 12°C

6.36 kW

This information was generated by the HP KEYMARK database on 22 Jun 2022

COP Tj = 12°C	5.06
Cdh Tj = +12 °C	0.98
Pdh Tj = Tbiv	10.34 kW
COP Tj = Tbiv	2.13
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.41 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.78
WTOL	55 °C
Poff	18 W
PTO	18 W
PSB	18 W
PCK	0 W
Supplementary Heater: Type of energy input	Electricity
Supplementary Heater: PSUP	0.59 kW
Annual energy consumption Qhe	6993 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	110 %
COP	2.62
Heating up time	1:52 h:min
Standby power input	62.6 W
Reference hot water temperature	52.8 °C
Mixed water at 40°C	372 l