

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	WPF 40	Reg. No.	011-1W0277
Certificate Holder			
Name	STIEBEL ELTRON GmbH & Co KG		
Address	Dr. Stiebel Straße 33	Zip	37603
City	Holzminden	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	WPF 40		
Heat Pump Type	Brine/Water		
Refrigerant	R410A		
Mass of Refrigerant	10 kg		
Certification Date	24.01.2019		

Model: WPF 40

Configure model	
Model name	WPF 40
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Colder Climate

EN 14825		
	Low temperature	Medium temperature
η_s	202 %	139 %
Prated	53.00 kW	50.00 kW
SCOP	5.25	3.68
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	43.60 kW	41.50 kW
COP Tj = -7°C	5.22	3.49
Pdh Tj = +2°C	43.90 kW	42.10 kW
COP Tj = +2°C	5.48	3.90
Pdh Tj = +7°C	44.00 kW	42.60 kW
COP Tj = +7°C	5.70	4.28

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	44.00 kW	43.00 kW
COP Tj = 12°C	5.73	4.60
Pdh Tj = Tbiv	43.50 kW	41.10 kW
COP Tj = Tbiv	5.11	3.27
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	43.10 kW	40.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.67	2.88
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	7 W	7 W
PSB	7 W	7 W
PCK	74 W	74 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	10.27 kW	10.14 kW
Annual energy consumption Qhe	25071 kWh	33723 kWh

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	59 dB(A)	59 dB(A)

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825

	Low temperature	Medium temperature
η_s	194 %	133 %
Prated	43.00 kW	40.00 kW
SCOP	5.05	3.53
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	43.20 kW	40.50 kW
COP Tj = -7°C	4.73	3.00
Pdh Tj = +2°C	43.50 kW	41.50 kW
COP Tj = +2°C	5.05	3.51
Pdh Tj = +7°C	43.80 kW	42.10 kW
COP Tj = +7°C	5.38	3.90
Pdh Tj = 12°C	44.10 kW	42.80 kW
COP Tj = 12°C	5.76	4.38
Pdh Tj = Tbiv	43.10 kW	40.20 kW
COP Tj = Tbiv	4.67	2.88
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	43.10 kW	40.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.67	2.88
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

Poff	0 W	0 W
PTO	7 W	7 W
PSB	7 W	7 W
PCK	74 W	74 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	17606 kWh	23479 kWh

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	59 dB(A)	59 dB(A)

Warmer Climate

EN 14825		
	Low temperature	Medium temperature
η_s	194 %	133 %
Prated	43.00 kW	40.00 kW
SCOP	5.05	3.53
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	43.10 kW	40.20 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = +2°C	4.67	2.88
Pdh Tj = +7°C	43.40 kW	41.10 kW
COP Tj = +7°C	4.98	3.27
Pdh Tj = 12°C	43.90 kW	42.40 kW
COP Tj = 12°C	5.51	4.05
Pdh Tj = Tbiv	43.10 kW	40.20 kW
COP Tj = Tbiv	4.67	2.88
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	43.10 kW	40.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.67	2.88
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	7 W	7 W
PSB	7 W	7 W
PCK	74 W	74 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	11415 kWh	15248 kWh

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	59 dB(A)	59 dB(A)

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	43.10 kW	40.20 kW
El input	9.23 kW	17.45 kW
COP	4.67	2.99

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed