This information was generated by the HP KEYMARK database on 23 Jun 2022

Login

Summary of	ECL-PAC-06-08	Reg. No.	ICIM-PDC-000142
Certificate Holder			
Name	ECL Nexus		
Address	13, Boulevard Pereire	Zip	75017
City	Paris	Country	France
Certification Body	ICIM S.p.A.		
Subtype title	ECL-PAC-06-08		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	1.5 kg		
Certification Date	20.05.2022		
Testing basis	HP KEYMARK certification scheme rules rev. no. 7		

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: ECLPAC06X.XT ; ECLPAC06X.KA

Configure model	
Model name	ECLPAC06X.XT ; ECLPAC06X.KA
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Cooling

EN 14511-2	
	+7°C/+12°C
El input	1.60 kW
Cooling capacity	5.02
EER	3.14

EN 14825

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

	+7°C/+12°C
Pdesignc	5.02 kW
SEER	4.42
Pdc Tj = 35°C	5.02 kW
EER Tj = 35°C	3.14
Pdc Tj = 30°C	3.70 kW
EER Tj = 30°C	4.03
Cdc	1.000
Pdc Tj = 25°C	2.70 kW
EER Tj = 25°C	4.82
Cdc	0.966
Pdc Tj = 20°C	2.96 kW
EER Tj = 20°C	6.57
Cdc	0.958
Poff	22 W
PTO	0 W
PSB	28 W
PCK	0 W
Annual energy consumption Qce	682 kWh

Heating

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	6.08 kW	6.03 kW
El input	1.35 kW	2.14 kW
COP	4.51	2.82

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	175 %	126 %
Prated	7.00 kW	7.00 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

SCOP	4.46	3.22
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-15 °C
Pdh Tj = -7°C	6.10 kW	5.80 kW
COP Tj = -7°C	2.96	2.08
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	3.70 kW	3.60 kW
COP Tj = +2°C	4.36	3.30
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	3.20 kW	3.00 kW
COP Tj = +7°C	5.56	3.49
Cdh Tj = +7 °C	0.967	0.978
Pdh Tj = 12°C	3.70 kW	3.60 kW
COP Tj = 12°C	7.88	6.49
Cdh Tj = +12 °C	0.959	0.966
Pdh Tj = Tbiv	6.10 kW	5.80 kW
COP Tj = Tbiv	2.96	2.08
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.10 kW	6.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.73	1.95
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Poff	19 W	19 W
PTO	22 W	22 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.90 kW	1.00 kW
Annual energy consumption Qhe	3178 kWh	4190 kWh

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: ECLPAC08X.XT ; ECLPAC08X.KA

Configure model	
Model name	ECLPAC08X.XT ; ECLPAC08X.KA
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Cooling

EN 14511-2	
	+7°C/+12°C
El input	1.99 kW
Cooling capacity	6.08
EER	3.05

EN 14825

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

	+7°C/+12°C
Pdesignc	6.08 kW
SEER	4.51
Pdc Tj = 35°C	6.08 kW
EER Tj = 35°C	3.05
Pdc Tj = 30°C	4.49 kW
EER Tj = 30°C	4.07
Cdc	0.980
Pdc Tj = 25°C	2.74 kW
EER Tj = 25°C	4.84
Cdc	0.966
Pdc Tj = 20°C	3.02 kW
EER Tj = 20°C	6.70
Cdc	0.958
Poff	22 W
PTO	0 W
PSB	28 W
PCK	0 W
Annual energy consumption Qce	809 kWh

Heating

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	7.81 kW	7.55 kW
El input	1.78 kW	2.65 kW
COP	4.38	2.85

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	176 %	128 %
Prated	7.00 kW	7.00 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

SCOP	4.46	3.27
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-15 °C
Pdh Tj = -7°C	6.50 kW	6.30 kW
COP Tj = -7°C	2.95	1.91
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	4.00 kW	3.80 kW
COP Tj = +2°C	4.37	3.33
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	3.10 kW	3.10 kW
COP Tj = +7°C	5.55	3.90
Cdh Tj = +7 °C	0.966	0.976
Pdh Tj = 12°C	3.70 kW	3.60 kW
COP Tj = 12°C	7.86	6.30
Cdh Tj = +12 °C	0.959	0.967
Pdh Tj = Tbiv	6.50 kW	6.30 kW
COP Tj = Tbiv	2.95	1.91
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.50 kW	6.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.70	1.95
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Poff	19 W	19 W
PTO	22 W	22 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.50 kW	0.60 kW
Annual energy consumption Qhe	3411 kWh	4494 kWh

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.