

This information was generated by the HP KEYMARK database on 21 Jun 2022

[Login](#)

Summary of	LW 180	Reg. No.	041-K001-39
Certificate Holder			
Name	ait-deutschland GmbH		
Address	Industriestr. 3	Zip	95359
City	Kasendorf	Country	Germany
Certification Body	BRE Global Limited		
Subtype title	LW 180		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R407c		
Mass of Refrigerant	6.8 kg		
Certification Date	08.10.2019		
Testing basis	HP Keymark Scheme Rules Rev 07		

Model: LW 180 (L)

Configure model	
Model name	LW 180 (L)
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	20.84 kW	22.00 kW
El input	5.71 kW	8.38 kW
COP	3.65	2.63

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 21 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	59 dB(A)	59 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	158 %	118 %
Prated	20.03 kW	18.50 kW
SCOP	4.03	3.02
Tbiv	-4 °C	-4 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	14.28 kW	12.78 kW
COP Tj = -7°C	2.94	1.94
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	17.48 kW	16.92 kW
COP Tj = +2°C	3.94	2.93
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	10.09 kW	10.08 kW
COP Tj = +7°C	5.38	4.21
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	12.90 kW	12.86 kW

This information was generated by the HP KEYMARK database on 21 Jun 2022

COP Tj = 12°C	5.96	5.39
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	15.41 kW	14.23 kW
COP Tj = Tbiv	3.30	2.23
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.17 kW	11.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.65	1.68
WTOL	60 °C	60 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.86 kW	7.20 kW
Annual energy consumption Qhe	10262 kWh	12643 kWh

Warmer Climate

EN 14825		
	Low temperature	Medium temperature
η_s	200 %	150 %
Prated	17.30 kW	16.23 kW
SCOP	5.08	3.82

This information was generated by the HP KEYMARK database on 21 Jun 2022

Tbiv	4 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	17.30 kW	16.23 kW
COP Tj = +2°C	3.56	2.18
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	10.08 kW	10.08 kW
COP Tj = +7°C	4.90	3.34
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	12.88 kW	12.82 kW
COP Tj = 12°C	5.74	4.89
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	14.46 kW	13.88 kW
COP Tj = Tbiv	3.93	2.51
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	17.30 kW	16.23 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.56	2.18
WTOL	60 °C	60 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity

This information was generated by the HP KEYMARK database on 21 Jun 2022

Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	4546 kWh	5671 kWh

Colder Climate

EN 14825		
	Low temperature	Medium temperature
η_s	139 %	107 %
Prated	17.39 kW	15.21 kW
SCOP	3.54	2.76
T _{biv}	-12 °C	-12 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	14.53 kW	13.45 kW
COP T _j = -7°C	3.18	2.31
C _{dh} T _j = -7 °C	1.00	1.00
P _{dh} T _j = +2°C	17.59 kW	17.19 kW
COP T _j = +2°C	4.17	3.35
C _{dh} T _j = +2 °C	1.00	1.00
P _{dh} T _j = +7°C	10.09 kW	10.08 kW
COP T _j = +7°C	5.60	4.68
C _{dh} T _j = +7 °C	0.99	1.00
P _{dh} T _j = 12°C	12.90 kW	12.88 kW

This information was generated by the HP KEYMARK database on 21 Jun 2022

COP Tj = 12°C	5.83	5.61
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	12.81 kW	12.21 kW
COP Tj = Tbiv	2.71	1.87
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.81 kW	8.36 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.95	1.38
WTOL	60 °C	60 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	17.39 kW	15.21 kW
Annual energy consumption Qhe	12110 kWh	13578 kWh
Pdh Tj = -15°C (if TOL<-20°C)	11.70	9.81
COP Tj = -15°C (if TOL<-20°C)	2.40	1.62
Cdh Tj = -15 °C	1.00	1.00

Model: LW 180A

Configure model	
Model name	LW 180A
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	20.84 kW	22.00 kW
El input	5.71 kW	8.38 kW
COP	3.65	2.63

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 21 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	59 dB(A)	59 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	158 %	118 %
Prated	20.03 kW	18.50 kW
SCOP	4.03	3.02
Tbiv	-4 °C	-4 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	14.28 kW	12.78 kW
COP Tj = -7°C	2.94	1.94
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	17.48 kW	16.92 kW
COP Tj = +2°C	3.94	2.93
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	10.09 kW	10.08 kW
COP Tj = +7°C	5.38	4.21
Cdh Tj = +7 °C	1.00	1.00

This information was generated by the HP KEYMARK database on 21 Jun 2022

Pdh Tj = 12°C	12.90 kW	12.86 kW
COP Tj = 12°C	5.96	5.39
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	15.41 kW	14.23 kW
COP Tj = Tbiv	3.30	2.23
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.17 kW	11.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.65	1.68
WTOL	60 °C	60 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	6.86 kW	7.20 kW
Annual energy consumption Qhe	10262 kWh	12643 kWh

Warmer Climate

EN 14825		
	Low temperature	Medium temperature
η_s	200 %	150 %
Prated	17.30 kW	16.23 kW

This information was generated by the HP KEYMARK database on 21 Jun 2022

SCOP	5.08	3.82
Tbiv	4 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	17.30 kW	16.23 kW
COP Tj = +2°C	3.56	2.18
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	10.08 kW	10.08 kW
COP Tj = +7°C	4.90	3.34
Cdh Tj = +7 °C	1.00	1.00
Pdh Tj = 12°C	12.88 kW	12.82 kW
COP Tj = 12°C	5.74	4.89
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	14.46 kW	13.88 kW
COP Tj = Tbiv	3.93	2.51
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	17.30 kW	16.23 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.56	2.18
WTOL	60 °C	60 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W

This information was generated by the HP KEYMARK database on 21 Jun 2022

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	4546 kWh	5671 kWh

Colder Climate

EN 14825		
	Low temperature	Medium temperature
η_s	139 %	107 %
Prated	17.39 kW	15.21 kW
SCOP	3.54	2.76
T _{biv}	-12 °C	-12 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	14.53 kW	13.45 kW
COP T _j = -7°C	3.18	2.31
C _{dh} T _j = -7 °C	1.00	1.00
P _{dh} T _j = +2°C	17.59 kW	17.19 kW
COP T _j = +2°C	4.17	3.35
C _{dh} T _j = +2 °C	1.00	1.00
P _{dh} T _j = +7°C	10.09 kW	10.08 kW
COP T _j = +7°C	5.60	4.68
C _{dh} T _j = +7 °C	0.99	1.00

This information was generated by the HP KEYMARK database on 21 Jun 2022

Pdh Tj = 12°C	12.90 kW	12.88 kW
COP Tj = 12°C	5.83	5.61
Cdh Tj = +12 °C	1.00	1.00
Pdh Tj = Tbiv	12.81 kW	12.21 kW
COP Tj = Tbiv	2.71	1.87
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.81 kW	8.36 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.95	1.38
WTOL	60 °C	60 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	17.39 kW	15.21 kW
Annual energy consumption Qhe	12110 kWh	13578 kWh
Pdh Tj = -15°C (if TOL<-20°C)	11.70	9.81
COP Tj = -15°C (if TOL<-20°C)	2.40	1.62
Cdh Tj = -15 °C	1.00	1.00