

Page 1 of 6

This information was generated by the HP KEYMARK database on 18 Mar 2022

Login

Summary of	F2120-20	Reg. No.	012-032	
Certificate Holder	<u> </u>	<u> </u>	'	
Name	Nibe AB			
Address	Box 14	Zip	S-28521	
City	Markaryd	Country	Sweden	
Certification Body	RISE CERT	RISE CERT		
Subtype title	F2120-20			
Heat Pump Type	Outdoor Air/Wat	er		
Refrigerant	R410A	R410A		
Mass of Refrigerant	3 kg			
Certification Date	05.05.2020			



Model: F2120-20

Configure model		
Model name	F2120-20	
Application	Heating (medium temp)	
Units	Outdoor	
Climate Zone	Colder Climate	
Reversibility No		
Cooling mode application (optional) n/a		

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4		
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.94 kW	7.25 kW
El input	1.43 kW	2.35 kW
СОР	4.85	3.08

Average Climate

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



 $$\operatorname{\textit{Page}}\xspace$ 3 of 6 This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	35 dB(A)	35 dB(A)
Sound power level outdoor	53 dB(A)	55 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	199 %	153 %
Prated	11.00 kW	12.30 kW
SCOP	5.05	3.90
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.74 kW	10.91 kW
COP Tj = -7°C	3.41	2.48
Pdh Tj = +2°C	6.47 kW	6.66 kW
COP Tj = +2°C	5.08	3.96
Pdh Tj = +7°C	6.86 kW	5.93 kW
COP Tj = +7°C	5.95	4.69
Pdh Tj = 12°C	6.76 kW	6.49 kW
COP Tj = 12°C	7.36	5.81
Pdh Tj = Tbiv	9.74 kW	10.91 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = Tbiv	3.41	2.48
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.80 kW	11.59 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.11	2.40
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99
WTOL	65 °C	65 °C
Poff	25 W	25 W
РТО	7 W	12 W
PSB	25 W	25 W
PCK	37 W	37 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.20 kW	0.70 kW
Annual energy consumption Qhe	4508 kWh	6530 kWh

Colder Climate

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	35 dB(A)	35 dB(A)	
Sound power level outdoor	53 dB(A)	53 dB(A)	

EN 14825		
	Low temperature	Medium temperature





This information was generated by the HP KEYMARK database on 18 N		
η_{s}	165 %	134 %
Prated	13.00 kW	14.00 kW
SCOP	4.19	3.41
Tbiv	-12 °C	-12 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	7.87 kW	8.47 kW
COP Tj = -7 °C	3.50	2.85
Pdh Tj = +2°C	6.20 kW	6.10 kW
COP Tj = +2°C	5.25	4.15
Pdh Tj = $+7^{\circ}$ C	5.90 kW	6.00 kW
$COP Tj = +7^{\circ}C$	5.60	4.80
Pdh Tj = 12°C	6.70 kW	6.40 kW
COP Tj = 12°C	7.00	5.80
Pdh Tj = Tbiv	9.58 kW	10.32 kW
COP Tj = Tbiv	3.15	2.55
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL $<$ Tdesignh	8.30 kW	8.69 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.30	1.94
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL $<$ Tdesignh	0.99	0.99
WTOL	65 °C	65 °C
Poff	25 W	25 W
PTO	7 W	12 W

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 6 of 6 This information was generated by the HP KEYMARK database on 18 Mar 2022

PSB	25 W	25 W
PCK	35 W	35 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.70 kW	5.30 kW
Annual energy consumption Qhe	7639 kWh	10108 kWh