

This information was generated by the HP KEYMARK database on 21 Jun 2022

[Login](#)

| | | | |
|---------------------|-------------------------|----------|---------------|
| Summary of | Jäspi Inverter Split 12 | Reg. No. | 012-SC0806-18 |
| Certificate Holder | | | |
| Name | Kaukora | | |
| Address | Tuotekatu 11 | Zip | FI-21200 |
| City | Raisio | Country | Finland |
| Certification Body | RISE CERT | | |
| Subtype title | Jäspi Inverter Split 12 | | |
| Heat Pump Type | Outdoor Air/Water | | |
| Refrigerant | R410A | | |
| Mass of Refrigerant | 2.9 kg | | |

Model: Jäspi Inverter Split 12 + Jäspi Splitbox

| Configure model | |
|-------------------------------------|--|
| Model name | Jäspi Inverter Split 12 + Jäspi Splitbox |
| Application | Heating (medium temp) |
| Units | Indoor + Outdoor |
| Climate Zone | n/a |
| Reversibility | No |
| Cooling mode application (optional) | n/a |

| General Data | |
|--------------|-------------|
| Power supply | 1x230V 50Hz |

Heating

| EN 14511-4 | |
|--|--------|
| Operating range outdoor exchanger/indoor exchanger lower limit/lower limit | passed |
| Operating range outdoor exchanger/indoor exchanger upper limit/upper limit | passed |
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure | passed |
| Defrost test | passed |

| EN 14511-2 | | |
|-------------|-----------------|--------------------|
| | Low temperature | Medium temperature |
| Heat output | 5.21 kW | 4.73 kW |
| El input | 1.09 kW | 1.54 kW |
| COP | 4.78 | 3.07 |

Average Climate

This information was generated by the HP KEYMARK database on 21 Jun 2022

EN 12102-1

| | Low temperature | Medium temperature |
|---------------------------|-----------------|--------------------|
| Sound power level indoor | 35 dB(A) | 35 dB(A) |
| Sound power level outdoor | 58 dB(A) | 58 dB(A) |

EN 14825

| | Low temperature | Medium temperature |
|---------------|-----------------|--------------------|
| η_s | 174 % | 132 % |
| Prated | 11.50 kW | 10.00 kW |
| SCOP | 4.42 | 3.37 |
| Tbiv | -7 °C | -8 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 10.30 kW | 8.90 kW |
| COP Tj = -7°C | 2.91 | 1.99 |
| Pdh Tj = +2°C | 6.30 kW | 5.50 kW |
| COP Tj = +2°C | 4.34 | 3.22 |
| Pdh Tj = +7°C | 4.10 kW | 3.50 kW |
| COP Tj = +7°C | 5.51 | 4.61 |
| Pdh Tj = 12°C | 4.80 kW | 5.00 kW |
| COP Tj = 12°C | 6.96 | 6.25 |
| Pdh Tj = Tbiv | 10.20 kW | 9.20 kW |

This information was generated by the HP KEYMARK database on 21 Jun 2022

| | | |
|---|-------------|-------------|
| COP $T_j = T_{biv}$ | 2.89 | 1.90 |
| $P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$ | 9.30 kW | 8.10 kW |
| COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$ | 2.66 | 1.92 |
| $C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$ | 0.97 | 0.98 |
| WTOL | 65 °C | 65 °C |
| Poff | 2 W | 2 W |
| PTO | 20 W | 15 W |
| PSB | 15 W | 15 W |
| PCK | 35 W | 35 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 2.20 kW | 1.90 kW |
| Annual energy consumption Q_{he} | 5482 kWh | 6136 kWh |