

## Page 1 of 4 This information was generated by the HP KEYMARK database on 17 Dec 2020

|                            | · ·                           |            |              |  |
|----------------------------|-------------------------------|------------|--------------|--|
| Summary of                 | ATLANTIC GEOLIA 17            | Reg. No.   | 012-C700083  |  |
| Certificate Holder         | <del></del>                   |            | <del>-</del> |  |
| Name                       | Groupe Atlantic               |            |              |  |
| Address                    | 44 boulevard des Etats-Unis   | Zip        | 85000        |  |
| City                       | La Roche Sur Yon              | Country    | France       |  |
| Certification Body         | RISE CERT                     |            |              |  |
| Name of testing laboratory | RISE                          |            |              |  |
| Subtype title              | ATLANTIC GEOLIA 17            |            |              |  |
| Heat Pump Type             | Water/Water                   |            |              |  |
| Refrigerant                | R410a                         |            |              |  |
| Mass Of Refrigerant        | 2.3 kg                        |            |              |  |
| Certification Date         | 16.10.2020                    | 16.10.2020 |              |  |
| Testing basis              | HP Keymark Scheme Rules rev 8 |            |              |  |



This information was generated by the HP KEYMARK database on 17 Dec 2020

## **Model: ATLANTIC GEOLIA 17**

| General Data |             |
|--------------|-------------|
| Power supply | 1x230V 50Hz |

## Heating

| EN 14511-2             |                 |                    |
|------------------------|-----------------|--------------------|
|                        | Low temperature | Medium temperature |
| Heat output            | 22.13 kW        | 20.14 kW           |
| El input               | 4.25 kW         | 5.69 kW            |
| СОР                    | 5.21            | 3.54               |
| Indoor water flow rate | 3.82 m³/h       | 2.17 m³/h          |

| EN 14511-4                                 |        |  |
|--|--------|--|
| Shutting off the heat transfer medium flow | passed |  |
| Complete power supply failure              | passed |  |
| Defrost test                               | passed |  |
| Starting and operating test                | passed |  |

## Average Climate



This information was generated by the HP KEYMARK database on 17 Dec 2020

| EN 12102-1               |                 |                    |
|--------------------------|-----------------|--------------------|
|                          | Low temperature | Medium temperature |
| Sound power level indoor | 55 dB(A)        | 55 dB(A)           |

|               | EN 14825        |                    |
|---------------|-----------------|--------------------|
|               | Low temperature | Medium temperature |
| $\eta_{s}$    | 217 %           | 176 %              |
| Prated        | 25.00 kW        | 23.00 kW           |
| SCOP          | 5.63            | 4.60               |
| Tbiv          | -7 °C           | -7 °C              |
| TOL           | -10 °C          | -10 °C             |
| Pdh Tj = -7°C | 21.80 kW        | 20.20 kW           |
| COP Tj = -7°C | 5.42            | 3.76               |
| Cdh           | 0.99            | 0.99               |
| Pdh Tj = +2°C | 22.00 kW        | 20.80 kW           |
| COP Tj = +2°C | 5.68            | 4.64               |
| Cdh           | 0.99            | 0.99               |
| Pdh Tj = +7°C | 22.10 kW        | 21.20 kW           |
| COP Tj = +7°C | 5.94            | 5.18               |
| Cdh           | 0.99            | 0.99               |
| Pdh Tj = 12°C | 22.80 kW        | 21.60 kW           |

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



 $$\operatorname{\textit{Page}}$4$ of 4$ This information was generated by the HP KEYMARK database on 17 Dec 2020$ 

|  | <u> </u>    |             |
|--|-------------|-------------|
| COP Tj = 12°C                              | 6.20        | 5.72        |
| Cdh  | 0.99        | 0.99        |
| Pdh Tj = Tbiv                              | 21.80 kW    | 20.20 kW    |
| COP Tj = Tbiv                              | 5.42        | 3.76        |
| Pdh Tj = TOL                               | 21.70 kW    | 19.90 kW    |
| COP Tj = TOL                               | 5.29        | 3.54        |
| WTOL                                       | 55 °C       | 55 °C       |
| Poff                                       | 2 W         | 2 W         |
| РТО  | 90 W        | 90 W        |
| PSB  | 3 W         | 3 W         |
| PCK  | 0 W         | 0 W         |
| Supplementary Heater: Type of energy input | ELECTRICITY | ELECTRICITY |
| Supplementary Heater: PSUP                 | 3.00 kW     | 2.90 kW     |
| Annual energy consumption Qhe              | 9057 kWh    | 10272 kWh   |