

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	18. Yutaki M 3.0HP (mono	Reg. No.	041-K002-18
Certificate Holder			
Name	Johnson Controls-Hitachi AirConditioning Spain		
Address	Ronda Shimizu, 1. Pol. Ind. Can Torrella	Zip	08233
City	Vacarisses, Barcelona	Country	Spain
Certification Body	BRE Global Limited		
Subtype title	18. Yutaki M 3.0HP (mono		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.4 kg		

Model: RASM-3VNE - Heating Only

Configure model	
Model name	RASM-3VNE - Heating Only
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	7.50 kW	7.50 kW
El input	1.65 kW	2.78 kW
COP	4.55	2.70

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	164 %	125 %
Prated	7.00 kW	6.00 kW
SCOP	4.18	3.20
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.90 kW	5.10 kW
COP Tj = -7°C	2.50	1.84
Pdh Tj = +2°C	3.59 kW	3.10 kW
COP Tj = +2°C	4.40	3.20
Pdh Tj = +7°C	2.31 kW	2.00 kW
COP Tj = +7°C	5.35	4.45
Pdh Tj = 12°C	2.10 kW	2.30 kW
COP Tj = 12°C	6.15	5.96
Pdh Tj = Tbiv	5.90 kW	5.10 kW
COP Tj = Tbiv	2.50	1.84

This information was generated by the HP KEYMARK database on 18 Mar 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	6.40 kW	5.20 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	2.30	1.65
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	55 °C	55 °C
Poff	15 W	15 W
PTO	0 W	0 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.60 kW	0.60 kW
Annual energy consumption Q_{he}	3298 kWh	3726 kWh

Model: RASM-3VNE - with cooling kit

Configure model	
Model name	RASM-3VNE - with cooling kit
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	7.50 kW	7.50 kW
El input	1.65 kW	2.78 kW
COP	4.55	2.70

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	167 %	127 %
Prated	7.00 kW	6.00 kW
SCOP	4.25	3.25
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.90 kW	5.10 kW
COP Tj = -7°C	2.50	1.84
Pdh Tj = +2°C	3.59 kW	3.10 kW
COP Tj = +2°C	4.40	3.20
Pdh Tj = +7°C	2.31 kW	2.00 kW
COP Tj = +7°C	5.35	4.45
Pdh Tj = 12°C	2.10 kW	2.30 kW
COP Tj = 12°C	6.15	5.96
Pdh Tj = Tbiv	5.90 kW	5.10 kW
COP Tj = Tbiv	2.50	1.84

This information was generated by the HP KEYMARK database on 18 Mar 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	6.40 kW	5.20 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	2.30	1.65
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.90	0.90
WTOL	55 °C	55 °C
Poff	15 W	15 W
PTO	0 W	0 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.60 kW	0.60 kW
Annual energy consumption Q_{he}	3242 kWh	3671 kWh