

This information was generated by the HP KEYMARK database on 22 Jun 2022

[Login](#)

Summary of	Ecodan Power Inverter 16	Reg. No.	037-0052-20
Certificate Holder			
Name	Mitsubishi Electric Air Conditioning Systems Europe LTD		
Address	Nettlehill Road, Houston Industrial Estate	Zip	EH54 5EQ
City	Livingston	Country	United Kingdom
Certification Body	SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)		
Subtype title	Ecodan Power Inverter 16		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	7.7 kg		
Certification Date	09.04.2020		
Testing basis	HP Keymark scheme rules rev. no. 7		

# Model: PUAZ-SW160YKA(-BS) + EHSE-M\*C

## Configure model

Model name	PUHZ-SW160YKA(-BS) + EHSE-M*C
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

## General Data

Power supply	3x400V 50Hz
--------------	-------------

## Heating

### EN 14511-2

	Low temperature	Medium temperature
Heat output	22.00 kW	22.00 kW
El input	5.23 kW	8.91 kW
COP	4.21	2.47

### EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)
Sound power level outdoor	78 dB(A)	78 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	161 %	125 %
Prated	15.30 kW	13.50 kW
SCOP	4.10	3.20
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	13.50 kW	11.90 kW
COP Tj = -7°C	2.57	1.83
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	8.20 kW	7.20 kW
COP Tj = +2°C	4.13	3.17
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	6.30 kW	5.90 kW
COP Tj = +7°C	5.22	4.29
Cdh Tj = +7 °C	0.990	0.990

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	7.70 kW	7.40 kW
COP Tj = 12°C	7.08	6.32
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	13.50 kW	11.90 kW
COP Tj = Tbiv	2.57	1.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.50 kW	11.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.35	1.80
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.80 kW	2.20 kW
Annual energy consumption Qhe	7702 kWh	8716 kWh

## Model: PUAZ-SW160YKA(-BS) + EHSE-\*M\*C

Configure model	
Model name	PUHZ-SW160YKA(-BS) + EHSE-*M*C
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

### Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	22.00 kW	22.00 kW
El input	5.23 kW	8.91 kW
COP	4.21	2.47

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### Average Climate

This information was generated by the HP KEYMARK database on 22 Jun 2022

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)
Sound power level outdoor	78 dB(A)	78 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	161 %	125 %
Prated	15.30 kW	13.50 kW
SCOP	4.10	3.20
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	13.50 kW	11.90 kW
COP Tj = -7°C	2.57	1.83
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	8.20 kW	7.20 kW
COP Tj = +2°C	4.13	3.17
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	6.30 kW	5.90 kW
COP Tj = +7°C	5.22	4.29
Cdh Tj = +7 °C	0.990	0.990

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	7.70 kW	7.40 kW
COP Tj = 12°C	7.08	6.32
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	13.50 kW	11.90 kW
COP Tj = Tbiv	2.57	1.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.50 kW	11.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.35	1.80
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.80 kW	2.20 kW
Annual energy consumption Qhe	7702 kWh	8716 kWh

## Model: PUAZ-SW160YKA(-BS) + ERSE-M\*C

### Configure model

Model name	PUHZ-SW160YKA(-BS) + ERSE-M*C
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

### General Data

Power supply	3x400V 50Hz
--------------	-------------

## Heating

### EN 14511-2

	Low temperature	Medium temperature
Heat output	22.00 kW	22.00 kW
El input	5.23 kW	8.91 kW
COP	4.21	2.47

### EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## Average Climate



This information was generated by the HP KEYMARK database on 22 Jun 2022

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)
Sound power level outdoor	78 dB(A)	78 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	163 %	126 %
Prated	15.30 kW	13.50 kW
SCOP	4.15	3.23
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	13.50 kW	11.90 kW
COP Tj = -7°C	2.57	1.83
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	8.20 kW	7.20 kW
COP Tj = +2°C	4.13	3.17
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	6.30 kW	5.90 kW
COP Tj = +7°C	5.22	4.29
Cdh Tj = +7 °C	0.990	0.990

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	7.70 kW	7.40 kW
COP Tj = 12°C	7.08	6.32
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	13.50 kW	11.90 kW
COP Tj = Tbiv	2.57	1.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.50 kW	11.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.35	1.80
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.80 kW	2.20 kW
Annual energy consumption Qhe	7621 kWh	8636 kWh

# Model: PUAZ-SW160YKA(-BS) + ERSE-\*M\*C

## Configure model

Model name	PUHZ-SW160YKA(-BS) + ERSE-*M*C
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

## General Data

Power supply	3x400V 50Hz
--------------	-------------

## Heating

### EN 14511-2

	Low temperature	Medium temperature
Heat output	22.00 kW	22.00 kW
El input	5.23 kW	8.91 kW
COP	4.21	2.47

### EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## Average Climate

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)
Sound power level outdoor	78 dB(A)	78 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	163 %	126 %
Prated	15.30 kW	13.50 kW
SCOP	4.15	3.23
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	13.50 kW	11.90 kW
COP Tj = -7°C	2.57	1.83
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	8.20 kW	7.20 kW
COP Tj = +2°C	4.13	3.17
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	6.30 kW	5.90 kW
COP Tj = +7°C	5.22	4.29
Cdh Tj = +7 °C	0.990	0.990

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	7.70 kW	7.40 kW
COP Tj = 12°C	7.08	6.32
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	13.50 kW	11.90 kW
COP Tj = Tbiv	2.57	1.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.50 kW	11.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.35	1.80
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.80 kW	2.20 kW
Annual energy consumption Qhe	7621 kWh	8636 kWh

## Model: PUAZ-SW160YKA(-BS) + EHSE-M\*D

### Configure model

Model name	PUHZ-SW160YKA(-BS) + EHSE-M*D
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

### General Data

Power supply	3x400V 50Hz
--------------	-------------

## Heating

### EN 14511-2

	Low temperature	Medium temperature
Heat output	22.00 kW	22.00 kW
El input	5.24 kW	8.91 kW
COP	4.20	2.47

### EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## Average Climate

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)
Sound power level outdoor	78 dB(A)	78 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	161 %	125 %
Prated	15.30 kW	13.50 kW
SCOP	4.10	3.20
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	13.50 kW	11.90 kW
COP Tj = -7°C	2.57	1.83
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	8.20 kW	7.20 kW
COP Tj = +2°C	4.13	3.17
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	6.30 kW	5.90 kW
COP Tj = +7°C	5.22	4.29
Cdh Tj = +7 °C	0.990	0.980

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	7.70 kW	7.40 kW
COP Tj = 12°C	7.08	6.32
Cdh Tj = +12 °C	0.990	0.980
Pdh Tj = Tbiv	13.50 kW	11.90 kW
COP Tj = Tbiv	2.57	1.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.50 kW	11.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.35	1.80
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.80 kW	2.20 kW
Annual energy consumption Qhe	7702 kWh	8716 kWh



# Model: PUAZ-SW160YKA(-BS) + EHSE-\*M\*D

Configure model	
Model name	PUHZ-SW160YKA(-BS) + EHSE-*M*D
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

## Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	22.00 kW	22.00 kW
El input	5.24 kW	8.91 kW
COP	4.20	2.47

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## Average Climate

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)
Sound power level outdoor	78 dB(A)	78 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	161 %	125 %
Prated	15.30 kW	13.50 kW
SCOP	4.10	3.20
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	13.50 kW	11.90 kW
COP Tj = -7°C	2.57	1.83
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	8.20 kW	7.20 kW
COP Tj = +2°C	4.13	3.17
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	6.30 kW	5.90 kW
COP Tj = +7°C	5.22	4.29
Cdh Tj = +7 °C	0.990	0.980

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	7.70 kW	7.40 kW
COP Tj = 12°C	7.08	6.32
Cdh Tj = +12 °C	0.990	0.980
Pdh Tj = Tbiv	13.50 kW	11.90 kW
COP Tj = Tbiv	2.57	1.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.50 kW	11.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.35	1.80
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.80 kW	2.20 kW
Annual energy consumption Qhe	7702 kWh	8716 kWh

## Model: PUAZ-SW160YKA(-BS) + ERSE-M\*D

Configure model	
Model name	PUHZ-SW160YKA(-BS) + ERSE-M*D
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

### Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	22.00 kW	22.00 kW
El input	5.24 kW	8.91 kW
COP	4.20	2.47

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### Average Climate

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)
Sound power level outdoor	78 dB(A)	78 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	163 %	126 %
Prated	15.30 kW	13.50 kW
SCOP	4.15	3.23
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	13.50 kW	11.90 kW
COP Tj = -7°C	2.57	1.83
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	8.20 kW	7.20 kW
COP Tj = +2°C	4.13	3.17
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	6.30 kW	5.90 kW
COP Tj = +7°C	5.22	4.29
Cdh Tj = +7 °C	0.990	0.980

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	7.70 kW	7.40 kW
COP Tj = 12°C	7.08	6.32
Cdh Tj = +12 °C	0.990	0.980
Pdh Tj = Tbiv	13.50 kW	11.90 kW
COP Tj = Tbiv	2.57	1.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.50 kW	11.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.35	1.80
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.80 kW	2.20 kW
Annual energy consumption Qhe	7621 kWh	8636 kWh

# Model: PUAZ-SW160YKA(-BS) + ERSE-\*M\*D

Configure model	
Model name	PUHZ-SW160YKA(-BS) + ERSE-*M*D
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

## Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	22.00 kW	22.00 kW
El input	5.24 kW	8.91 kW
COP	4.20	2.47

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## Average Climate

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	45 dB(A)	45 dB(A)
Sound power level outdoor	78 dB(A)	78 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	163 %	126 %
Prated	15.30 kW	13.50 kW
SCOP	4.15	3.23
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	13.50 kW	11.90 kW
COP Tj = -7°C	2.57	1.83
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	8.20 kW	7.20 kW
COP Tj = +2°C	4.13	3.17
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	6.30 kW	5.90 kW
COP Tj = +7°C	5.22	4.29
Cdh Tj = +7 °C	0.990	0.980



This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	7.70 kW	7.40 kW
COP Tj = 12°C	7.08	6.32
Cdh Tj = +12 °C	0.990	0.980
Pdh Tj = Tbiv	13.50 kW	11.90 kW
COP Tj = Tbiv	2.57	1.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.50 kW	11.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.35	1.80
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.80 kW	2.20 kW
Annual energy consumption Qhe	7621 kWh	8636 kWh