

This information was generated by the HP KEYMARK database on 22 Jun 2022

[Login](#)

Summary of	Samsung EHS R32 Split 9kW (wall-mounted hydro unit)		Reg. No.	011-1W0456
Certificate Holder				
Name	Samsung Electronics Air Conditioner Europe B.V.			
Address	Evert van de Beekstraat 310	Zip	1118 CX	
City	Schiphol	Country	Netherlands	
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH			
Subtype title	Samsung EHS R32 Split 9kW (wall-mounted hydro unit)			
Heat Pump Type	Outdoor Air/Water			
Refrigerant	R32			
Mass of Refrigerant	1.4 kg			
Certification Date	26.01.2021			
Testing basis	HP KEYMARK certification scheme rules V7			

# Model: AE090RXEDEG/EU & AE090RNYDEG/EU

Configure model	
Model name	AE090RXEDEG/EU & AE090RNYDEG/EU
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

## Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	9.00 kW	8.00 kW
El input	1.87 kW	2.73 kW
COP	4.81	2.93

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## Average Climate

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	175 %	127 %
Prated	9.00 kW	8.00 kW
SCOP	4.45	3.24
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.50 kW	7.10 kW
COP Tj = -7°C	2.64	1.76
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.60 kW	4.30 kW
COP Tj = +2°C	4.17	3.23
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	2.90 kW	2.80 kW
COP Tj = +7°C	6.53	4.62
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	2.70 kW	2.60 kW
COP Tj = 12°C	8.87	5.88
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.50 kW	7.10 kW
COP Tj = Tbiv	2.64	1.76
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.70 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.32	1.35
WTOL	65 °C	65 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.30 kW	3.10 kW
Annual energy consumption Qhe	3949 kWh	5103 kWh

# Model: AE090RXEDGG/EU & AE090RNYDGG/EU

Configure model	
Model name	AE090RXEDGG/EU & AE090RNYDGG/EU
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

## Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	9.00 kW	8.00 kW
El input	1.87 kW	2.73 kW
COP	4.81	2.93

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## Average Climate

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	175 %	127 %
Prated	9.00 kW	8.00 kW
SCOP	4.45	3.24
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.50 kW	7.10 kW
COP Tj = -7°C	2.64	1.76
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.60 kW	4.30 kW
COP Tj = +2°C	4.17	3.23
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	2.90 kW	2.80 kW
COP Tj = +7°C	6.53	4.62
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 22 Jun 2022

Pdh Tj = 12°C	2.70 kW	2.60 kW
COP Tj = 12°C	8.87	5.88
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.50 kW	7.10 kW
COP Tj = Tbiv	2.64	1.76
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.70 kW	4.90 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.32	1.35
WTOL	65 °C	65 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.30 kW	3.10 kW
Annual energy consumption Qhe	3949 kWh	5103 kWh