

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	CTA Aeroheat CM 18a	Reg. No.	012-SC0321-18
Certificate Holder			
Name	Enertech CTC AB		
Address	Box 309, Näsvägen	Zip	SE-381 26
City	Ljungby	Country	Sweden
Certification Body	RISE CERT		
Subtype title	CTA Aeroheat CM 18a		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R407c		
Mass of Refrigerant	2.7 kg		

Model: CTA Aeroheat CM 18a

Configure model	
Model name	CTA Aeroheat CM 18a
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.38 kW	9.35 kW
El input	2.25 kW	2.84 kW
COP	5.06	3.29

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	56 dB(A)	56 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	193 %	147 %
Prated	8.50 kW	8.50 kW
SCOP	4.92	3.77
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.76 kW	7.52 kW
COP Tj = -7°C	3.53	2.41
Pdh Tj = +2°C	4.49 kW	4.61 kW
COP Tj = +2°C	4.97	3.81
Pdh Tj = +7°C	4.81 kW	4.72 kW
COP Tj = +7°C	5.94	4.76
Pdh Tj = 12°C	5.56 kW	5.55 kW
COP Tj = 12°C	7.35	6.15
Pdh Tj = Tbiv	8.75 kW	8.66 kW
COP Tj = Tbiv	3.04	1.99

This information was generated by the HP KEYMARK database on 18 Mar 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	8.75 kW	8.66 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	3.04	1.99
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.98	0.99
WTOL	65 °C	65 °C
Poff	12 W	12 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q_{he}	3567 kWh	4656 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	56 dB(A)	56 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	167 %	136 %
Prated	12.50 kW	11.50 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

SCOP	4.26	3.47
Tbiv	-17 °C	-18 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	7.60 kW	7.29 kW
COP Tj = -7°C	3.67	2.91
Pdh Tj = +2°C	4.70 kW	4.63 kW
COP Tj = +2°C	5.49	4.53
Pdh Tj = +7°C	4.87 kW	4.76 kW
COP Tj = +7°C	6.70	5.28
Pdh Tj = 12°C	5.58 kW	5.55 kW
COP Tj = 12°C	7.77	6.44
Pdh Tj = Tbiv	11.35 kW	10.87 kW
COP Tj = Tbiv	1.99	1.46
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.92 kW	4.57 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.99	1.51
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.98	0.99
WTOL	65 °C	65 °C
Poff	12 W	12 W
PTO	12 W	12 W
PSB	12 W	12 W
PCK	0 W	0 W

This information was generated by the HP KEYMARK database on 18 Mar 2022

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	12.50 kW	11.50 kW
Annual energy consumption Q _{he}	7225 kWh	8159 kWh