

This information was generated by the HP KEYMARK database on 7 Jul 2022

[Login](#)

Summary of	F2120-8	Reg. No.	012-029
Certificate Holder			
Name	Nibe AB		
Address	Box 14	Zip	S-28521
City	Markaryd	Country	Sweden
Certification Body	RISE CERT		
Subtype title	F2120-8		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.4 kg		

Model: F2120-8 1x230

Configure model	
Model name	F2120-8 1x230
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	3.57 kW	3.75 kW
El input	0.78 kW	1.23 kW
COP	4.57	3.05

Colder Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	158 %	130 %
Prated	6.80 kW	7.40 kW
SCOP	4.02	3.32
Tbiv	-12 °C	-12 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.10 kW	4.50 kW
COP Tj = -7°C	3.30	2.74
Pdh Tj = +2°C	2.60 kW	2.70 kW
COP Tj = +2°C	5.20	4.10
Pdh Tj = +7°C	2.90 kW	2.90 kW
COP Tj = +7°C	5.52	4.65
Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	6.25	5.31
Pdh Tj = Tbiv	5.00 kW	5.50 kW
COP Tj = Tbiv	3.00	2.50

This information was generated by the HP KEYMARK database on 7 Jul 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	3.80 kW	4.30 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	2.30	1.85
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.99	0.99
WTOL	65 °C	65 °C
Poff	25 W	25 W
PTO	10 W	10 W
PSB	25 W	25 W
PCK	37 W	37 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.10 kW	3.10 kW
Annual energy consumption Q_{he}	4182 kWh	5524 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	189 %	147 %
Prated	5.90 kW	6.30 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

SCOP	4.80	3.67
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.20 kW	5.50 kW
COP Tj = -7°C	3.25	2.48
Pdh Tj = +2°C	4.00 kW	4.10 kW
COP Tj = +2°C	4.91	3.80
Pdh Tj = +7°C	2.90 kW	2.90 kW
COP Tj = +7°C	5.60	4.45
Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	6.40	5.26
Pdh Tj = Tbiv	5.20 kW	5.50 kW
COP Tj = Tbiv	3.25	2.48
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.30 kW	5.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.12	2.34
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99
WTOL	65 °C	65 °C
Poff	25 W	25 W
PTO	10 W	10 W
PSB	25 W	25 W
PCK	37 W	37 W

This information was generated by the HP KEYMARK database on 7 Jul 2022

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.60 kW	0.60 kW
Annual energy consumption Q _{he}	4182 kWh	5524 kWh

Model: F2120-8 3x400

Configure model	
Model name	F2120-8 3x400
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	3.57 kW	3.75 kW
El input	0.78 kW	1.23 kW
COP	4.57	3.05

Colder Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	158 %	130 %
Prated	6.80 kW	7.40 kW
SCOP	4.02	3.32
Tbiv	-12 °C	-12 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.10 kW	4.50 kW
COP Tj = -7°C	3.30	2.74
Pdh Tj = +2°C	2.60 kW	2.70 kW
COP Tj = +2°C	5.20	4.10
Pdh Tj = +7°C	2.90 kW	2.90 kW
COP Tj = +7°C	5.52	4.65
Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	6.25	5.31
Pdh Tj = Tbiv	5.00 kW	5.50 kW
COP Tj = Tbiv	3.00	2.50

This information was generated by the HP KEYMARK database on 7 Jul 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	3.80 kW	4.30 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	2.30	1.85
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.99	0.99
WTOL	65 °C	65 °C
Poff	25 W	25 W
PTO	10 W	10 W
PSB	25 W	25 W
PCK	37 W	37 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	3.10 kW	3.10 kW
Annual energy consumption Q_{he}	4182 kWh	5524 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	189 %	147 %
Prated	5.90 kW	6.30 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

SCOP	4.80	3.67
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.20 kW	5.50 kW
COP Tj = -7°C	3.25	2.48
Pdh Tj = +2°C	4.00 kW	4.10 kW
COP Tj = +2°C	4.91	3.80
Pdh Tj = +7°C	2.90 kW	2.90 kW
COP Tj = +7°C	5.60	4.45
Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	6.40	5.26
Pdh Tj = Tbiv	5.20 kW	5.50 kW
COP Tj = Tbiv	3.25	2.48
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.30 kW	5.70 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.12	2.34
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.99	0.99
WTOL	65 °C	65 °C
Poff	25 W	25 W
PTO	10 W	10 W
PSB	25 W	25 W
PCK	37 W	37 W

This information was generated by the HP KEYMARK database on 7 Jul 2022

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.60 kW	0.60 kW
Annual energy consumption Q _{he}	4182 kWh	5524 kWh