

This information was generated by the HP KEYMARK database on 23 Jun 2022

[Login](#)

Summary of	ecoAIR 3-18 PRO	Reg. No.	011-1W0442
Certificate Holder			
Name	Ecoforest Geotermia S.L.		
Address	Rúa das Pontes, 25	Zip	36350
City	Nigrán (Pontevedra)	Country	Spain
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	ecoAIR 3-18 PRO		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R290		
Mass of Refrigerant	1.37 kg		
Certification Date	22.11.2021		
Testing basis	Europäisches Zertifizierungsprogramm Wärmepumpen KEYMARK Version8 (Stand: 2020-09)		

Model: ecoAIR T 3-18 PRO

Configure model	
Model name	ecoAIR T 3-18 PRO
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	7.53 kW	8.48 kW
El input	1.50 kW	2.53 kW
COP	5.02	3.35

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	0 dB(A)	0 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	236 %	188 %
Prated	11.70 kW	11.00 kW
SCOP	5.98	4.77
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.69 kW	10.96 kW
COP Tj = +2°C	3.04	2.19
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	8.22 kW	7.47 kW
COP Tj = +7°C	5.70	4.25
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.99 kW	7.27 kW
COP Tj = 12°C	7.27	6.27
Cdh Tj = +12 °C	0.990	0.990

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = Tbiv	11.69 kW	10.96 kW
COP Tj = Tbiv	3.04	2.19
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.69 kW	10.96 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.04	2.19
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	70 °C	70 °C
Poff	0 W	0 W
PTO	9 W	9 W
PSB	8 W	8 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2613 kWh	3079 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	0 dB(A)	0 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	Low temperature	Medium temperature
η_s	145 %	124 %
Prated	10.00 kW	10.00 kW
SCOP	3.70	3.16
Tbiv	-15 °C	-15 °C
TOL	-15 °C	-15 °C
Pdh Tj = -7°C	5.95 kW	6.04 kW
COP Tj = -7°C	3.73	3.16
Cdh Tj = -7 °C	0.990	1.000
Pdh Tj = +2°C	4.47 kW	4.64 kW
COP Tj = +2°C	4.26	3.47
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	7.64 kW	6.48 kW
COP Tj = +7°C	6.50	5.65
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	4.80 kW	6.46 kW
COP Tj = 12°C	7.22	6.96
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	8.16 kW	8.15 kW
COP Tj = Tbiv	3.11	2.40
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.16 kW	8.15 kW

This information was generated by the HP KEYMARK database on 23 Jun 2022

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.11	2.40
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	70 °C	70 °C
Poff	0 W	0 W
PTO	9 W	9 W
PSB	8 W	8 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	10.00 kW	10.00 kW
Annual energy consumption Qhe	6661 kWh	7795 kWh
Pdh Tj = -15°C (if TOL<-20°C)		
COP Tj = -15°C (if TOL<-20°C)		
Cdh Tj = -15 °C		

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	0 dB(A)	0 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	Low temperature	Medium temperature
η_s	175 %	138 %
Prated	10.60 kW	10.50 kW
SCOP	4.46	3.53
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.44 kW	9.26 kW
COP Tj = -7°C	3.30	2.40
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	5.76 kW	5.63 kW
COP Tj = +2°C	3.97	3.13
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	6.56 kW	6.18 kW
COP Tj = +7°C	6.27	5.18
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	4.25 kW	6.14 kW
COP Tj = 12°C	7.00	6.65
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	10.55 kW	10.47 kW
COP Tj = Tbiv	3.14	2.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.55 kW	10.47 kW

This information was generated by the HP KEYMARK database on 23 Jun 2022

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.14	2.22
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	70 °C	70 °C
Poff	0 W	0 W
PTO	9 W	9 W
PSB	8 W	8 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	4914 kWh	6144 kWh

Model: ecoAIR 3-18 PRO

Configure model	
Model name	ecoAIR 3-18 PRO
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	7.53 kW	8.48 kW
El input	1.50 kW	2.53 kW
COP	5.02	3.35

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	0 dB(A)	0 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	236 %	188 %
Prated	11.70 kW	11.00 kW
SCOP	5.98	4.77
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.69 kW	10.96 kW
COP Tj = +2°C	3.04	2.19
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	8.22 kW	7.47 kW
COP Tj = +7°C	5.70	4.25
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	6.99 kW	7.27 kW
COP Tj = 12°C	7.27	6.27
Cdh Tj = +12 °C	0.990	0.990

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = Tbiv	11.69 kW	10.96 kW
COP Tj = Tbiv	3.04	2.19
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.69 kW	10.96 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.04	2.19
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	70 °C	70 °C
Poff	0 W	0 W
PTO	9 W	9 W
PSB	8 W	8 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2613 kWh	3079 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	0 dB(A)	0 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	Low temperature	Medium temperature
η_s	145 %	124 %
Prated	10.00 kW	10.00 kW
SCOP	3.70	3.16
Tbiv	-15 °C	-15 °C
TOL	-15 °C	-15 °C
Pdh Tj = -7°C	5.95 kW	6.04 kW
COP Tj = -7°C	3.73	3.16
Cdh Tj = -7 °C	0.990	1.000
Pdh Tj = +2°C	4.47 kW	4.64 kW
COP Tj = +2°C	4.26	3.47
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	7.64 kW	6.48 kW
COP Tj = +7°C	6.50	5.65
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	4.80 kW	6.46 kW
COP Tj = 12°C	7.22	6.96
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	8.16 kW	8.15 kW
COP Tj = Tbiv	3.11	2.40
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.16 kW	8.15 kW

This information was generated by the HP KEYMARK database on 23 Jun 2022

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.11	2.40
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	70 °C	70 °C
Poff	0 W	0 W
PTO	9 W	9 W
PSB	8 W	8 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	10.00 kW	10.00 kW
Annual energy consumption Qhe	6661 kWh	7795 kWh
Pdh Tj = -15°C (if TOL<-20°C)		
COP Tj = -15°C (if TOL<-20°C)		
Cdh Tj = -15 °C		

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	0 dB(A)	0 dB(A)
Sound power level outdoor	57 dB(A)	57 dB(A)

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	Low temperature	Medium temperature
η_s	175 %	138 %
Prated	10.60 kW	10.50 kW
SCOP	4.46	3.53
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.44 kW	9.26 kW
COP Tj = -7°C	3.30	2.40
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	5.76 kW	5.63 kW
COP Tj = +2°C	3.97	3.13
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	6.56 kW	6.18 kW
COP Tj = +7°C	6.27	5.18
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	4.25 kW	6.14 kW
COP Tj = 12°C	7.00	6.65
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	10.55 kW	10.47 kW
COP Tj = Tbiv	3.14	2.22
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.55 kW	10.47 kW

This information was generated by the HP KEYMARK database on 23 Jun 2022

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.14	2.22
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	70 °C	70 °C
Poff	0 W	0 W
PTO	9 W	9 W
PSB	8 W	8 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	4914 kWh	6144 kWh