

Page 1 of 5

This information was generated by the HP KEYMARK database on 22 Jun 2022

<u>Login</u>

Summary of	Versati monobloc G1 8kW	Reg. No.	041-K004-03	
Certificate Holder				
Name	Gree Electric Appliances, Inc. of Zhuha	Gree Electric Appliances, Inc. of Zhuhai		
Address	West Jinji Rd	Zip	519070	
City	Qianshan, Zhuhai, Guangdong	Country	China	
Certification Body	BRE Global Limited	·		
Subtype title	Versati monobloc G1 8kW			
Heat Pump Type	Outdoor Air/Water			
Refrigerant	R32			
Mass of Refrigerant	0.87 kg			
Certification Date	27.07.2020			
Testing basis	Scheme Rules Rev 07			



This information was generated by the HP KEYMARK database on 22 Jun 2022

Model: GRS-CQ8.0Pd/NhG-K+SXTVD300LCJ2/A-K

Configure model		
Model name	GRS-CQ8.0Pd/NhG-K+SXTVD300LCJ2/A-K	
Application	Heating + DHW	
Units	Outdoor	
Climate Zone	n/a	
Reversibility	Yes	
Cooling mode application (optional)	n/a	

General Data		
Power supply	1x230V 50Hz	

Heating

EN 14511-2		
	Medium temperature	
Heat output	6.50 kW	
El input	2.40 kW	
СОР	2.71	

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate



This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1	
	Medium temperature
Sound power level outdoor	65 dB(A)

EN 14825		
	Medium temperature	
η_s	127 %	
Prated	7.00 kW	
SCOP	3.27	
Tbiv	-7 °C	
TOL	-10 °C	
Pdh Tj = -7°C	6.20 kW	
COP Tj = -7°C	2.22	
Cdh Tj = -7 °C	0.96	
Pdh Tj = +2°C	4.00 kW	
COP Tj = +2°C	3.13	
Cdh Tj = +2 °C	0.96	
Pdh Tj = +7°C	2.43 kW	
$COP Tj = +7^{\circ}C$	4.26	
Cdh Tj = +7 °C	0.96	
Pdh Tj = 12°C	2.98 kW	

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





This information was generated by the Till RETHARK database on 22 juli 202		
COP Tj = 12°C	5.52	
Cdh Tj = +12 °C	0.96	
Pdh Tj = Tbiv	6.20 kW	
COP Tj = Tbiv	2.22	
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.34 kW	
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.78	
WTOL	55 °C	
Poff	18 W	
РТО	18 W	
PSB	18 W	
PCK	0 W	
Supplementary Heater: Type of energy input	Electricity	
Supplementary Heater: PSUP	2.66 kW	
Annual energy consumption Qhe	4423 kWh	

Domestic Hot Water (DHW)

Average Climate





 $$\operatorname{\textit{Page}}\xspace\:5\:\:\text{of}\:5\:$ This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 16147		
Declared load profile	XL	
Efficiency ηDHW	106 %	
СОР	2.53	
Heating up time	2:59 h:min	
Standby power input	62.2 W	
Reference hot water temperature	51.7 °C	
Mixed water at 40°C	379	