

## Page 1 of 4 This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	Ideal Boiler Alféa Extensa A.I. 10	Reg. No.	012-SC0140-19
Certificate Holder			-
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Name of testing laboratory	RISE		
Subtype title	Ideal Boiler Alféa Extensa A.I. 10		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	1.8 kg		
Certification Date	04.04.2020		



This information was generated by the HP KEYMARK database on 17 Dec 2020

## Model: Alféa Extensa A.I. 10

General Data	
Power supply	1x230V 50Hz

## Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	10.00 kW	7.00 kW	
El input	2.49 kW	2.86 kW	
СОР	4.02	2.45	
Indoor water flow rate	1.80 m³/h	0.75 m³/h	

EN 14511-4		
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed	
	pusseu	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	

## **Average Climate**



 $$\operatorname{\textit{Page}}\xspace$  3 of 4 This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	69 dB(A)	69 dB(A)

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	155 %	113 %
Prated	8.00 kW	8.00 kW
SCOP	3.95	2.90
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.50 kW	6.70 kW
COP Tj = -7°C	2.40	1.70
Pdh Tj = +2°C	4.50 kW	4.10 kW
COP Tj = +2°C	3.80	2.70
Pdh Tj = +7°C	3.50 kW	3.20 kW
COP Tj = +7°C	5.70	4.10
Pdh Tj = 12°C	4.00 kW	4.00 kW
COP Tj = 12°C	7.20	5.70
Pdh Tj = Tbiv	7.50 kW	6.70 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



 $$\operatorname{\textit{Page}}$4$ of 4$ This information was generated by the HP KEYMARK database on 17 Dec 2020$ 

COP Tj = Tbiv	2.40	1.70
Pdh Tj = TOL	7.00 kW	5.90 kW
COP Tj = TOL	2.20	1.40
Cdh	0.90	0.90
WTOL	55 °C	55 °C
Poff	5 W	5 W
РТО	43 W	22 W
PSB	8 W	8 W
PCK	0 W	o w
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.40 kW	1.70 kW
Annual energy consumption Qhe	4415 kWh	5415 kWh