

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	CTC EcoPart 412	Reg. No.	012-065
Certificate Holder			
Name	Eneritech CTC AB		
Address	Box 309, Näsvägen	Zip	SE-381 26
City	Ljungby	Country	Sweden
Certification Body	RISE CERT		
Subtype title	CTC EcoPart 412		
Heat Pump Type	Brine/Water		
Refrigerant	R407c		
Mass of Refrigerant	2.3 kg		

Model: CTC EcoPart 412 1x230V

Configure model	
Model name	CTC EcoPart 412 1x230V
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.75 kW	10.97 kW
El input	2.56 kW	3.57 kW
COP	4.60	3.08

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	50 dB(A)	50 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	182 %	138 %
Prated	13.35 kW	12.49 kW
SCOP	4.80	3.65
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.80 kW	11.00 kW
COP Tj = -7°C	4.69	3.25
Pdh Tj = +2°C	11.90 kW	11.20 kW
COP Tj = +2°C	4.88	3.64
Pdh Tj = +7°C	12.00 kW	11.40 kW
COP Tj = +7°C	5.06	4.02
Pdh Tj = 12°C	12.10 kW	11.60 kW
COP Tj = 12°C	5.23	4.40
Pdh Tj = Tbiv	11.80 kW	11.20 kW
COP Tj = Tbiv	4.69	3.25

This information was generated by the HP KEYMARK database on 18 Mar 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	11.75 kW	10.97 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	4.60	3.08
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.98	0.99
WTOL	65 °C	65 °C
Poff	18 W	18 W
PTO	22 W	5 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.60 kW	1.50 kW
Annual energy consumption Q_{he}	5814 kWh	7084 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	50 dB(A)	50 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	185 %	141 %
Prated	12.44 kW	12.35 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

SCOP	4.80	3.70
Tbiv	-20 °C	-18 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	11.90 kW	11.20 kW
COP Tj = -7°C	4.89	3.56
Pdh Tj = +2°C	12.00 kW	11.40 kW
COP Tj = +2°C	5.06	3.94
Pdh Tj = +7°C	12.10 kW	11.60 kW
COP Tj = +7°C	5.18	4.29
Pdh Tj = 12°C	12.10 kW	11.70 kW
COP Tj = 12°C	5.20	4.54
Pdh Tj = Tbiv	11.80 kW	11.20 kW
COP Tj = Tbiv	4.66	3.25
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.75 kW	10.97 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.60	3.08
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.98	0.99
WTOL	65 °C	65 °C
Poff	18 W	18 W
PTO	22 W	5 W
PSB	18 W	18 W
PCK	0 W	0 W

This information was generated by the HP KEYMARK database on 18 Mar 2022

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.70 kW	1.40 kW
Annual energy consumption Q _{he}	6373 kWh	8195 kWh

Model: CTC EcoPart 412 3x400V

Configure model	
Model name	CTC EcoPart 412 3x400V
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.75 kW	10.97 kW
El input	2.56 kW	3.57 kW
COP	4.60	3.08

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	50 dB(A)	50 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	182 %	138 %
Prated	13.35 kW	12.49 kW
SCOP	4.80	3.65
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.80 kW	11.00 kW
COP Tj = -7°C	4.69	3.25
Pdh Tj = +2°C	11.90 kW	11.20 kW
COP Tj = +2°C	4.88	3.64
Pdh Tj = +7°C	12.00 kW	11.40 kW
COP Tj = +7°C	5.06	4.02
Pdh Tj = 12°C	12.10 kW	11.60 kW
COP Tj = 12°C	5.23	4.40
Pdh Tj = Tbiv	11.80 kW	11.20 kW
COP Tj = Tbiv	4.69	3.25

This information was generated by the HP KEYMARK database on 18 Mar 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	11.75 kW	10.97 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	4.60	3.08
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.98	0.99
WTOL	65 °C	65 °C
Poff	18 W	18 W
PTO	22 W	5 W
PSB	18 W	18 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.60 kW	1.50 kW
Annual energy consumption Q_{he}	5814 kWh	7084 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	50 dB(A)	50 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	185 %	141 %
Prated	12.44 kW	12.35 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

SCOP	4.80	3.70
Tbiv	-20 °C	-18 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	11.90 kW	11.20 kW
COP Tj = -7°C	4.89	3.56
Pdh Tj = +2°C	12.00 kW	11.40 kW
COP Tj = +2°C	5.06	3.94
Pdh Tj = +7°C	12.10 kW	11.60 kW
COP Tj = +7°C	5.18	4.29
Pdh Tj = 12°C	12.10 kW	11.70 kW
COP Tj = 12°C	5.20	4.54
Pdh Tj = Tbiv	11.80 kW	11.20 kW
COP Tj = Tbiv	4.66	3.25
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.75 kW	10.97 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.60	3.08
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.98	0.99
WTOL	65 °C	65 °C
Poff	18 W	18 W
PTO	22 W	5 W
PSB	18 W	18 W
PCK	0 W	0 W

This information was generated by the HP KEYMARK database on 18 Mar 2022

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.70 kW	1.40 kW
Annual energy consumption Q _{he}	6373 kWh	8195 kWh