

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	31. Yutaki S (N1) & S Combi (NW1) 220L 4HP R410A (3ph)	Reg. No.	041-K002-52
Certificate Holder			
Name	Johnson Controls-Hitachi AirConditioning Spain		
Address	Ronda Shimizu, 1. Pol. Ind. Can Torrella	Zip	08233
City	Vacarisses, Barcelona	Country	Spain
Certification Body	BRE Global Limited		
Subtype title	31. Yutaki S (N1) & S Combi (NW1) 220L 4HP R410A (3ph)		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	3.3 kg		
Certification Date	08.02.2022		
Testing basis	Heat Pump Keymark Scheme Rules Rev 09		

Model: 03. RAS-4WHNPE RWD-4.0NW1E-220S - Heating Only

Configure model	
Model name	03. RAS-4WHNPE RWD-4.0NW1E-220S - Heating Only
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.00 kW	11.00 kW
El input	2.20 kW	3.67 kW
COP	5.00	3.00

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	180 %	135 %
Prated	11.00 kW	10.00 kW
SCOP	4.58	3.44
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.45 kW	8.60 kW
COP Tj = -7°C	3.05	1.80
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.75 kW	5.23 kW
COP Tj = +2°C	4.50	3.60
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.70 kW	3.52 kW
COP Tj = +7°C	6.00	4.80
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.70 kW	3.60 kW
COP Tj = 12°C	7.50	5.80
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	9.45 kW	8.60 kW
COP Tj = Tbiv	3.05	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.50 kW	7.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.65	1.70
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.50 kW	2.60 kW
Annual energy consumption Qhe	4823 kWh	5837 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	127 %
COP	3.10
Heating up time	1:05 h:min
Standby power input	34.0 W
Reference hot water temperature	52.6 °C
Mixed water at 40°C	288 l

Model: 04. RAS-4WHNPE RWD-4.0NW1E-220S - with cooling kit

Configure model	
Model name	04. RAS-4WHNPE RWD-4.0NW1E-220S - with cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C and +18°C/+23°C

General Data	
Power supply	n/a

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.00 kW	11.00 kW
El input	2.20 kW	3.67 kW
COP	5.00	3.00

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	183 %	136 %
Prated	11.00 kW	10.00 kW
SCOP	4.64	3.44
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.45 kW	8.60 kW
COP Tj = -7°C	3.05	1.80
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.75 kW	5.23 kW
COP Tj = +2°C	4.50	3.60
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.70 kW	3.52 kW
COP Tj = +7°C	6.00	4.80
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.70 kW	3.60 kW
COP Tj = 12°C	7.50	5.80
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	9.45 kW	8.60 kW
COP Tj = Tbiv	3.05	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.50 kW	7.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.65	1.70
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.50 kW	2.60 kW
Annual energy consumption Qhe	4753 kWh	5767 kWh

Cooling

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	1.87 kW	2.31 kW
Cooling capacity	7.20	10.40
EER	3.84	4.50

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C	+18°C/+23°C
P _{designc}	7.20 kW	10.40 kW
SEER	5.00	6.22
P _{dc} T _j = 35°C	7.20 kW	10.40 kW
EER T _j = 35°C	3.84	4.50
P _{dc} T _j = 30°C	5.30 kW	7.66 kW
EER T _j = 30°C	4.60	6.30
C _{dc}	0.900	0.900
P _{dc} T _j = 25°C	3.50 kW	4.93 kW
EER T _j = 25°C	5.80	7.20
C _{dc}	0.900	0.900
P _{dc} T _j = 20°C	3.60 kW	5.10 kW
EER T _j = 20°C	7.50	8.20
C _{dc}	0.900	0.900
P _{off}	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Annual energy consumption Q _{ce}	504 kWh	585 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	127 %
COP	3.10
Heating up time	1:05 h:min
Standby power input	34.0 W
Reference hot water temperature	52.6 °C
Mixed water at 40°C	288 l

Model: 05. RAS-4WHNPE RWD-4.0NW1E-220S-K - UK Version - Heating Only

Configure model	
Model name	05. RAS-4WHNPE RWD-4.0NW1E-220S-K - UK Version - Heating Only
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.00 kW	11.00 kW
El input	2.20 kW	3.67 kW
COP	5.00	3.00

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	180 %	135 %
Prated	11.00 kW	10.00 kW
SCOP	4.58	3.44
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.45 kW	8.60 kW
COP Tj = -7°C	3.05	1.80
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.75 kW	5.23 kW
COP Tj = +2°C	4.50	3.60
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.70 kW	3.52 kW
COP Tj = +7°C	6.00	4.80
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.70 kW	3.60 kW
COP Tj = 12°C	7.50	5.80
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	9.45 kW	8.60 kW
COP Tj = Tbiv	3.05	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.50 kW	7.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.65	1.70
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.50 kW	2.60 kW
Annual energy consumption Qhe	4823 kWh	5837 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	127 %
COP	3.10
Heating up time	1:05 h:min
Standby power input	34.0 W
Reference hot water temperature	52.6 °C
Mixed water at 40°C	288 l

Model: 06. RAS-4WHNPE RWD-4.0NW1E-220S-K - UK Version - with cooling kit

Configure model	
Model name	06. RAS-4WHNPE RWD-4.0NW1E-220S-K - UK Version - with cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C and +18°C/+23°C

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.00 kW	11.00 kW
El input	2.20 kW	3.67 kW
COP	5.00	3.00

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	183 %	136 %
Prated	11.00 kW	10.00 kW
SCOP	4.64	3.44
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.45 kW	8.60 kW
COP Tj = -7°C	3.05	1.80
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.75 kW	5.23 kW
COP Tj = +2°C	4.50	3.60
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.70 kW	3.52 kW
COP Tj = +7°C	6.00	4.80
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.70 kW	3.60 kW
COP Tj = 12°C	7.50	5.80
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	9.45 kW	8.60 kW
COP Tj = Tbiv	3.05	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.50 kW	7.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.65	1.70
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.50 kW	2.60 kW
Annual energy consumption Qhe	4753 kWh	5767 kWh

Cooling

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	1.87 kW	2.31 kW
Cooling capacity	7.20	10.40
EER	3.84	4.50

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C	+18°C/+23°C
P _{designc}	7.20 kW	10.40 kW
SEER	5.00	6.22
P _{dc} T _j = 35°C	7.20 kW	10.40 kW
EER T _j = 35°C	3.84	4.50
P _{dc} T _j = 30°C	5.30 kW	7.66 kW
EER T _j = 30°C	4.60	6.30
C _{dc}	0.900	0.900
P _{dc} T _j = 25°C	3.50 kW	4.93 kW
EER T _j = 25°C	5.80	7.20
C _{dc}	0.900	0.900
P _{dc} T _j = 20°C	3.60 kW	5.10 kW
EER T _j = 20°C	7.50	8.20
C _{dc}	0.900	0.900
P _{off}	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Annual energy consumption Q _{ce}	504 kWh	585 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	127 %
COP	3.10
Heating up time	1:05 h:min
Standby power input	34.0 W
Reference hot water temperature	52.6 °C
Mixed water at 40°C	288 l

Model: 01. RAS-4WHNPE RWM-4.0N1E - Heating Only

Configure model	
Model name	01. RAS-4WHNPE RWM-4.0N1E - Heating Only
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.00 kW	11.00 kW
El input	2.20 kW	3.67 kW
COP	5.00	3.00

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	180 %	135 %
Prated	11.00 kW	10.00 kW
SCOP	4.58	3.44
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.45 kW	8.60 kW
COP Tj = -7°C	3.05	1.80
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.75 kW	5.23 kW
COP Tj = +2°C	4.50	3.60
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.70 kW	3.52 kW
COP Tj = +7°C	6.00	4.80
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.70 kW	3.60 kW
COP Tj = 12°C	7.50	5.80
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	9.45 kW	8.60 kW
COP Tj = Tbiv	3.05	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.50 kW	7.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.65	1.70
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.50 kW	2.60 kW
Annual energy consumption Qhe	4823 kWh	5837 kWh

Model: 02. RAS-4WHNPE RWM-4.0N1E - with cooling kit

Configure model	
Model name	02. RAS-4WHNPE RWM-4.0N1E - with cooling kit
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C and +18°C/+23°C

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.00 kW	11.00 kW
El input	2.20 kW	3.67 kW
COP	5.00	3.00

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	58 dB(A)	58 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	183 %	136 %
Prated	11.00 kW	10.00 kW
SCOP	4.64	3.44
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.45 kW	8.60 kW
COP Tj = -7°C	3.05	1.80
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.75 kW	5.23 kW
COP Tj = +2°C	4.50	3.60
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.70 kW	3.52 kW
COP Tj = +7°C	6.00	4.80
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.70 kW	3.60 kW
COP Tj = 12°C	7.50	5.80
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	9.45 kW	8.60 kW
COP Tj = Tbiv	3.05	1.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.50 kW	7.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.65	1.70
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	55 °C	55 °C
Poff	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.50 kW	2.60 kW
Annual energy consumption Qhe	4753 kWh	5767 kWh

Cooling

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	1.87 kW	2.31 kW
Cooling capacity	7.20	10.40
EER	3.84	4.50

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C	+18°C/+23°C
P _{designc}	7.20 kW	10.40 kW
SEER	5.00	6.22
P _{dc} T _j = 35°C	7.20 kW	10.40 kW
EER T _j = 35°C	3.84	4.50
P _{dc} T _j = 30°C	5.30 kW	7.66 kW
EER T _j = 30°C	4.60	6.30
C _{dc}	0.900	0.900
P _{dc} T _j = 25°C	3.50 kW	4.93 kW
EER T _j = 25°C	5.80	7.20
C _{dc}	0.900	0.900
P _{dc} T _j = 20°C	3.60 kW	5.10 kW
EER T _j = 20°C	7.50	8.20
C _{dc}	0.900	0.900
P _{off}	19 W	19 W
PTO	0 W	0 W
PSB	19 W	19 W
PCK	0 W	0 W
Annual energy consumption Q _{ce}	504 kWh	585 kWh