

Page 1 of 10

This information was generated by the HP KEYMARK database on 18 Mar 2022

Login

Summary of	Vitocal 2xx-A ODU2	Reg. No.	011-1W0147
Certificate Holder	Certificate Holder		
Name	Viessmann Wärmepumpen GmbH	Viessmann Wärmepumpen GmbH	
Address	Viessmannstr. 1	Zip	35107
City	Allendorf/Eder	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	Vitocal 2xx-A ODU2		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	1.4 kg		



Model: Vitocal 200-A AWO-M 201.A08

Configure model		
Model name Vitocal 200-A AWO-M 201.A08		
Application	Heating (medium temp)	
Units	Indoor + Outdoor	
Climate Zone	n/a	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply 1x230V 50Hz		

Heating

EN 14511-4		
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	

EN 14511-2		
Low temperature Medium temperature		Medium temperature
Heat output	5.62 kW	4.97 kW
El input	1.19 kW	1.81 kW
СОР	4.71	2.76



EN 14825

Pdesignh

6.82 kW

Rated airflow rate

2600 m³/h

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	39 dB(A)	39 dB(A)
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{S}	175 %	127 %
Prated	6.82 kW	6.41 kW
SCOP	4.46	3.25
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7° C	6.04 kW	5.67 kW
COP Tj = -7° C	3.07	2.15
Pdh Tj = $+2$ °C	3.67 kW	3.53 kW
$COPTj = +2^{\circ}C$	4.35	3.10

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



govern		TR database on 10 Mai 2022
Pdh Tj = $+7^{\circ}$ C	4.36 kW	4.14 kW
$COP Tj = +7^{\circ}C$	5.70	4.26
Pdh Tj = 12°C	4.17 kW	4.01 kW
COP Tj = 12°C	7.17	5.72
Pdh Tj = Tbiv	6.04 kW	5.67 kW
COP Tj = Tbiv	3.07	2.15
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.41 kW	5.38 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.74	1.99
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.98	0.99
WTOL	60 °C	60 °C
Poff	14 W	14 W
РТО	0 W	o w
PSB	16 W	16 W
PCK	0 W	o w
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.45 kW	1.06 kW
Annual energy consumption Qhe	3163 kWh	4071 kWh



Model: Vitocal 200-A AWO-M-E-AC 201.A08

Configure model		
Model name	Vitocal 200-A AWO-M-E-AC 201.A08	
Application	Heating (medium temp)	
Units	Indoor + Outdoor	
Climate Zone	n/a	
Reversibility	No	
Cooling mode application (optional) n/a		

General Data		
Power supply 1x230V 50Hz		

Heating

EN 14511-4		
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	

EN 14511-2		
Low temperature Medium temperature		
Heat output	5.62 kW	4.97 kW
El input	1.19 kW	1.81 kW
СОР	4.71	2.76



EN 14825		
Pdesignh	6.82 kW	
Rated airflow rate	2600 m³/h	

Average Climate

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	39 dB(A)	39 dB(A)	
Sound power level outdoor	55 dB(A)	56 dB(A)	

EN 14825			
	Low temperature	Medium temperature	
η_{S}	175 %	127 %	
Prated	6.82 kW	6.41 kW	
SCOP	4.46	3.25	
Tbiv	-7 °C	-7 °C	
TOL	-20 °C	-20 °C	
Pdh Tj = -7° C	6.04 kW	5.67 kW	
COP Tj = -7° C	3.07	2.15	
Pdh Tj = $+2$ °C	3.67 kW	3.53 kW	
$COPTj = +2^{\circ}C$	4.35	3.10	

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



PCK

Supplementary Heater: Type of energy input

Supplementary Heater: PSUP

Annual energy consumption Qhe

Page 7 of 10

This information was generated by the HP KEYMARK database on 18 Mar 2022 Pdh Tj = $+7^{\circ}$ C 4.36 kW 4.14 kW $COPTj = +7^{\circ}C$ 5.70 4.26 Pdh Tj = 12° C 4.17 kW 4.01 kW $COP Tj = 12^{\circ}C$ 7.17 5.72 Pdh Tj = Tbiv6.04 kW 5.67 kW 3.07 COP Tj = Tbiv2.15 Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh 5.38 kW 5.41 kW COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh 2.74 1.99 Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh 0.98 0.99 60 °C WTOL 60 °C 14 W Poff 14 W PTO 0 W 0 W **PSB** 16 W 16 W

0 W

Electricity

1.45 kW

3163 kWh

0 W

Electricity

1.06 kW

4071 kWh



Model: Vitocal 200-A AWO-E-M 201.A08

Configure model		
Model name	Vitocal 200-A AWO-E-M 201.A08	
Application	Heating (medium temp)	
Units	Indoor + Outdoor	
Climate Zone	n/a	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply	1x230V 50Hz	

Heating

EN 14511-4		
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed	
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	

EN 14511-2			
Low temperature Medium temperature			
Heat output	5.62 kW	4.97 kW	
El input	1.19 kW	1.81 kW	
СОР	4.71	2.76	



EN 14825		
Pdesignh	6.82 kW	
Rated airflow rate	2600 m³/h	

Average Climate

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	39 dB(A)	39 dB(A)	
Sound power level outdoor	55 dB(A)	55 dB(A)	

EN 14825			
	Low temperature	Medium temperature	
η_{s}	175 %	127 %	
Prated	6.82 kW	6.41 kW	
SCOP	4.46	3.25	
Tbiv	-7 °C	-7 °C	
TOL	-20 °C	-20 °C	
Pdh Tj = -7°C	6.04 kW	5.67 kW	
COP Tj = -7°C	3.07	2.15	
Pdh Tj = +2°C	3.67 kW	3.53 kW	
$COP Tj = +2^{\circ}C$	4.35	3.10	

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



$$\operatorname{Page}\ 10$$ of 10 This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = $+7^{\circ}$ C	4.36 kW	4.14 kW
$COP Tj = +7^{\circ}C$	5.70	4.26
Pdh Tj = 12°C	4.17 kW	4.01 kW
COP Tj = 12°C	7.17	5.72
Pdh Tj = Tbiv	6.04 kW	5.67 kW
COP Tj = Tbiv	3.07	2.15
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.41 kW	5.38 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.74	1.99
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.98	0.99
WTOL	60 °C	60 °C
Poff	14 W	14 W
РТО	0 W	o w
PSB	16 W	16 W
PCK	0 W	o w
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.45 kW	1.06 kW
Annual energy consumption Qhe	3163 kWh	4071 kWh