

## Page 1 of 4 This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	Bosch Compress 6000 8 LW	Reg. No.	011-1W0173	
Certificate Holder				
Name	Bosch Thermotechnik GmbH	Bosch Thermotechnik GmbH		
Address	Junkersstraße 20 - 24	Zip	73249	
City	Wernau	Country	Germany	
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH			
Name of testing laboratory	IGE Institut für GebäudeEnergetik	IGE Institut für GebäudeEnergetik		
Subtype title	Bosch Compress 6000 8 LW			
Heat Pump Type	Brine/Water			
Refrigerant	R410a			
Mass Of Refrigerant	1.95 kg			



This information was generated by the HP KEYMARK database on 17 Dec 2020

## **Model: Bosch Compress 6000 8 LW**

General Data	
Power supply	3x400V 50Hz

## Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	7.46 kW	6.78 kW
El input	1.64 kW	2.35 kW
СОР	4.54	2.89
Indoor water flow rate	1.28 m³/h	0.74 m³/h

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

## **Average Climate**



This information was generated by the HP KEYMARK database on 17 Dec 2020

	EN 12102-1		
	Low temperature	Medium temperature	
Sound power level indoor	47 dB(A)	47 dB(A)	

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	186 %	131 %
Prated	9.00 kW	8.00 kW
SCOP	4.85	3.48
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.50 kW	6.80 kW
COP Tj = -7°C	4.66	2.92
Pdh Tj = +2°C	7.60 kW	7.00 kW
COP Tj = +2°C	4.87	3.43
Pdh Tj = +7°C	7.70 kW	7.20 kW
COP Tj = +7°C	5.07	3.86
Pdh Tj = 12°C	7.80 kW	7.40 kW
COP Tj = 12°C	5.26	4.29
Pdh Tj = Tbiv	7.50 kW	6.80 kW
COP Tj = Tbiv	4.66	2.92

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



 $$\operatorname{\textit{Page}}$4$ of 4$ This information was generated by the HP KEYMARK database on 17 Dec 2020$ 

Pdh Tj = TOL	7.50 kW	6.70 kW
COP Tj = TOL	4.55	2.68
Cdh	1.00	1.00
WTOL	62 °C	62 °C
Poff	6 W	6 W
PTO	6 W	6 W
PSB	6 W	6 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electric	Electric
Supplementary Heater: PSUP	1.00 kW	1.00 kW
Annual energy consumption Qhe	3619 kWh	4540 kWh