

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	CTC GSi 612 1x230V	Reg. No.	012-C700086
Certificate Holder			
Name	Enertech CTC AB		
Address	Box 309, Näsvägen	Zip	SE-381 26
City	Ljungby	Country	Sweden
Certification Body	RISE CERT		
Name of testing laboratory	RISE		
Subtype title	CTC GSi 612 1x230V		
Heat Pump Type	Brine/Water		
Refrigerant	R407c		
Mass Of Refrigerant	2.3 kg		
Certification Date	30.11.2020		
Testing basis	HP Keymark Scheme 2017		

Model: CTC GSi 612 1x230V

General Data

Power supply	1x230V 50Hz
Off-peak product	No

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	5.55 kW	6.20 kW
El input	1.29 kW	2.34 kW
COP	4.31	2.65
Indoor water flow rate	0.98 m ³ /h	0.67 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 14825

	Low temperature	Medium temperature
η_s	196 %	148 %
Prated	10.00 kW	12.00 kW
SCOP	5.10	3.90
Tbiv	-15 °C	-9 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	8.90 kW	10.60 kW
COP Tj = -7°C	4.37	2.96
Pdh Tj = +2°C	5.40 kW	6.50 kW
COP Tj = +2°C	5.25	3.90
Pdh Tj = +7°C	3.40 kW	4.20 kW
COP Tj = +7°C	5.75	4.55
Pdh Tj = 12°C	2.40 kW	2.30 kW
COP Tj = 12°C	6.10	5.24
Pdh Tj = Tbiv	11.80 kW	11.60 kW
COP Tj = Tbiv	3.68	2.73
Pdh Tj = TOL	10.00 kW	11.60 kW
COP Tj = TOL	4.03	2.64
Cdh	0.97	0.98
WTOL	65 °C	65 °C

This information was generated by the HP KEYMARK database on 17 Dec 2020

Poff	23 W	23 W
PTO	0 W	0 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.40 kW
Annual energy consumption Qhe	4041 kWh	6369 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	204 %	152 %
Prated	9.50 kW	11.80 kW
SCOP	5.30	4.00
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	5.70 kW	7.13 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP Tj = -7°C	5.15	3.66
Pdh Tj = +2°C	3.50 kW	4.30 kW
COP Tj = +2°C	5.65	4.38
Pdh Tj = +7°C	2.40 kW	2.70 kW
COP Tj = +7°C	6.06	5.04
Pdh Tj = 12°C	2.40 kW	2.30 kW
COP Tj = 12°C	6.06	5.33
Pdh Tj = Tbiv	9.50 kW	11.60 kW
COP Tj = Tbiv	4.21	2.68
Pdh Tj = TOL	9.50 kW	11.71 kW
COP Tj = TOL	4.23	2.68
Cdh	0.96	0.97
WTOL	65 °C	65 °C
Poff	23 W	23 W
PTO	0 W	0 W
PSB	23 W	23 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.10 kW
Annual energy consumption Qhe	4425 kWh	7225 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	96 %
COP	2.40
Heating up time	1:49 h:min
Standby power input	23.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	232 l

Colder Climate

EN 16147	
Declared load profile	XL
COP	2.40
Heating up time	1:49 h:min
Standby power input	70.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	232 l
Efficiency η_{DHW}	96 %