

Summary of	TERRA 6 HPLA	Reg. No.	011-1W0414
Certificate Holder			
Name	Ochsner Wärmepumpen GmbH		
Address	Krackowizerstraße 4	Zip	4020
City	Linz	Country	Austria
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Name of testing laboratory	VDE Prüf- und Zertifizierungsinstitut		
Subtype title	TERRA 6 HPLA		
Heat Pump Type	Brine/Water		
Refrigerant	R410a		
Mass Of Refrigerant	1.4 kg		
Certification Date	30.09.2020		
Testing basis	HP KEYMARK certification scheme rules rev. 7		



# Model: TERRA 6 HPLA, average climate

General Data	
Power supply	3x400V 50Hz

# Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	5.82 kW	5.19 kW
El input	1.21 kW	1.85 kW
СОР	4.80	2.81
Indoor water flow rate	1.04 m³/h	1.04 m³/h

#### **Average Climate**



EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	0 dB(A)	0 dB(A)

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	205 %	134 %
Prated	6.00 kW	5.00 kW
SCOP	5.32	3.55
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.80 kW	5.30 kW
COP Tj = -7°C	4.87	2.94
Pdh Tj = +2°C	5.90 kW	5.50 kW
COP Tj = +2°C	5.24	3.49
Pdh Tj = +7°C	6.00 kW	5.60 kW
COP Tj = +7°C	5.61	3.92
Pdh Tj = 12°C	6.00 kW	5.70 kW
COP Tj = 12°C	6.03	4.44
Pdh Tj = Tbiv	5.80 kW	5.20 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



COP Tj = Tbiv	4.81	2.81
Pdh Tj = TOL	5.80 kW	5.20 kW
COP Tj = TOL	4.81	2.81
Rated airflow rate	0 m³/h	0 m³/h
Cdh	0.90	0.90
WTOL	65 °C	65 °C
Poff	o w	o w
РТО	54 W	54 W
PSB	9 W	9 W
PCK	o w	o w
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	2262 kWh	3017 kWh

#### Warmer Climate

#### Colder Climate



# Model: TERRA 6 HPLA, low temperature, all climates

General Data	
Power supply	3x400V 50Hz

## Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 14511-2	
	Low temperature
Heat output	5.82 kW
El input	1.21 kW
СОР	4.80
Indoor water flow rate	1.04 m³/h

### **Average Climate**



EN 12102-1	
	Low temperature
Sound power level indoor	43 dB(A)
Sound power level outdoor	0 dB(A)

EN 14825	
	Low temperature
$\eta_{s}$	205 %
Prated	6.00 kW
SCOP	5.32
Tbiv	-10 °C
TOL	-10 °C
Pdh Tj = -7°C	5.80 kW
COP Tj = -7°C	4.87
Pdh Tj = +2°C	5.90 kW
COP Tj = +2°C	5.24
Pdh Tj = +7°C	6.00 kW
COP Tj = +7°C	5.61
Pdh Tj = 12°C	6.00 kW
COP Tj = 12°C	6.03
Pdh Tj = Tbiv	5.80 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





COP Tj = Tbiv	4.81
Pdh Tj = TOL	5.80 kW
COP Tj = TOL	4.81
Rated airflow rate	0 m³/h
Cdh	0.90
WTOL	65 °C
Poff	0 W
РТО	54 W
PSB	9 W
PCK	o w
Supplementary Heater: Type of energy input	electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	2262 kWh

#### Warmer Climate

EN 12102-1	
	Low temperature
Sound power level indoor	43 dB(A)
Sound power level outdoor	0 dB(A)

EN 14825	
	Low temperature





ras generated by the HF KLTMAKK database on 17 Dec 20
203 %
6.00 kW
5.28
2 °C
0 °C
0.00 kW
0.00
5.80 kW
4.81
5.90 kW
5.16
6.00 kW
5.75
5.80 kW
4.81
5.80 kW
4.81
0 m³/h
0.90
65 °C





Poff	o w
PTO	54 W
PSB	9 W
PCK	0 W
Supplementary Heater: Type of energy input	electricity
Supplementary Heater: PSUP	0.00 kW
Annual energy consumption Qhe	1473 kWh

#### Colder Climate

EN 12102-1	
	Low temperature
Sound power level indoor	43 dB(A)
Sound power level outdoor	0 dB(A)

EN 14825	
	Low temperature
$\eta_{S}$	212 %
Prated	7.00 kW
SCOP	5.49
Tbiv	-15 °C
TOL	-22 °C





# $$\operatorname{\textit{Page}}\ 10$$ of 11 This information was generated by the HP KEYMARK database on 17 Dec 2020

This information was generated by the first	
Pdh Tj = -7°C	5.90 kW
COP Tj = -7°C	5.43
Pdh Tj = +2°C	6.00 kW
COP Tj = +2°C	5.72
Pdh Tj = +7°C	6.00 kW
$COP Tj = +7^{\circ}C$	5.97
Pdh Tj = 12°C	6.00 kW
COP Tj = 12°C	6.01
Pdh Tj = Tbiv	5.90 kW
COP Tj = Tbiv	5.31
Pdh Tj = TOL	5.90 kW
COP Tj = TOL	5.31
Rated airflow rate	0 m³/h
Cdh	0.90
WTOL	65 °C
Poff	o w
PTO	54 W
PSB	9 W
PCK	o w
Supplementary Heater: Type of energy input	electricity
Supplementary Heater: PSUP	1.43 kW



 $$\operatorname{\textit{Page}}\ 11$ of 11$$  This information was generated by the HP KEYMARK database on 17 Dec 2020

Annual energy consumption Qhe	3254 kWh