

This information was generated by the HP KEYMARK database on 7 Jul 2022

[Login](#)

Summary of	Bosch Compress 7000 LW 22	Reg. No.	011-1W0152
Certificate Holder			
Name	Bosch Thermotechnik GmbH		
Address	Junkersstraße 20 - 24	Zip	73249
City	Wernau	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	Bosch Compress 7000 LW 22		
Heat Pump Type	Brine/Water		
Refrigerant	R410A		
Mass of Refrigerant	4.5 kg		

## Model: Bosch Compress 7000 LW 22

Configure model	
Model name	Bosch Compress 7000 LW 22
Application	Heating (medium temp)
Units	Indoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

### Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	22.90 kW	23.27 kW
El input	5.01 kW	7.73 kW
COP	4.57	3.01

### Average Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	57 dB(A)	57 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	207 %	160 %
Prated	21.00 kW	21.00 kW
SCOP	5.38	4.19
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	18.58 kW	18.58 kW
COP Tj = -7°C	4.80	3.31
Pdh Tj = +2°C	11.77 kW	11.78 kW
COP Tj = +2°C	5.54	4.31
Pdh Tj = +7°C	11.76 kW	11.77 kW
COP Tj = +7°C	5.65	4.61
Pdh Tj = 12°C	11.74 kW	11.76 kW
COP Tj = 12°C	5.67	4.88
Pdh Tj = Tbiv	22.90 kW	23.27 kW
COP Tj = Tbiv	4.57	3.01

This information was generated by the HP KEYMARK database on 7 Jul 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	22.90 kW	23.27 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	4.57	3.01
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	1.00	1.00
WTOL	68 °C	68 °C
Poff	25 W	25 W
PTO	25 W	25 W
PSB	25 W	25 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption $Q_{he}$	8072 kWh	10349 kWh