Login

Summary of	Ecodan Power Inverter 11-300D Packaged AA	Reg. No.	037-0037-20
Certificate Holder			
Name	Mitsubishi Electric Air Conditioning Systems Europe LTD		
Address	Nettlehill Road, Houston Industrial Estate	Zip	EH54 5EQ
City	Livingston	Country	United Kingdom
Certification Body	SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)		
Subtype title	Ecodan Power Inverter 11-300D Packaged AA		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	3 kg		
Certification Date	27.07.2020		
Testing basis	HP Keymark scheme rules rev. no. 6		

Model: PUZ-WM112VAA(-BS) + EHPT30X-*M*D

Configure model	
Model name	PUZ-WM112VAA(-BS) + EHPT30X-*M*D
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	11.2 kW	10 kW
El input	2.38 kW	3.33 kW
COP	4.7	3

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	191 %	134 %
Prated	10 kW	10 kW
SCOP	4.86	3.43
Tbiv	-7 °C	-7 °C
TOL	-25 °C	-25 °C
Pdh Tj = -7°C	8.8 kW	8.8 kW
COP Tj = -7°C	3.31	2.21
Cdh Tj = -7 °C	0.99	1
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.56	3.27
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	4.9 kW	5.2 kW
COP Tj = +7°C	6.68	4.61
Cdh Tj = +7 °C	0.98	0.99

Pdh Tj = 12°C	4.6 kW	4.7 kW
COP Tj = 12°C	9.1	6.35
Cdh Tj = +12 °C	0.97	0.98
Pdh Tj = Tbiv	8.8 kW	8.8 kW
COP Tj = Tbiv	3.31	2.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.78 kW	8.78 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.03	2.11
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	1.22 kW
Annual energy consumption Qhe	4251 kWh	6024 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	215 %	152 %
Prated	10 kW	10 kW
SCOP	5.46	3.87
Tbiv	2 °C	2 °C
TOL	-25 °C	-25 °C
Pdh Tj = +2°C	10 kW	10 kW
COP Tj = +2°C	3.3	1.81
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	6.4 kW	6.4 kW
COP Tj = +7°C	4.82	3.13
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	4.7 kW	4.4 kW
COP Tj = 12°C	7.12	5.66
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	10 kW	10 kW
COP Tj = Tbiv	3.3	1.81
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10 kW	10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.3	1.81
WTOL	60 °C	60 °C

Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Qhe	2449 kWh	3452 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency ηDHW	120 %
COP	2.91
Heating up time	03:10 h:min
Standby power input	40 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	417 l

Warmer Climate

EN 16147

Declared load profile	XL
Efficiency ηDHW	135 %
COP	3.24
Heating up time	03:42 h:min
Standby power input	39 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	417 l

Model: PUZ-WM112VAA(-BS) + EHPT30X-M*D

Configure model	
Model name	PUZ-WM112VAA(-BS) + EHPT30X-M*D
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	11.2 kW	10 kW
El input	2.38 kW	3.33 kW
COP	4.7	3

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	191 %	134 %
Prated	10 kW	10 kW
SCOP	4.86	3.43
Tbiv	-7 °C	-7 °C
TOL	-25 °C	-25 °C
Pdh Tj = -7°C	8.8 kW	8.8 kW
COP Tj = -7°C	3.31	2.21
Cdh Tj = -7 °C	0.99	1
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.56	3.27
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	4.9 kW	5.2 kW
COP Tj = +7°C	6.68	4.61
Cdh Tj = +7 °C	0.98	0.99

Pdh Tj = 12°C	4.6 kW	4.7 kW
COP Tj = 12°C	9.1	6.35
Cdh Tj = +12 °C	0.97	0.98
Pdh Tj = Tbiv	8.8 kW	8.8 kW
COP Tj = Tbiv	3.31	2.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.78 kW	8.78 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.03	2.11
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	1.22 kW
Annual energy consumption Qhe	4251 kWh	6024 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	215 %	152 %
Prated	10 kW	10 kW
SCOP	5.46	3.87
Tbiv	2 °C	2 °C
TOL	-25 °C	-25 °C
Pdh Tj = +2°C	10 kW	10 kW
COP Tj = +2°C	3.3	1.81
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	6.4 kW	6.4 kW
COP Tj = +7°C	4.82	3.15
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	4.7 kW	4.4 kW
COP Tj = 12°C	7.12	5.66
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	10 kW	10 kW
COP Tj = Tbiv	3.3	1.81
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10 kW	10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.3	1.81
WTOL	60 °C	60 °C

Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Qhe	2449 kWh	3452 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency ηDHW	120 %
COP	2.91
Heating up time	03:10 h:min
Standby power input	40 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	417 l

Warmer Climate

EN 16147

Declared load profile	XL
Efficiency ηDHW	135 %
COP	3.24
Heating up time	03:42 h:min
Standby power input	39 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	417 l

Model: PUZ-WM112VAA(-BS) + ERPT30X-*M*D

Configure model	
Model name	PUZ-WM112VAA(-BS) + ERPT30X-*M*D
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	11.2 kW	10 kW
El input	2.38 kW	3.33 kW
COP	4.7	3

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	195 %	136 %
Prated	10 kW	10 kW
SCOP	4.95	3.48
Tbiv	-7 °C	-7 °C
TOL	-25 °C	-25 °C
Pdh Tj = -7°C	8.8 kW	8.8 kW
COP Tj = -7°C	3.31	2.21
Cdh Tj = -7 °C	0.99	1
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.61	3.31
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	4.9 kW	5.2 kW
COP Tj = +7°C	6.68	4.61
Cdh Tj = +7 °C	0.98	0.99

Pdh Tj = 12°C	4.6 kW	4.7 kW
COP Tj = 12°C	9.1	6.35
Cdh Tj = +12 °C	0.97	0.98
Pdh Tj = Tbiv	8.8 kW	8.8 kW
COP Tj = Tbiv	3.31	2.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.78 kW	8.78 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.03	2.11
WTOL	60 °C	60 °C
Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	1.22 kW
Annual energy consumption Qhe	4173 kWh	5932 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	220 %	154 %
Prated	10 kW	10 kW
SCOP	5.58	3.93
Tbiv	2 °C	2 °C
TOL	-25 °C	-25 °C
Pdh Tj = +2°C	10 kW	10 kW
COP Tj = +2°C	3.3	1.81
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	6.4 kW	6.4 kW
COP Tj = +7°C	4.76	3.11
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	4.7 kW	4.4 kW
COP Tj = 12°C	7.12	5.66
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	10 kW	10 kW
COP Tj = Tbiv	3.3	1.81
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10 kW	10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.3	1.81
WTOL	60 °C	60 °C

Poff	15 W	15 W
PTO	15 W	15 W
PSB	15 W	15 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Qhe	2396 kWh	3396 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency ηDHW	120 %
COP	2.91
Heating up time	03:10 h:min
Standby power input	40 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	417 l

Warmer Climate

EN 16147	
Declared load profile	XL
Efficiency ηDHW	135 %
COP	3.24
Heating up time	03:42 h:min
Standby power input	39 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	417 l

Model: PUZ-WM112YAA(-BS) + EHPT30X-*M*D

Configure model	
Model name	PUZ-WM112YAA(-BS) + EHPT30X-*M*D
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	11.2 kW	10 kW
El input	2.38 kW	3.33 kW
COP	4.7	3

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	189 %	133 %
Prated	10 kW	10 kW
SCOP	4.81	3.41
Tbiv	-7 °C	-7 °C
TOL	-25 °C	-25 °C
Pdh Tj = -7°C	8.8 kW	8.8 kW
COP Tj = -7°C	3.31	2.21
Cdh Tj = -7 °C	0.99	0.99
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.55	3.27
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	4.9 kW	5.2 kW
COP Tj = +7°C	6.68	4.61
Cdh Tj = +7 °C	0.98	0.98

Pdh Tj = 12°C	4.6 kW	4.7 kW
COP Tj = 12°C	9.1	6.35
Cdh Tj = +12 °C	0.97	0.97
Pdh Tj = Tbiv	8.8 kW	8.8 kW
COP Tj = Tbiv	3.31	2.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.78 kW	8.78 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.03	2.11
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	1.22 kW
Annual energy consumption Qhe	4293 kWh	6063 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	213 %	150 %
Prated	10 kW	10 kW
SCOP	5.41	3.84
Tbiv	2 °C	2 °C
TOL	-25 °C	-25 °C
Pdh Tj = +2°C	10 kW	10 kW
COP Tj = +2°C	3.3	1.81
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	6.4 kW	6.4 kW
COP Tj = +7°C	4.85	3.15
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	4.7 kW	4.4 kW
COP Tj = 12°C	7.22	5.67
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	10 kW	10 kW
COP Tj = Tbiv	3.3	1.81
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10 kW	10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.3	1.81
WTOL	60 °C	60 °C

Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Qhe	2471 kWh	3483 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency ηDHW	120 %
COP	2.91
Heating up time	03:10 h:min
Standby power input	40 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	417 l

Warmer Climate

EN 16147

Declared load profile	XL
Efficiency ηDHW	135 %
COP	3.24
Heating up time	03:42 h:min
Standby power input	39 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	417 l

Model: PUZ-WM112YAA(-BS) + EHPT30X-M*D

Configure model	
Model name	PUZ-WM112YAA(-BS) + EHPT30X-M*D
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	11.2 kW	10 kW
El input	2.38 kW	3.33 kW
COP	4.7	3

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	189 %	133 %
Prated	10 kW	10 kW
SCOP	4.81	3.41
Tbiv	-7 °C	-7 °C
TOL	-25 °C	-25 °C
Pdh Tj = -7°C	8.8 kW	8.8 kW
COP Tj = -7°C	3.31	2.21
Cdh Tj = -7 °C	0.99	0.99
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.55	3.27
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	4.9 kW	5.2 kW
COP Tj = +7°C	6.68	4.61
Cdh Tj = +7 °C	0.98	0.98

Pdh Tj = 12°C	4.6 kW	4.7 kW
COP Tj = 12°C	9.1	6.35
Cdh Tj = +12 °C	0.97	0.97
Pdh Tj = Tbiv	8.8 kW	8.8 kW
COP Tj = Tbiv	3.31	2.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.78 kW	8.78 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.03	2.11
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	1.22 kW
Annual energy consumption Qhe	4293 kWh	6063 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	213 %	150 %
Prated	10 kW	10 kW
SCOP	5.41	3.84
Tbiv	2 °C	2 °C
TOL	-25 °C	-25 °C
Pdh Tj = +2°C	10 kW	10 kW
COP Tj = +2°C	3.3	1.81
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	6.4 kW	6.4 kW
COP Tj = +7°C	4.85	3.15
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	4.7 kW	4.4 kW
COP Tj = 12°C	7.22	5.67
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	10 kW	10 kW
COP Tj = Tbiv	3.3	1.81
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10 kW	10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.3	1.81
WTOL	60 °C	60 °C

Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Qhe	2471 kWh	3483 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency ηDHW	120 %
COP	2.91
Heating up time	03:10 h:min
Standby power input	40 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	417 l

Warmer Climate

EN 16147

Declared load profile	XL
Efficiency ηDHW	135 %
COP	3.24
Heating up time	03:42 h:min
Standby power input	39 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	417 l

Model: PUZ-WM112YAA(-BS) + ERPT30X-*M*D

Configure model	
Model name	PUZ-WM112YAA(-BS) + ERPT30X-*M*D
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	11.2 kW	10 kW
El input	2.38 kW	3.33 kW
COP	4.7	3

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	195 %	136 %
Prated	10 kW	10 kW
SCOP	4.95	3.48
Tbiv	-7 °C	-7 °C
TOL	-25 °C	-25 °C
Pdh Tj = -7°C	8.8 kW	8.8 kW
COP Tj = -7°C	3.31	2.21
Cdh Tj = -7 °C	0.99	0.99
Pdh Tj = +2°C	5.7 kW	5.4 kW
COP Tj = +2°C	4.64	3.32
Cdh Tj = +2 °C	0.99	0.99
Pdh Tj = +7°C	4.9 kW	5.2 kW
COP Tj = +7°C	6.68	4.61
Cdh Tj = +7 °C	0.98	0.98

Pdh Tj = 12°C	4.6 kW	4.7 kW
COP Tj = 12°C	9.1	6.35
Cdh Tj = +12 °C	0.97	0.97
Pdh Tj = Tbiv	8.8 kW	8.8 kW
COP Tj = Tbiv	3.31	2.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.78 kW	8.78 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.03	2.11
WTOL	60 °C	60 °C
Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.22 kW	1.22 kW
Annual energy consumption Qhe	4171 kWh	5936 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	40 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	220 %	154 %
Prated	10 kW	10 kW
SCOP	5.58	3.93
Tbiv	2 °C	2 °C
TOL	-25 °C	-25 °C
Pdh Tj = +2°C	10 kW	10 kW
COP Tj = +2°C	3.3	1.81
Cdh Tj = +2 °C	1	1
Pdh Tj = +7°C	6.4 kW	6.4 kW
COP Tj = +7°C	4.78	3.12
Cdh Tj = +7 °C	0.99	0.99
Pdh Tj = 12°C	4.7 kW	4.4 kW
COP Tj = 12°C	7.2	5.67
Cdh Tj = +12 °C	0.98	0.98
Pdh Tj = Tbiv	10 kW	10 kW
COP Tj = Tbiv	3.3	1.81
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10 kW	10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.3	1.81
WTOL	60 °C	60 °C

Poff	22 W	22 W
PTO	22 W	22 W
PSB	22 W	22 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Qhe	2392 kWh	3401 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	XL
Efficiency ηDHW	120 %
COP	2.91
Heating up time	03:10 h:min
Standby power input	40 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	417 l

Warmer Climate

EN 16147

Declared load profile	XL
Efficiency ηDHW	135 %
COP	3.24
Heating up time	03:42 h:min
Standby power input	39 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	417 l