

Page 1 of 4

This information was generated by the HP KEYMARK database on 18 Mar 2022

Login

Summary of	Hi-Therma Monobloc 8kW	Reg. No.	041-K021-04
Certificate Holder			
Name	Qingdao Hisense Hitachi Air-conditioning Systems Co.,Ltd.		
Address	Qianwangang Road	Zip	266555
City	Qingdao, Shandong	Country	China
Certification Body	BRE Global Limited		
Subtype title	Hi-Therma Monobloc 8kW		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	1.21 kg		
Certification Date	01.03.2022		
Testing basis	Heat Pump Keymark Scheme Rules Rev 09		

This information was generated by the HP KEYMARK database on 18 Mar 2022

Model: AHZ-080HCDS1

Configure model			
Model name	AHZ-080HCDS1		
Application	Heating (medium temp)		
Units	Outdoor		
Climate Zone	n/a		
Reversibility	Yes		
Cooling mode application (optional)	n/a		

General Data		
Power supply 1x230V 50Hz		

Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	8.00 kW	8.00 kW	
El input	1.63 kW	2.86 kW	
СОР	4.90	2.80	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

Average Climate



 $$\operatorname{\textit{Page}}\xspace$ 3 of 4 This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level outdoor	64 dB(A)	64 dB(A)	

EN 14825			
	Low temperature	Medium temperature	
η_{s}	197 %	137 %	
Prated	6.52 kW	6.07 kW	
SCOP	5.00	3.50	
Tbiv	-7 °C	-7 °C	
TOL	-10 °C	-10 °C	
Pdh Tj = -7°C	5.74 kW	5.34 kW	
COP Tj = -7°C	3.09	2.18	
Cdh Tj = -7 °C	0.900	0.900	
Pdh Tj = +2°C	3.47 kW	3.11 kW	
COP Tj = +2°C	4.76	3.41	
Cdh Tj = +2 °C	0.900	0.900	
Pdh Tj = +7°C	2.44 kW	2.09 kW	
COP Tj = +7°C	6.65	4.36	
Cdh Tj = +7 °C	0.900	0.900	
Pdh Tj = 12°C	1.48 kW	1.23 kW	

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 4 This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = 12°C	9.58	6.52
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	5.74 kW	5.34 kW
COP Tj = Tbiv	3.09	2.18
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.14 kW	5.81 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.84	1.72
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	60 °C	60 °C
Poff	10 W	10 W
РТО	11 W	11 W
PSB	10 W	10 W
PCK	o w	o w
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.37 kW	0.25 kW
Annual energy consumption Qhe	2680 kWh	3574 kWh