

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	LW 251	Reg. No.	041-K001-40
Certificate Holder			
Name	ait-deutschland GmbH		
Address	Industriestr. 3	Zip	95359
City	Kasendorf	Country	Germany
Certification Body	BRE Energy & Communications Division		
Name of testing laboratory	HLK Stuttgart		
Subtype title	LW 251		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R407c		
Mass Of Refrigerant	9.8 kg		
Certification Date	08.10.2019		

Model: LW 251 (L)

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 14511-2

	Low temperature	Medium temperature
Heat output	15.47 kW	15.28 kW
El input	3.77 kW	5.21 kW
COP	4.11	2.93
Indoor water flow rate	2.93 m ³ /h	1.76 m ³ /h

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	63 dB(A)	63 dB(A)

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 14825

	Low temperature	Medium temperature
η_s	155 %	122 %
Prated	25.31 kW	25.01 kW
SCOP	3.95	3.13
Tbiv	-5 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	19.36 kW	19.18 kW
COP Tj = -7°C	2.96	2.07
Cdh	1.00	1.00
Pdh Tj = +2°C	24.23 kW	23.93 kW
COP Tj = +2°C	3.77	3.02
Cdh	1.00	1.00
Pdh Tj = +7°C	14.34 kW	14.29 kW
COP Tj = +7°C	5.06	4.13
Cdh	1.00	1.00
Pdh Tj = 12°C	16.85 kW	16.82 kW
COP Tj = 12°C	5.90	5.44
Cdh	1.00	1.00
Pdh Tj = Tbiv	20.44 kW	20.20 kW
COP Tj = Tbiv	3.18	2.24

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	17.75 kW	17.70 kW
COP Tj = TOL	2.66	1.83
WTOL	70 °C	70 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	7.56 kW	7.31 kW
Annual energy consumption Qhe	13252 kWh	16517 kWh

Warmer Climate

EN 14825		
	Low temperature	Medium temperature
η_s	198 %	152 %
Prated	24.15 kW	23.51 kW
SCOP	5.02	3.87
Tbiv	4 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	24.15 kW	23.51 kW
COP Tj = +2°C	3.55	2.35

This information was generated by the HP KEYMARK database on 17 Dec 2020

Cdh	1.00	1.00
Pdh Tj = +7°C	14.33 kW	14.23 kW
COP Tj = +7°C	4.74	3.33
Cdh	1.00	1.00
Pdh Tj = 12°C	16.84 kW	16.77 kW
COP Tj = 12°C	5.71	4.90
Cdh	1.00	1.00
Pdh Tj = Tbiv	20.25 kW	19.85 kW
COP Tj = Tbiv	3.88	2.63
Pdh Tj = TOL	24.15 kW	23.51 kW
COP Tj = TOL	3.55	2.35
WTOL	70 °C	70 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	6424 kWh	8123 kWh

Colder Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 14825

	Low temperature	Medium temperature
η_s	134 %	110 %
Prated	22.63 kW	22.68 kW
SCOP	3.43	2.83
Tbiv	-12 °C	-12 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	19.39 kW	19.68 kW
COP Tj = -7°C	3.15	2.39
Cdh	1.00	1.00
Pdh Tj = +2°C	24.28 kW	24.09 kW
COP Tj = +2°C	3.93	3.37
Cdh	1.00	1.00
Pdh Tj = +7°C	14.35 kW	14.32 kW
COP Tj = +7°C	5.22	4.56
Cdh	1.00	1.00
Pdh Tj = 12°C	16.85 kW	16.85 kW
COP Tj = 12°C	5.78	5.71
Cdh	1.00	1.00
Pdh Tj = Tbiv	16.68 kW	16.71 kW
COP Tj = Tbiv	2.71	1.96

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	12.40 kW	13.77 kW
COP Tj = TOL	1.92	1.53
WTOL	70 °C	70 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	22.63 kW	22.68 kW
Annual energy consumption Qhe	16286 kWh	19754 kWh
Pdh Tj = -15°C (if TOL<-20°C)	15.06	15.23
COP Tj = -15°C (if TOL<-20°C)	2.40	1.74
Cdh	1.00	1.00

Model: LW 251A

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

EN 14511-2

	Low temperature	Medium temperature
Heat output	15.47 kW	15.28 kW
El input	3.77 kW	5.21 kW
COP	4.11	2.93
Indoor water flow rate	2.93 m ³ /h	1.76 m ³ /h

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	63 dB(A)	63 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	155 %	122 %
Prated	25.31 kW	25.01 kW
SCOP	3.95	3.13
Tbiv	-5 °C	-5 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	19.36 kW	19.18 kW
COP Tj = -7°C	2.96	2.07
Cdh	1.00	1.00
Pdh Tj = +2°C	24.23 kW	23.93 kW
COP Tj = +2°C	3.77	3.02
Cdh	1.00	1.00
Pdh Tj = +7°C	14.34 kW	14.29 kW
COP Tj = +7°C	5.06	4.13
Cdh	1.00	1.00

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	16.85 kW	16.82 kW
COP Tj = 12°C	5.90	5.44
Cdh	1.00	1.00
Pdh Tj = Tbiv	20.44 kW	20.20 kW
COP Tj = Tbiv	3.18	2.24
Pdh Tj = TOL	17.75 kW	17.70 kW
COP Tj = TOL	2.66	1.83
WTOL	70 °C	70 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	7.56 kW	7.31 kW
Annual energy consumption Qhe	13252 kWh	16517 kWh

Warmer Climate

EN 14825		
	Low temperature	Medium temperature
η_s	198 %	152 %
Prated	24.15 kW	23.51 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

SCOP	5.02	3.87
Tbiv	4 °C	4 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	24.15 kW	23.51 kW
COP Tj = +2°C	3.55	2.35
Cdh	1.00	1.00
Pdh Tj = +7°C	14.33 kW	14.23 kW
COP Tj = +7°C	4.74	3.33
Cdh	1.00	1.00
Pdh Tj = 12°C	16.84 kW	16.77 kW
COP Tj = 12°C	5.71	4.90
Cdh	1.00	1.00
Pdh Tj = Tbiv	20.25 kW	19.85 kW
COP Tj = Tbiv	3.88	2.63
Pdh Tj = TOL	24.15 kW	23.51 kW
COP Tj = TOL	3.55	2.35
WTOL	70 °C	70 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W

This information was generated by the HP KEYMARK database on 17 Dec 2020

Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	6424 kWh	8123 kWh

Colder Climate

EN 14825		
	Low temperature	Medium temperature
η_s	134 %	110 %
Prated	22.63 kW	22.68 kW
SCOP	3.43	2.83
T _{biv}	-12 °C	-12 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	19.39 kW	19.68 kW
COP T _j = -7°C	3.15	2.39
C _{dh}	1.00	1.00
P _{dh} T _j = +2°C	24.28 kW	24.09 kW
COP T _j = +2°C	3.93	3.37
C _{dh}	1.00	1.00
P _{dh} T _j = +7°C	14.35 kW	14.32 kW
COP T _j = +7°C	5.22	4.56
C _{dh}	1.00	1.00

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	16.85 kW	16.85 kW
COP Tj = 12°C	5.78	5.71
Cdh	1.00	1.00
Pdh Tj = Tbiv	16.68 kW	16.71 kW
COP Tj = Tbiv	2.71	1.96
Pdh Tj = TOL	12.40 kW	13.77 kW
COP Tj = TOL	1.92	1.53
WTOL	70 °C	70 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	22.63 kW	22.68 kW
Annual energy consumption Qhe	16286 kWh	19754 kWh
Pdh Tj = -15°C (if TOL<-20°C)	15.06	15.23
COP Tj = -15°C (if TOL<-20°C)	2.40	1.74
Cdh	1.00	1.00