

Page 1 of 5

This information was generated by the HP KEYMARK database on 18 Mar 2022

<u>Login</u>

Summary of	Grant Aerona3 HPID6R32	Reg. No.	041-K006-01
Certificate Holder			
Name	Grant Engineering (UK) Ltd		
Address	Hopton Industrial Estate, Hopton House	Zip	SN10 2EU
City	Devizes	Country	United Kingdom
Certification Body	BRE Global Limited		
Subtype title	Grant Aerona3 HPID6R32		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	0.8 kg		
Certification Date	01.03.2022		
Testing basis	Heat Pump Keymark Scheme Rules Rev 09		

This information was generated by the HP KEYMARK database on 18 Mar 2022

Model: HPID6R32

Configure model		
Model name	HPID6R32	
Application	Heating + DHW + low temp	
Units	Outdoor	
Climate Zone	n/a	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply	1x230V 50Hz	

Heating

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	6.92 kW	6.24 kW	
El input	1.41 kW	2.05 kW	
СОР	4.91	3.04	

Average Climate



 $$\operatorname{\textit{Page}}\ 3$$ of 5 This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	65.2 dB(A)	65.2 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	185 %	132 %
Prated	4.50 kW	4.50 kW
SCOP	4.70	3.38
Tbiv	-9 °C	-9 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.68 kW	5.03 kW
COP Tj = -7°C	3.13	2.11
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	3.24 kW	3.21 kW
COP Tj = +2°C	6.02	4.03
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	2.10 kW	2.20 kW
COP Tj = +7°C	7.40	5.10
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	2.00 kW	1.78 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





COP Tj = 12°C	9.20	6.15
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	4.50 kW	4.49 kW
COP Tj = Tbiv	3.02	1.99
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.87 kW	3.51 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.67	1.85
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	60 °C	60 °C
Poff	100 W	100 W
РТО	40 W	40 W
PSB	100 W	100 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.63 kW	0.99 kW
Annual energy consumption Qhe	1979 kWh	2754 kWh

Domestic Hot Water (DHW)

Average Climate





 $$\operatorname{\textit{Page}}\xspace\:5\:\text{of}\:5\:$ This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 16147		
Declared load profile	L	
Efficiency ηDHW	114 %	
СОР	2.75	
Heating up time	1:47 h:min	
Standby power input	26.3 W	
Reference hot water temperature	49.0 °C	
Mixed water at 40°C	278	