

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	F1355-28	Reg. No.	012-SC1196-17
Certificate Holder			
Name	Nibe AB		
Address	Box 14	Zip	S-28521
City	Markaryd	Country	Sweden
Certification Body	RISE CERT		
Subtype title	F1355-28		
Heat Pump Type	Brine/Water and Water/Water		
Refrigerant	R407c		
Mass of Refrigerant	4.4 kg		

Model: F1355-28

Configure model	
Model name	F1355-28
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Brine/Water Heat Pump

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	20.77 kW	19.87 kW
El input	4.56 kW	6.48 kW
COP	4.55	3.07

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	47 dB(A)	47 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	198 %	155 %
Prated	28.00 kW	28.00 kW
SCOP	5.07	4.07
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	24.80 kW	25.00 kW
COP Tj = -7°C	4.40	3.10
Pdh Tj = +2°C	15.60 kW	15.30 kW
COP Tj = +2°C	4.90	3.90
Pdh Tj = +7°C	9.70 kW	9.70 kW
COP Tj = +7°C	5.60	4.60
Pdh Tj = 12°C	4.30 kW	4.30 kW
COP Tj = 12°C	6.10	5.30
Pdh Tj = Tbiv	28.00 kW	28.00 kW
COP Tj = Tbiv	4.10	2.80

This information was generated by the HP KEYMARK database on 18 Mar 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	28.00 kW	28.00 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	4.10	2.80
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.98	0.99
WTOL	65 °C	65 °C
Poff	7 W	7 W
PTO	50 W	35 W
PSB	19 W	19 W
PCK	25 W	25 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q_{he}	11528 kWh	14621 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	47 dB(A)	47 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	211 %	165 %
Prated	28.00 kW	28.00 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

SCOP	5.47	4.32
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	17.00 kW	17.00 kW
COP Tj = -7°C	5.10	3.90
Pdh Tj = +2°C	10.30 kW	10.30 kW
COP Tj = +2°C	5.50	4.50
Pdh Tj = +7°C	6.60 kW	6.60 kW
COP Tj = +7°C	6.30	5.40
Pdh Tj = 12°C	3.80 kW	3.70 kW
COP Tj = 12°C	5.90	5.40
Pdh Tj = Tbiv	28.00 kW	28.00 kW
COP Tj = Tbiv	4.10	2.80
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	28.00 kW	28.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.10	2.80
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.97	0.98
WTOL	65 °C	65 °C
Poff	7 W	7 W
PTO	50 W	35 W
PSB	19 W	19 W
PCK	25 W	25 W

This information was generated by the HP KEYMARK database on 18 Mar 2022

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	12907 kWh	16450 kWh

Water/Water Heat Pump

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	26.68 kW	25.23 kW
El input	4.76 kW	6.37 kW
COP	5.60	3.96

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	47 dB(A)	47 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	243 %	188 %
Prated	35.00 kW	35.00 kW
SCOP	6.15	4.79
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	31.00 kW	31.00 kW
COP Tj = -7°C	5.40	3.80
Pdh Tj = +2°C	21.60 kW	18.80 kW
COP Tj = +2°C	6.10	4.70
Pdh Tj = +7°C	12.10 kW	12.10 kW
COP Tj = +7°C	6.60	5.50
Pdh Tj = 12°C	7.00 kW	6.80 kW
COP Tj = 12°C	7.70	6.60
Pdh Tj = Tbiv	35.00 kW	35.00 kW
COP Tj = Tbiv	4.90	3.50

This information was generated by the HP KEYMARK database on 18 Mar 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	35.00 kW	35.00 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	4.90	3.50
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.97	0.99
WTOL	65 °C	65 °C
Poff	7 W	7 W
PTO	65 W	45 W
PSB	19 W	19 W
PCK	25 W	25 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q_{he}	11765 kWh	15111 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	47 dB(A)	47 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	252 %	197 %
Prated	35.00 kW	35.00 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

SCOP	6.37	4.99
Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	21.20 kW	21.20 kW
COP Tj = -7°C	6.20	4.60
Pdh Tj = +2°C	12.90 kW	12.90 kW
COP Tj = +2°C	6.50	5.30
Pdh Tj = +7°C	8.30 kW	8.30 kW
COP Tj = +7°C	7.50	6.40
Pdh Tj = 12°C	6.90 kW	6.80 kW
COP Tj = 12°C	7.40	6.60
Pdh Tj = Tbiv	35.00 kW	35.00 kW
COP Tj = Tbiv	4.90	3.50
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	35.00 kW	35.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.90	3.50
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.97	0.98
WTOL	65 °C	65 °C
Poff	7 W	7 W
PTO	65 W	45 W
PSB	19 W	19 W
PCK	25 W	25 W

This information was generated by the HP KEYMARK database on 18 Mar 2022

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	13541 kWh	17279 kWh