

This information was generated by the HP KEYMARK database on 23 Jun 2022

[Login](#)

Summary of	Jersey 7	Reg. No.	041-K001-48
Certificate Holder			
Name	ait-deutschland GmbH		
Address	Industriestr. 3	Zip	95359
City	Kasendorf	Country	Germany
Certification Body	BRE Global Limited		
Subtype title	Jersey 7		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.55 kg		
Certification Date	29.04.2022		
Testing basis	Heat Pump Keymark Scheme Rules Rev 09		

Model: Jersey 7-1

Configure model	
Model name	Jersey 7-1
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	3.87 kW	3.09 kW
El input	0.85 kW	1.21 kW
COP	4.54	2.55

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	162 %	123 %
Prated	8.20 kW	7.49 kW
SCOP	4.13	3.15
Tbiv	-8 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.18 kW	6.55 kW
COP Tj = -7°C	2.65	2.03
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	4.14 kW	3.70 kW
COP Tj = +2°C	3.99	3.00
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	2.63 kW	2.49 kW
COP Tj = +7°C	5.34	4.25
Cdh Tj = +7 °C	1.000	1.000
Pdh Tj = 12°C	2.24 kW	2.16 kW

This information was generated by the HP KEYMARK database on 23 Jun 2022

COP Tj = 12°C	7.15	5.60
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	7.22 kW	6.55 kW
COP Tj = Tbiv	2.59	2.03
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.94 kW	5.26 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.75
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	58 °C	58 °C
Poff	41 W	41 W
PTO	45 W	45 W
PSB	45 W	45 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.26 kW	2.33 kW
Annual energy consumption Qhe	4102 kWh	4917 kWh

Model: Jabbah 7-1

Configure model

Model name	Jabbah 7-1
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	3.87 kW	3.09 kW
El input	0.85 kW	1.21 kW
COP	4.54	2.55

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	55 dB(A)	55 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	162 %	123 %
Prated	8.20 kW	7.49 kW
SCOP	4.13	3.15
Tbiv	-8 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.18 kW	6.55 kW
COP Tj = -7°C	2.65	2.03
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	4.14 kW	3.70 kW
COP Tj = +2°C	3.99	3.00
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	2.63 kW	2.49 kW
COP Tj = +7°C	5.34	4.25
Cdh Tj = +7 °C	1.000	1.000
Pdh Tj = 12°C	2.24 kW	2.16 kW

This information was generated by the HP KEYMARK database on 23 Jun 2022

COP Tj = 12°C	7.15	5.60
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	7.22 kW	6.55 kW
COP Tj = Tbiv	2.59	2.03
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.94 kW	5.26 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.56	1.75
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	58 °C	58 °C
Poff	41 W	41 W
PTO	45 W	45 W
PSB	45 W	45 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.26 kW	2.33 kW
Annual energy consumption Qhe	4102 kWh	4917 kWh