

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	03. Yutaki S Combi 260L 2.0HP R32	Reg. No.	041-K002-31
Certificate Holder			
Name	Johnson Controls-Hitachi AirConditioning Spain		
Address	Ronda Shimizu, 1. Pol. Ind. Can Torrella	Zip	08233
City	Vacarisses, Barcelona	Country	Spain
Certification Body	BRE Energy & Communications Division		
Name of testing laboratory	CEIS		
Subtype title	03. Yutaki S Combi 260L 2.0HP R32		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass Of Refrigerant	1.2 kg		
Certification Date	08.08.2019		

Model: 01. RAS-2WHVRP RWD-2.0NRWE-260S - Heating Only

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	4.30 kW	4.30 kW
El input	0.82 kW	1.43 kW
COP	5.25	3.00
Indoor water flow rate	0.77 m ³ /h	0.46 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	181 %	133 %
Prated	4.00 kW	4.00 kW
SCOP	4.60	3.40
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.54 kW	3.50 kW
COP Tj = -7°C	3.20	2.13
Cdh	1.00	1.00
Pdh Tj = +2°C	2.35 kW	2.10 kW
COP Tj = +2°C	4.80	3.35
Cdh	1.00	1.00
Pdh Tj = +7°C	3.00 kW	2.43 kW
COP Tj = +7°C	6.20	5.15
Cdh	0.90	0.90

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	3.05 kW	2.80 kW
COP Tj = 12°C	8.30	6.80
Cdh	0.90	0.90
Pdh Tj = Tbiv	3.54 kW	3.50 kW
COP Tj = Tbiv	3.20	2.13
Pdh Tj = TOL	4.00 kW	3.10 kW
COP Tj = TOL	2.75	1.90
WTOL	55 °C	55 °C
Poff	12 W	12 W
PTO	0 W	0 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	1798 kWh	2401 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	136 %
COP	3.40
Heating up time	2:20 h:min
Standby power input	37.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	350 l

Model: 02. RAS-2WHVRP RWD-2.0NRWE-260S - with cooling kit

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	4.30 kW	4.30 kW
El input	0.82 kW	1.43 kW
COP	5.25	3.00
Indoor water flow rate	0.77 m ³ /h	0.46 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	186 %	136 %
Prated	4.00 kW	4.00 kW
SCOP	4.73	3.48
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.54 kW	3.50 kW
COP Tj = -7°C	3.20	2.13
Cdh	1.00	1.00
Pdh Tj = +2°C	2.35 kW	2.10 kW
COP Tj = +2°C	4.80	3.35
Cdh	1.00	1.00
Pdh Tj = +7°C	3.00 kW	2.43 kW
COP Tj = +7°C	6.20	5.15
Cdh	0.90	0.90

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	3.05 kW	2.80 kW
COP Tj = 12°C	8.30	6.80
Cdh	0.90	0.90
Pdh Tj = Tbiv	3.54 kW	3.50 kW
COP Tj = Tbiv	3.20	2.13
Pdh Tj = TOL	4.00 kW	3.10 kW
COP Tj = TOL	2.75	1.90
WTOL	55 °C	55 °C
Poff	12 W	12 W
PTO	0 W	0 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	1754 kWh	2357 kWh

Cooling

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	1 kW	1.02 kW
Cooling capacity	4	5.5
EER	4	5.4

EN 14825

This information was generated by the HP KEYMARK database on 17 Dec 2020

	+7°C/+12°C	+18°C/+23°C
P _{designc}	4 kW	5.5 kW
SEER	5.57	8.04
P _{dc} T _j = 35°C	4 kW	5.5 kW
EER T _j = 35°C	4	5.4
P _{dc} T _j = 30°C	2.95 kW	4.05 kW
EER T _j = 30°C	5	7.2
C _{dc}	1	1
P _{dc} T _j = 25°C	2.05 kW	2.61 kW
EER T _j = 25°C	6.45	9.6
C _{dc}	0.9	0.9
P _{dc} T _j = 20°C	2.88 kW	2.51 kW
EER T _j = 20°C	8	10.3
C _{dc}	0.9	0.9
P _{off}	12 W	12 W
P _{TO}	0 W	0 W
P _{SB}	12 W	12 W
P _{CK}	0 W	0 W
Annual energy consumption Q _{ce}	431 kWh	410 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	136 %
COP	3.40
Heating up time	2:20 h:min
Standby power input	37.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	350 l

Model: 03. RAS-2WHVRP RWD-2.0NRWE-260S-K - UK Version - Heating Only

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	4.30 kW	4.30 kW
El input	0.82 kW	1.43 kW
COP	5.25	3.00
Indoor water flow rate	0.77 m ³ /h	0.46 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	181 %	133 %
Prated	4.00 kW	4.00 kW
SCOP	4.60	3.40
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.54 kW	3.50 kW
COP Tj = -7°C	3.20	2.13
Cdh	1.00	1.00
Pdh Tj = +2°C	2.35 kW	2.10 kW
COP Tj = +2°C	4.80	3.35
Cdh	1.00	1.00
Pdh Tj = +7°C	3.00 kW	2.43 kW
COP Tj = +7°C	6.20	5.15
Cdh	0.90	0.90

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	3.05 kW	2.80 kW
COP Tj = 12°C	8.30	6.80
Cdh	0.90	0.90
Pdh Tj = Tbiv	3.54 kW	3.50 kW
COP Tj = Tbiv	3.20	2.13
Pdh Tj = TOL	4.00 kW	3.10 kW
COP Tj = TOL	2.75	1.90
WTOL	55 °C	55 °C
Poff	12 W	12 W
PTO	0 W	0 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	1798 kWh	2401 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	136 %
COP	3.40
Heating up time	2:20 h:min
Standby power input	37.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	350 l

Model: 04. RAS-2WHVRP RWD-2.0NRWE-260S-K - UK Version - with cooling kit

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	4.30 kW	4.30 kW
El input	0.82 kW	1.43 kW
COP	5.25	3.00
Indoor water flow rate	0.77 m ³ /h	0.46 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	186 %	136 %
Prated	4.00 kW	4.00 kW
SCOP	4.73	3.48
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.54 kW	3.50 kW
COP Tj = -7°C	3.20	2.13
Cdh	1.00	1.00
Pdh Tj = +2°C	2.35 kW	2.10 kW
COP Tj = +2°C	4.80	3.35
Cdh	1.00	1.00
Pdh Tj = +7°C	3.00 kW	2.43 kW
COP Tj = +7°C	6.20	5.15
Cdh	0.90	0.90

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	3.05 kW	2.80 kW
COP Tj = 12°C	8.30	6.80
Cdh	0.90	0.90
Pdh Tj = Tbiv	3.54 kW	3.50 kW
COP Tj = Tbiv	3.20	2.13
Pdh Tj = TOL	4.00 kW	3.10 kW
COP Tj = TOL	2.75	1.90
WTOL	55 °C	55 °C
Poff	12 W	12 W
PTO	0 W	0 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	1754 kWh	2357 kWh

Cooling

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	1 kW	1.02 kW
Cooling capacity	4	5.5
EER	4	5.4

EN 14825

This information was generated by the HP KEYMARK database on 17 Dec 2020

	+7°C/+12°C	+18°C/+23°C
P _{designc}	4 kW	5.5 kW
SEER	5.57	8.04
P _{dc} T _j = 35°C	4 kW	5.5 kW
EER T _j = 35°C	4	5.4
P _{dc} T _j = 30°C	2.95 kW	4.05 kW
EER T _j = 30°C	5	7.2
C _{dc}	1	1
P _{dc} T _j = 25°C	2.05 kW	2.61 kW
EER T _j = 25°C	6.45	9.6
C _{dc}	0.9	0.9
P _{dc} T _j = 20°C	2.88 kW	2.51 kW
EER T _j = 20°C	8	10.3
C _{dc}	0.9	0.9
P _{off}	12 W	12 W
PTO	0 W	0 W
PSB	12 W	12 W
PCK	0 W	0 W
Annual energy consumption Q _{ce}	431 kWh	410 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	136 %
COP	3.40
Heating up time	2:20 h:min
Standby power input	37.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	350 l

Model: 05. RAS-2WHVRP RWD-2.0NRWSE-260S - Solar Version - Heating Only

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	4.30 kW	4.30 kW
El input	0.82 kW	1.43 kW
COP	5.25	3.00
Indoor water flow rate	0.77 m ³ /h	0.46 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	181 %	133 %
Prated	4.00 kW	4.00 kW
SCOP	4.60	3.40
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.54 kW	3.50 kW
COP Tj = -7°C	3.20	2.13
Cdh	1.00	1.00
Pdh Tj = +2°C	2.35 kW	2.10 kW
COP Tj = +2°C	4.80	3.35
Cdh	1.00	1.00
Pdh Tj = +7°C	3.00 kW	2.43 kW
COP Tj = +7°C	6.20	5.15
Cdh	0.90	0.90

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	3.05 kW	2.80 kW
COP Tj = 12°C	8.30	6.80
Cdh	0.90	0.90
Pdh Tj = Tbiv	3.54 kW	3.50 kW
COP Tj = Tbiv	3.20	2.13
Pdh Tj = TOL	4.00 kW	3.10 kW
COP Tj = TOL	2.75	1.90
WTOL	55 °C	55 °C
Poff	12 W	12 W
PTO	0 W	0 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	1798 kWh	2401 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	136 %
COP	3.40
Heating up time	2:20 h:min
Standby power input	37.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	350 l

Model: 06. RAS-2WHVRP RWD-2.0NRWSE-260S - Solar Version - with cooling kit

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	4.30 kW	4.30 kW
El input	0.82 kW	1.43 kW
COP	5.25	3.00
Indoor water flow rate	0.77 m ³ /h	0.46 m ³ /h

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	37 dB(A)	37 dB(A)
Sound power level outdoor	61 dB(A)	61 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	186 %	136 %
Prated	4.00 kW	4.00 kW
SCOP	4.73	3.48
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.54 kW	3.50 kW
COP Tj = -7°C	3.20	2.13
Cdh	1.00	1.00
Pdh Tj = +2°C	2.35 kW	2.10 kW
COP Tj = +2°C	4.80	3.35
Cdh	1.00	1.00
Pdh Tj = +7°C	3.00 kW	2.43 kW
COP Tj = +7°C	6.20	5.15
Cdh	0.90	0.90

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	3.05 kW	2.80 kW
COP Tj = 12°C	8.30	6.80
Cdh	0.90	0.90
Pdh Tj = Tbiv	3.54 kW	3.50 kW
COP Tj = Tbiv	3.20	2.13
Pdh Tj = TOL	4.00 kW	3.10 kW
COP Tj = TOL	2.75	1.90
WTOL	55 °C	55 °C
Poff	12 W	12 W
PTO	0 W	0 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.00 kW	0.90 kW
Annual energy consumption Qhe	1754 kWh	2357 kWh

Cooling

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 14511-2

	+7°C/+12°C	+18°C/+23°C
El input	1 kW	1.02 kW
Cooling capacity	4	5.5
EER	4	5.4

EN 14825

This information was generated by the HP KEYMARK database on 17 Dec 2020

	+7°C/+12°C	+18°C/+23°C
P _{designc}	4 kW	5.5 kW
SEER	5.57	8.04
P _{dc} T _j = 35°C	4 kW	5.5 kW
EER T _j = 35°C	4	5.4
P _{dc} T _j = 30°C	2.95 kW	4.05 kW
EER T _j = 30°C	5	7.2
C _{dc}	1	1
P _{dc} T _j = 25°C	2.05 kW	2.61 kW
EER T _j = 25°C	6.45	9.6
C _{dc}	0.9	0.9
P _{dc} T _j = 20°C	2.88 kW	2.51 kW
EER T _j = 20°C	8	10.3
C _{dc}	0.9	0.9
P _{off}	12 W	12 W
PTO	0 W	0 W
PSB	12 W	12 W
PCK	0 W	0 W
Annual energy consumption Q _{ce}	431 kWh	410 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	136 %
COP	3.40
Heating up time	2:20 h:min
Standby power input	37.0 W
Reference hot water temperature	54.0 °C
Mixed water at 40°C	350 l