

Page 1 of 8

This information was generated by the HP KEYMARK database on 23 Jun 2022

<u>Login</u>

Summary of	ecoAIR 1-9 PRO	Reg. No.	011-1W0469	
Certificate Holder				
Name	Ecoforest Geotermia S.L.	Ecoforest Geotermia S.L.		
Address	Rúa das Pontes, 25	Rúa das Pontes, 25 Zip 36350		
City	Nigrán (Pontevedra)	Country	Spain	
Certification Body	DIN CERTCO Gesellschaft für	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	ecoAIR 1-9 PRO			
Heat Pump Type	Outdoor Air/Water			
Refrigerant	R290			
Mass of Refrigerant	0.85 kg	0.85 kg		
Certification Date	03.06.2021	03.06.2021		
Testing basis	HP KEYMARK certification scheme rules rev. 8			

Model: ecoAIR 1-9 PRO

Configure model		
Model name	ecoAIR 1-9 PRO	
Application	Heating (medium temp)	
Units	Indoor + Outdoor	
Climate Zone	Colder Climate + Warmer Climate	
Reversibility	Yes	
Cooling mode application (optional)	n/a	

General Data		
Power supply	1x230V 50Hz	

Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	4.20 kW	4.10 kW	
El input	0.84 kW	1.30 kW	
СОР	4.98	3.15	

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Warmer Climate



 $$\operatorname{\textit{Page}}\xspace$ 3 of 8 This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	0 dB(A)	0 dB(A)	
Sound power level outdoor	57 dB(A)	57 dB(A)	

EN 14825		
	Low temperature	Medium temperature
η_{s}	218 %	171 %
Prated	6.50 kW	6.00 kW
SCOP	5.53	4.35
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	6.47 kW	5.96 kW
COP Tj = +2°C	3.39	2.49
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = $+7^{\circ}$ C	4.12 kW	3.92 kW
$COP Tj = +7^{\circ}C$	5.38	3.88
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	4.92 kW	4.59 kW
COP Tj = 12°C	6.66	5.67
Cdh Tj = +12 °C	0.990	0.990

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





Pdh Tj = Tbiv	6.47 kW	5.96 kW
COP Tj = Tbiv	3.39	2.49
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.47 kW	5.96 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.39	2.49
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	1.000	1.000
WTOL	70 °C	70 °C
Poff	0 W	0 W
РТО	9 W	9 W
PSB	8 W	8 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1570 kWh	1844 kWh

Colder Climate

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	0 dB(A)	0 dB(A)	
Sound power level outdoor	57 dB(A)	57 dB(A)	

EN 14825





	Low temperature	Medium temperature
η_{s}	148 %	125 %
Prated	4.50 kW	4.50 kW
SCOP	3.78	3.20
Tbiv	-15 °C	-15 °C
TOL	-15 °C	-15 °C
Pdh Tj = -7°C	2.75 kW	2.48 kW
$COP Tj = -7^{\circ}C$	3.80	2.88
Cdh Tj = -7 °C	0.990	0.990
Pdh Tj = +2°C	3.12 kW	3.42 kW
COP Tj = +2°C	4.80	4.07
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = $+7^{\circ}$ C	4.18 kW	4.06 kW
$COP Tj = +7^{\circ}C$	6.13	5.26
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	2.26 kW	4.81 kW
COP Tj = 12°C	5.29	6.38
Cdh Tj = +12 °C	0.980	0.990
Pdh Tj = Tbiv	3.64 kW	3.71 kW
COP Tj = Tbiv	2.92	2.24
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	3.64 kW	3.71 kW





COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.92	2.24
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	0.990
WTOL	70 °C	70 °C
Poff	o w	o w
РТО	9 W	9 W
PSB	8 W	8 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.50 kW	4.50 kW
Annual energy consumption Qhe	2936 kWh	3472 kWh
Pdh Tj = -15°C (if TOL<-20°C)	3.64	3.71
COP Tj = -15°C (if TOL $<$ -20°C)	2.92	2.24
Cdh Tj = -15 °C	0.990	0.990

Average Climate

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	0 dB(A)	0 dB(A)	
Sound power level outdoor	57 dB(A)	57 dB(A)	

EN 14825





	Low temperature	Medium temperature
η_{s}	180 %	142 %
Prated	5.00 kW	5.00 kW
SCOP	4.57	3.63
Tbiv	-10 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	4.32 kW	4.40 kW
$COP Tj = -7^{\circ}C$	3.27	2.35
Cdh Tj = -7 °C	0.990	1.000
Pdh Tj = +2°C	3.18 kW	3.41 kW
COP Tj = +2°C	4.49	3.58
Cdh Tj = +2 °C	0.990	0.990
Pdh Tj = +7°C	4.07 kW	3.85 kW
$COP Tj = +7^{\circ}C$	5.87	4.81
Cdh Tj = +7 °C	0.990	0.990
Pdh Tj = 12°C	5.11 kW	4.79 kW
COP Tj = 12°C	6.96	6.11
Cdh Tj = +12 °C	0.990	0.990
Pdh Tj = Tbiv	5.03 kW	4.40 kW
COP Tj = Tbiv	3.01	2.35
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.03 kW	4.52 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



$$\operatorname{\textit{Page}}8 of 8 This information was generated by the HP KEYMARK database on 23 Jun 2022

COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.01	2.19
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.990	1.000
WTOL	70 °C	70 °C
Poff	o w	o w
PTO	9 W	9 W
PSB	8 W	8 W
PCK	9 W	9 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.48 kW
Annual energy consumption Qhe	2258 kWh	2844 kWh