

This information was generated by the HP KEYMARK database on 7 Jul 2022

[Login](#)

Summary of	AUREA 5	Reg. No.	012-SC1489-17
Certificate Holder			
Name	Groupe Atlantic		
Address	44 boulevard des Etats-Unis	Zip	85000
City	La Roche Sur Yon	Country	France
Certification Body	RISE CERT		
Subtype title	AUREA 5		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	1.05 kg		

## Model: AUREA 5

Configure model	
Model name	AUREA 5
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

### Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.84 kW	4.10 kW
El input	1.20 kW	1.58 kW
COP	4.03	2.60

### Average Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	0 dB(A)	0 dB(A)
Sound power level outdoor	60 dB(A)	60 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	167 %	119 %
Prated	4.40 kW	4.40 kW
SCOP	4.25	3.06
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	3.89 kW	3.89 kW
COP Tj = -7°C	2.64	1.82
Pdh Tj = +2°C	2.37 kW	2.37 kW
COP Tj = +2°C	4.35	3.11
Pdh Tj = +7°C	2.16 kW	1.92 kW
COP Tj = +7°C	5.93	4.15
Pdh Tj = 12°C	1.15 kW	0.96 kW
COP Tj = 12°C	7.55	5.03
Pdh Tj = Tbiv	3.89 kW	3.89 kW

This information was generated by the HP KEYMARK database on 7 Jul 2022

COP $T_j = T_{biv}$	2.64	1.82
$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	3.72 kW	3.41 kW
COP $T_j = TOL$ or COP $T_j = T_{designh}$ if $TOL < T_{designh}$	2.57	1.52
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	0.84	0.89
WTOL	55 °C	55 °C
P <sub>off</sub>	5 W	5 W
PTO	60 W	50 W
PSB	5 W	5 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.70 kW	1.00 kW
Annual energy consumption $Q_{he}$	2137 kWh	2973 kWh