

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	AW-TDF190-H31	Reg. No.	ICIM-PDC-000034-00
Certificate Holder			
Name	Airwell Residential		
Address	10, rue du Fort de Saint Cyr	Zip	78180
City	Montigny le Bretonneux	Country	France
Certification Body	ICIM S.p.A.		
Name of testing laboratory	-- TRANSITION RULES --		
Subtype title	AW-TDF190-H31		
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)		
Refrigerant	R134a		
Mass Of Refrigerant	1.1 kg		
Certification Date	20.06.2019		

## Model: AW-TDF190-H31

### General Data

Power supply	1x230V 50Hz
Off-peak product	No

Domestic Hot Water (DHW)

Average Climate

### EN 12102-2

Sound power level indoor	51 dB(A)
--------------------------	----------

### EN 16147

Declared load profile	L
Efficiency $\eta_{DHW}$	115 %
COP	2.76
Heating up time	7:01 h:min
Standby power input	26.3 W
Reference hot water temperature	53.8 °C
Mixed water at 40°C	234 l

Operating test

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Temperature operating range	passed
Safety devices checking test	passed
Condensate draining	passed