

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	VIESSMANN Vitocal 060-A (100 L) Typ TOP 060-A		Reg. No.	011-1W0318
Certificate Holder				
Name	Viessmann Faulquemont SAS			
Address	Avenue André Gouy		Zip	F-57380
City	Faulquemont		Country	France
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH			
Name of testing laboratory	TÜV Rheinland Energy GmbH			
Subtype title	VIESSMANN Vitocal 060-A (100 L) Typ TOP 060-A			
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)			
Refrigerant	R134a			
Mass Of Refrigerant	1.35 kg			
Certification Date	19.11.2019			

## Model: Vitocal 060-A TOP

### General Data

Power supply	1x230V 50Hz
Off-peak product	Yes

Domestic Hot Water (DHW)

Average Climate

### EN 12102-2

Sound power level indoor	57 dB(A)
--------------------------	----------

### EN 16147

Declared load profile	S
Efficiency $\eta_{DHW}$	103 %
COP	2.22
Heating up time	4:20 h:min
Standby power input	23.0 W
Reference hot water temperature	53.5 °C
Mixed water at 40°C	63 l

Operating test

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Temperature operating range	passed
Safety devices checking test	passed
Condensate draining	passed