

This information was generated by the HP KEYMARK database on 21 Jun 2022

[Login](#)

Summary of	TTL 8.5 ICS, TTL 8.5 IKCS	Reg. No.	011-1W0226
Certificate Holder			
Name	tecalor GmbH		
Address	Fürstenbergerstr. 77	Zip	37603
City	Holzminden	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	TTL 8.5 ICS, TTL 8.5 IKCS		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.6 kg		
Certification Date	03.04.2018		
Testing basis	HP KEYMARK certification scheme rules rev. no. 3		

Model: TTL 8.5 IKCS

Configure model	
Model name	TTL 8.5 IKCS
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.22 kW	3.75 kW
El input	0.92 kW	1.49 kW
COP	4.60	2.51

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 21 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	40 dB(A)	44 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	161 %	126 %
Prated	9.20 kW	7.10 kW
SCOP	4.11	3.21
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.93 kW	6.28 kW
COP Tj = -7°C	2.61	2.13
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	5.16 kW	4.73 kW
COP Tj = +2°C	4.03	3.04
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.20 kW	4.20 kW
COP Tj = +7°C	5.25	4.44
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.39 kW	3.14 kW

This information was generated by the HP KEYMARK database on 21 Jun 2022

COP Tj = 12°C	8.03	6.21
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.93 kW	6.28 kW
COP Tj = Tbiv	2.61	2.13
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.29 kW	2.77 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.55	1.83
WTOL	60 °C	60 °C
Poff	56 W	56 W
PTO	21 W	21 W
PSB	56 W	56 W
PCK	26 W	26 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.91 kW	4.43 kW
Annual energy consumption Qhe	4621 kWh	4564 kWh

Warmer Climate

EN 14825		
	Low temperature	Medium temperature
η_s	207 %	142 %
Prated	4.95 kW	4.30 kW
SCOP	5.24	3.63

This information was generated by the HP KEYMARK database on 21 Jun 2022

Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	4.95 kW	4.34 kW
COP Tj = +2°C	3.70	2.21
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.21 kW	3.96 kW
COP Tj = +7°C	4.90	3.21
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.31 kW	2.98 kW
COP Tj = 12°C	7.35	5.30
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	4.95 kW	4.34 kW
COP Tj = Tbiv	3.70	2.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.95 kW	4.34 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.70	2.21
WTOL	60 °C	60 °C
Poff	56 W	56 W
PTO	21 W	21 W
PSB	56 W	56 W
PCK	26 W	26 W
Supplementary Heater: Type of energy input	Electricity	Electricity

This information was generated by the HP KEYMARK database on 21 Jun 2022

Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	1262 kWh	1584 kWh

Colder Climate

EN 14825		
	Low temperature	Medium temperature
η_s	126 %	105 %
Prated	13.20 kW	12.70 kW
SCOP	3.23	2.69
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	7.96 kW	7.69 kW
COP T _j = -7°C	2.73	2.26
C _{dh} T _j = -7 °C	0.90	0.90
P _{dh} T _j = +2°C	5.29 kW	4.89 kW
COP T _j = +2°C	4.24	3.49
C _{dh} T _j = +2 °C	0.90	0.90
P _{dh} T _j = +7°C	4.19 kW	4.21 kW
COP T _j = +7°C	5.45	4.82
C _{dh} T _j = +7 °C	0.90	0.90
P _{dh} T _j = 12°C	3.39 kW	3.23 kW

This information was generated by the HP KEYMARK database on 21 Jun 2022

COP Tj = 12°C	8.03	6.75
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.96 kW	7.69 kW
COP Tj = Tbiv	2.73	2.26
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.13 kW	5.24 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.27	1.00
WTOL	60 °C	60 °C
Poff	56 W	56 W
PTO	21 W	21 W
PSB	56 W	56 W
PCK	26 W	26 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	7.38 kW	6.79 kW
Annual energy consumption Qhe	10074 kWh	11651 kWh
Pdh Tj = -15°C (if TOL<-20°C)	6.21	6.18
COP Tj = -15°C (if TOL<-20°C)	2.43	1.48
Cdh Tj = -15 °C	0.90	0.90

Model: TTL 8.5 ICS

Configure model	
Model name	TTL 8.5 ICS
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	4.27 kW	3.81 kW
El input	0.90 kW	1.48 kW
COP	4.74	2.58

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate

This information was generated by the HP KEYMARK database on 21 Jun 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	48 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	167 %	129 %
Prated	9.00 kW	7.20 kW
SCOP	4.24	3.30
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.98 kW	6.39 kW
COP Tj = -7°C	2.65	2.17
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	5.25 kW	4.81 kW
COP Tj = +2°C	4.19	3.14
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.26 kW	4.25 kW
COP Tj = +7°C	5.44	4.56
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.43 kW	3.18 kW

This information was generated by the HP KEYMARK database on 21 Jun 2022

COP Tj = 12°C	8.21	6.33
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.98 kW	6.39 kW
COP Tj = Tbiv	2.65	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.35 kW	2.77 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.59	1.83
WTOL	60 °C	60 °C
Poff	56 W	56 W
PTO	21 W	21 W
PSB	56 W	56 W
PCK	26 W	26 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.65 kW	4.43 kW
Annual energy consumption Qhe	4387 kWh	4506 kWh

Warmer Climate

EN 14825		
	Low temperature	Medium temperature
η_s	212 %	145 %
Prated	5.02 kW	4.40 kW
SCOP	5.38	3.69

This information was generated by the HP KEYMARK database on 21 Jun 2022

Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.02 kW	4.42 kW
COP Tj = +2°C	3.83	2.27
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.27 kW	4.02 kW
COP Tj = +7°C	5.06	3.30
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.35 kW	3.01 kW
COP Tj = 12°C	7.50	5.35
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	5.02 kW	4.42 kW
COP Tj = Tbiv	3.83	2.27
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.02 kW	4.42 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.83	2.27
WTOL	60 °C	60 °C
Poff	56 W	56 W
PTO	21 W	21 W
PSB	56 W	56 W
PCK	26 W	26 W
Supplementary Heater: Type of energy input	Electricity	Electricity

This information was generated by the HP KEYMARK database on 21 Jun 2022

Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Q _{he}	1247 kWh	1592 kWh

Colder Climate

EN 14825		
	Low temperature	Medium temperature
η_s	130 %	112 %
Prated	13.40 kW	13.00 kW
SCOP	3.33	2.86
T _{biv}	-7 °C	-7 °C
TOL	-20 °C	-20 °C
P _{dh} T _j = -7°C	8.13 kW	7.84 kW
COP T _j = -7°C	2.81	2.31
C _{dh} T _j = -7 °C	0.90	0.90
P _{dh} T _j = +2°C	5.39 kW	4.96 kW
COP T _j = +2°C	4.42	3.61
C _{dh} T _j = +2 °C	0.90	0.90
P _{dh} T _j = +7°C	4.26 kW	4.27 kW
COP T _j = +7°C	5.65	4.98
C _{dh} T _j = +7 °C	0.90	0.90
P _{dh} T _j = 12°C	3.43 kW	3.26 kW

This information was generated by the HP KEYMARK database on 21 Jun 2022

COP Tj = 12°C	8.21	6.88
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	8.13 kW	7.84 kW
COP Tj = Tbiv	2.81	2.31
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.24 kW	5.24 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.33	2.33
WTOL	60 °C	60 °C
Poff	56 W	56 W
PTO	21 W	21 W
PSB	56 W	56 W
PCK	26 W	26 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	7.45 kW	7.08 kW
Annual energy consumption Qhe	9919 kWh	11197 kWh
Pdh Tj = -15°C (if TOL<-20°C)	6.29	6.24
COP Tj = -15°C (if TOL<-20°C)	2.47	2.32
Cdh Tj = -15 °C	0.90	0.90