

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	THERMOR Alféa Extensa A.I. size 16		Reg. No.	012-SC0227-19
Certificate Holder				
Name	Groupe Atlantic			
Address	44 boulevard des Etats-Unis	Zip	85000	
City	La Roche Sur Yon	Country	France	
Certification Body	RISE CERT			
Name of testing laboratory	SP			
Subtype title	THERMOR Alféa Extensa A.I. size 16			
Heat Pump Type	Outdoor Air/Water			
Refrigerant	R410a			
Mass Of Refrigerant	2.5 kg			
Certification Date	05.06.2019			

Model: THERMOR Alféa Extensa A.I. 16

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	16.06 kW	10.03 kW
El input	4.37 kW	4.01 kW
COP	3.68	2.50
Indoor water flow rate	2.77 m ³ /h	1.08 m ³ /h

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	46 dB(A)	46 dB(A)
Sound power level outdoor	70 dB(A)	70 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	149 %	113 %
Prated	13.00 kW	11.00 kW
SCOP	3.77	2.90
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	11.10 kW	10.00 kW
COP Tj = -7°C	2.50	1.90
Pdh Tj = +2°C	6.70 kW	6.10 kW
COP Tj = +2°C	3.60	2.80
Pdh Tj = +7°C	6.20 kW	5.90 kW
COP Tj = +7°C	5.40	3.90
Pdh Tj = 12°C	7.30 kW	7.10 kW
COP Tj = 12°C	6.90	5.10
Pdh Tj = Tbiv	11.10 kW	10.00 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

COP $T_j = T_{biv}$	2.50	1.90
P _{dh} $T_j = TOL$	10.80 kW	9.30 kW
COP $T_j = TOL$	2.40	1.70
C _{dh}	0.90	0.90
WTOL	55 °C	55 °C
P _{off}	8 W	8 W
PTO	72 W	25 W
PSB	12 W	12 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	1.70 kW	2.10 kW
Annual energy consumption Q _{he}	6824 kWh	8041 kWh