

Page 1 of 8

#### This information was generated by the HP KEYMARK database on 4 Apr 2022

#### <u>Login</u>

Summary of	WPF 35	Reg. No.	011-1W0029	
Certificate Holder	<u> </u>	<u> </u>		
Name	STIEBEL ELTRON GmbH & Co	STIEBEL ELTRON GmbH & Co KG		
Address	Dr. Stiebel Straße 33	Zip	37603	
City	Holzminden	Country	Germany	
Certification Body	DIN CERTCO Gesellschaft für	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	WPF 35			
Heat Pump Type	Brine/Water			
Refrigerant	R410A			
Mass of Refrigerant	10 kg	10 kg		
Certification Date	19.09.2016	19.09.2016		
Testing basis	Heat pump scheme rules KEYMARK Rev 1.1			



## Model: WPF 35

Configure model		
Model name	WPF 35	
Application	Heating (medium temp)	
Units	Indoor + Outdoor	
Climate Zone	Colder Climate + Warmer Climate	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply	3x400V 50Hz	

### Heating

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

EN 14511-2				
Low temperature Medium temperature				
Heat output	37.70 kW	34.49 kW		
El input	7.98 kW	11.47 kW		
СОР	4.72	3.01		

# **Average Climate**



EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	60 dB(A)	60 dB(A)	
Sound power level outdoor	60 dB(A)	60 dB(A)	

EN 14825		
	Low temperature	Medium temperature
$\eta_{s}$	200 %	133 %
Prated	38.00 kW	34.00 kW
SCOP	5.19	3.52
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	38.10 kW	34.50 kW
COP Tj = -7°C	4.84	2.95
Pdh Tj = +2°C	38.60 kW	35.80 kW
COP Tj = +2°C	5.20	3.50
Pdh Tj = +7°C	39.00 kW	36.70 kW
COP Tj = +7°C	5.56	2.92
Pdh Tj = 12°C	39.30 kW	37.50 kW
COP Tj = 12°C	5.96	4.42
Pdh Tj = Tbiv	38.00 kW	34.10 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





		<u> </u>
COP Tj = Tbiv	4.75	2.82
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	38.00 kW	34.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.78	2.82
Rated airflow rate	0 m³/h	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	0 W	0 W
PTO	7 W	7 W
PSB	7 W	7 W
PCK	74 W	74 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	15136 kWh	20029 kWh

### Warmer Climate

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level indoor	60 dB(A)	60 dB(A)	
Sound power level outdoor	60 dB(A)	60 dB(A)	

EN 14825		
	Low temperature	Medium temperature





<u> </u>		MARK database on 4 Apr 20
$\eta_s$	199 %	132 %
Prated	38.00 kW	34.00 kW
SCOP	5.17	3.50
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = -7°C	0.00 kW	0.00 kW
$COP Tj = -7^{\circ}C$	0.00	0.00
Pdh Tj = +2°C	38.00 kW	34.10 kW
COP Tj = +2°C	4.78	2.82
Pdh Tj = +7°C	38.50 kW	35.20 kW
COP Tj = +7°C	5.12	3.24
Pdh Tj = 12°C	39.10 kW	37.00 kW
COP Tj = 12°C	5.69	4.08
Pdh Tj = Tbiv	38.00 kW	34.10 kW
COP Tj = Tbiv	4.78	2.82
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	38.00 kW	34.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.78	2.82
Rated airflow rate	0 m³/h	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C






Poff	o w	0 W
PTO	7 W	7 W
PSB	7 W	7 W
PCK	7 W	74 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	9834 kWh	13033 kWh

#### Colder Climate

EN 12102-1				
	Low temperature	Medium temperature		
Sound power level indoor	60 dB(A)	60 dB(A)		
Sound power level outdoor	60 dB(A)	60 dB(A)		

EN 14825			
	Low temperature	Medium temperature	
$\eta_{s}$	208 %	139 %	
Prated	47.00 kW	43.00 kW	
SCOP	5.41	3.66	
Tbiv	-15 °C	-15 °C	
TOL	-22 °C	-22 °C	





This information was gener	ated by the HE KETMA	ink database on 4 Apr 2022
Pdh Tj = $-7^{\circ}$ C	38.80 kW	35.80 kW
$COP Tj = -7^{\circ}C$	5.38	3.48
Pdh Tj = +2°C	39.10 kW	36.70 kW
COP Tj = +2°C	5.67	3.91
Pdh Tj = $+7^{\circ}$ C	39.30 kW	37.40 kW
$COP Tj = +7^{\circ}C$	5.90	4.32
Pdh Tj = 12°C	39.30 kW	37.90 kW
COP Tj = 12°C	5.94	4.66
Pdh Tj = Tbiv	38.60 kW	35.30 kW
COP Tj = Tbiv	5.26	3.25
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	38.60 kW	34.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.26	2.82
Rated airflow rate	0 m³/h	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	o w	o w
РТО	7 W	7 W
PSB	7 W	7 W
РСК	74 W	74 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	9.32 kW	9.15 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 8 of 8

This information was generated by the HP KEYMARK database on 4 Apr 2022

Annual energy consumption Qhe	21594 kWh	28986 kWh