

Page 1 of 7

This information was generated by the HP KEYMARK database on 23 Jun 2022

Login

Summary of	WPL 25 ACS	Reg. No.	011-1W0492	
Certificate Holder				
Name	STIEBEL ELTRON GmbH & Co	STIEBEL ELTRON GmbH & Co KG		
Address	Dr. Stiebel Straße 33	Zip	37603	
City	Holzminden	Country	Germany	
Certification Body	DIN CERTCO Gesellschaft für	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	WPL 25 ACS	WPL 25 ACS		
Heat Pump Type	Outdoor Air/Water	Outdoor Air/Water		
Refrigerant	R410A	R410A		
Mass of Refrigerant	5.5 kg	5.5 kg		
Certification Date	11.08.2016	11.08.2016		

This information was generated by the HP KEYMARK database on 23 Jun 2022

Model: WPL 25 ACS

Configure model		
Model name	WPL 25 ACS	
Application	Heating (medium temp)	
Units	Outdoor	
Climate Zone	Colder Climate + Warmer Climate	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply	1x230V 50Hz	

Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	8.00 kW	7.52 kW	
El input	1.66 kW	2.33 kW	
СОР	4.82	3.23	

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Starting and operating test	passed

Average Climate



This information was generated by the HP KEYMARK database on 23 Jun 2022

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level outdoor	54 dB(A)	54 dB(A)	

EN 14825		
	Low temperature	Medium temperature
η_{s}	178 %	139 %
Prated	15.00 kW	15.00 kW
SCOP	4.53	3.55
Tbiv	-5 °C	-5 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	13.00 kW	13.80 kW
COP Tj = -7°C	3.02	2.43
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	8.00 kW	7.70 kW
COP Tj = +2°C	4.40	3.37
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	8.10 kW	7.90 kW
COP Tj = +7°C	5.64	4.45
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	9.10 kW	9.00 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com






COP Tj = 12°C	8.11	6.66
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	11.80 kW	12.40 kW
COP Tj = Tbiv	3.18	2.53
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.60 kW	13.40 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.87	2.28
WTOL	65 °C	65 °C
Poff	16 W	16 W
РТО	16 W	16 W
PSB	16 W	16 W
PCK	43 W	43 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	6839 kWh	8723 kWh

Warmer Climate

EN 14825		
ture Medium temperature		
174 %		
7.00 kW		
4.44		
_		





This information was gener	The The The Territor	RK database on 23 Jun 202
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	7.90 kW	7.40 kW
COP Tj = +2°C	3.89	2.59
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = $+7^{\circ}$ C	8.10 kW	7.70 kW
$COPTj = +7^{\circ}C$	5.10	3.60
Cdh Tj = $+7$ °C	0.90	0.90
Pdh Tj = 12°C	9.10 kW	9.00 kW
COP Tj = 12°C	7.72	6.11
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.90 kW	7.40 kW
COP Tj = Tbiv	3.89	2.59
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	17.60 kW	19.80 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.72	2.29
WTOL	65 °C	65 °C
Poff	16 W	16 W
РТО	16 W	16 W
PSB	16 W	16 W
PCK	43 W	43 W
Supplementary Heater: Type of energy input	Electricity	Electricity





This information was generated by the HP KEYMARK database on 23 Jun 2022			
ementary Heater: PSUP	0.00 kW	0.00 kW	

Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1789 kWh	2107 kWh

Colder Climate

EN 14825			
	Low temperature	Medium temperature	
η_{s}	154 %	137 %	
Prated	21.00 kW	22.00 kW	
SCOP	3.93	3.25	
Tbiv	-7 °C	-7 °C	
TOL	-20 °C	-20 °C	
Pdh Tj = -7°C	12.80 kW	13.50 kW	
COP Tj = -7°C	3.21	2.65	
Cdh Tj = -7 °C	0.90	0.90	
Pdh Tj = +2°C	8.10 kW	7.90 kW	
COP Tj = +2°C	4.75	3.75	
Cdh Tj = +2 °C	0.90	0.90	
Pdh Tj = +7°C	8.20 kW	8.00 kW	
COP Tj = +7°C	5.95	4.86	
Cdh Tj = +7 °C	0.90	0.90	
Pdh Tj = 12°C	9.10 kW	9.00 kW	

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 7 of 7 This information was generated by the HP KEYMARK database on 23 Jun 2022

		-
COP Tj = 12°C	8.11	6.95
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	12.80 kW	13.50 kW
COP Tj = Tbiv	3.21	2.65
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	17.40 kW	19.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	2.38
WTOL	65 °C	65 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	43 W	43 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	21.17 kW	22.26 kW
Annual energy consumption Qhe	13182 kWh	16684 kWh
Pdh Tj = -15°C (if TOL<-20°C)	17.40	19.30
COP Tj = -15°C (if TOL $<$ -20°C)	2.80	2.38
Cdh Tj = -15 °C	0.90	0.90