

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	ECO300	Reg. No.	011-1W0352
Certificate Holder			
Name	Energie		
Address		Zip	4570-311
City	Laúndos - Póvoa de Varzim	Country	Portugal
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Name of testing laboratory	Centro de apoio tecnológico à Indústria Metalomecânica (CATIM)		
Subtype title	ECO300		
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)		
Refrigerant	R134a		
Mass Of Refrigerant	1300 kg		
Certification Date	23.06.2020		

Model: Eco300

General Data

Power supply	1x230V 50Hz
Off-peak product	No

Domestic Hot Water (DHW)

Operating test

EN 16147

Temperature operating range	passed
Safety devices checking test	passed
Condensate draining	passed

Average Climate

EN 12102-2

Sound power level indoor	47 dB(A)
--------------------------	----------

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 16147	
Declared load profile	XL
Efficiency η_{DHW}	129 %
COP	3.13
Heating up time	11:27 h:min
Standby power input	32.0 W
Reference hot water temperature	53.5 °C
Mixed water at 40°C	330 l