

Page 1 of 6

#### This information was generated by the HP KEYMARK database on 22 Jun 2022

#### **Login**

Summary of	SHP-F 300 (X) Premium	Reg. No.	011-1W0241
Certificate Holder			
Name	STIEBEL ELTRON GmbH & Co KG		
Address	Dr. Stiebel Straße 33	Zip	37603
City	Holzminden	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	SHP-F 300 (X) Premium		
Heat Pump Type	Heat Pump for Domestic Hot Water (DHW)		
Refrigerant	R134a		
Mass of Refrigerant	0.85 kg		
Certification Date	22.02.2018		



This information was generated by the HP KEYMARK database on 22 Jun 2022

## **Model: SHP-F 300 Premium**

Configure model		
Model name	SHP-F 300 Premium	
Units	Indoor + Outdoor	
Climate zone (for heating)	n/a	
Heat Source	n/a	
Any additional heat sources	n/a	

General Data	
Power supply	1x230V 50Hz
Off-peak product	No



#### Domestic Hot Water (DHW)

### Average Climate

EN 12102-2		
Sound power level indoor	60 dB(A)	
Sound power level outdoor	48 dB(A)	

EN 16147		
Declared load profile	XL	
Efficiency ηDHW	132 %	
СОР	3.22	
Heating up time	11:19 h:min	
Standby power input	27.0 W	
Reference hot water temperature	54.3 °C	
Mixed water at 40°C	422 I	

# Operating test

EN 16147	
Temperature operating range	passed
Safety devices checking test	passed
Condensate draining	passed



This information was generated by the HP KEYMARK database on 22 Jun 2022

# **Model: SHP-F 300 X Premium**

Configure model		
Model name	SHP-F 300 X Premium	
Units	Indoor + Outdoor	
Climate zone (for heating)	n/a	
Heat Source	n/a	
Any additional heat sources	n/a	

General Data	
Power supply	1x230V 50Hz
Off-peak product	No



#### Domestic Hot Water (DHW)

### Average Climate

EN 12102-2	
Sound power level indoor	60 dB(A)
Sound power level outdoor	48 dB(A)

EN 16147		
Declared load profile	XL	
Efficiency ηDHW	122 %	
СОР	2.99	
Heating up time	12:14 h:min	
Standby power input	27.0 W	
Reference hot water temperature	52.5 °C	
Mixed water at 40°C	394 I	

# Operating test

EN 16147	
Temperature operating range	passed
Safety devices checking test	passed
Condensate draining	passed





This information was generated by the HP KEYMARK database on 22 Jun 2022