

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	DAIKIN ALTHERMA 3 H F+W 11kW (180L)	Reg. No.	011-1W0319
Certificate Holder			
Name	DAIKIN Europe N.V.		
Address	Zandvoordestraat 300	Zip	B-8400
City	Oostende	Country	Belgium
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	DAIKIN ALTHERMA 3 H F+W 11kW (180L)		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	3.5 kg		
Certification Date	06.03.2019		
Testing basis	HP KEYMARK certification scheme rules rev. 9		

Model: EPGA11DV / EABH16D(6V/9W)

Configure model	
Model name	EPGA11DV / EABH16D(6V/9W)
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.10 kW	15.84 kW
El input	2.16 kW	5.17 kW
COP	5.15	3.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	3.30 kW
Cooling capacity	10.66
EER	3.23

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	10.7 kW
SEER	5.1
P _{dc} T _j = 35°C	10.66 kW
EER T _j = 35°C	3.23
P _{dc} T _j = 30°C	7.87 kW
EER T _j = 30°C	4.32
C _{dc}	1
P _{dc} T _j = 25°C	5.16 kW
EER T _j = 25°C	6.16
C _{dc}	1
P _{dc} T _j = 20°C	7.86 kW
EER T _j = 20°C	6.65
C _{dc}	1
P _{off}	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Q _{ce}	1260 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	172 %	129 %
Prated	11.00 kW	13.00 kW
SCOP	4.38	3.29
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.70 kW	11.50 kW
COP Tj = -7°C	3.07	2.25
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	6.30 kW	6.50 kW
COP Tj = +2°C	4.15	3.14
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.50 kW	4.60 kW
COP Tj = +7°C	5.86	4.27
Cdh Tj = +7 °C	0.95	0.96

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.30 kW	5.20 kW
COP Tj = 12°C	7.88	5.75
Cdh Tj = +12 °C	0.94	0.95
Pdh Tj = Tbiv	11.00 kW	12.50 kW
COP Tj = Tbiv	2.80	2.11
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.00 kW	12.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	2.11
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5189 kWh	7845 kWh

Model: EPGA11DV / EABX16D(6V/9W)

Configure model	
Model name	EPGA11DV / EABX16D(6V/9W)
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.10 kW	15.84 kW
El input	2.16 kW	5.17 kW
COP	5.15	3.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	3.30 kW
Cooling capacity	10.66
EER	3.23

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	10.7 kW
SEER	5.1
P _{dc} T _j = 35°C	10.66 kW
EER T _j = 35°C	3.23
P _{dc} T _j = 30°C	7.87 kW
EER T _j = 30°C	4.32
C _{dc}	1
P _{dc} T _j = 25°C	5.16 kW
EER T _j = 25°C	6.16
C _{dc}	1
P _{dc} T _j = 20°C	7.86 kW
EER T _j = 20°C	6.65
C _{dc}	1
P _{off}	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Q _{ce}	1260 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	130 %
Prated	11.00 kW	13.00 kW
SCOP	4.44	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.70 kW	11.50 kW
COP Tj = -7°C	3.07	2.25
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	6.30 kW	6.50 kW
COP Tj = +2°C	4.15	3.14
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.50 kW	4.60 kW
COP Tj = +7°C	5.86	4.27
Cdh Tj = +7 °C	0.95	0.96

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.30 kW	5.20 kW
COP Tj = 12°C	7.88	5.75
Cdh Tj = +12 °C	0.94	0.95
Pdh Tj = Tbiv	11.00 kW	12.50 kW
COP Tj = Tbiv	2.80	2.11
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.00 kW	12.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	2.11
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5112 kWh	7768 kWh

Model: EPGA11DV / EAVH16S18D(6V/9W)(G)

Configure model

Model name	EPGA11DV / EAVH16S18D(6V/9W)(G)
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.10 kW	15.84 kW
El input	2.16 kW	5.17 kW
COP	5.15	3.06

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	3.30 kW
Cooling capacity	10.66
EER	3.23

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	10.7 kW
SEER	5.1
P _{dc} T _j = 35°C	10.66 kW
EER T _j = 35°C	3.23
P _{dc} T _j = 30°C	7.87 kW
EER T _j = 30°C	4.32
C _{dc}	1
P _{dc} T _j = 25°C	5.16 kW
EER T _j = 25°C	6.16
C _{dc}	1
P _{dc} T _j = 20°C	7.86 kW
EER T _j = 20°C	6.65
C _{dc}	1
P _{off}	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Q _{ce}	1260 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	172 %	129 %
Prated	11.00 kW	13.00 kW
SCOP	4.38	3.29
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.70 kW	11.50 kW
COP Tj = -7°C	3.07	2.25
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	6.30 kW	6.50 kW
COP Tj = +2°C	4.15	3.14
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.50 kW	4.60 kW
COP Tj = +7°C	5.86	4.27
Cdh Tj = +7 °C	0.95	0.96

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.30 kW	5.20 kW
COP Tj = 12°C	7.88	5.75
Cdh Tj = +12 °C	0.94	0.95
Pdh Tj = Tbiv	11.00 kW	12.50 kW
COP Tj = Tbiv	2.80	2.11
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.00 kW	12.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	2.11
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5189 kWh	7845 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	104 %
COP	2.51
Heating up time	0:57 h:min
Standby power input	32.8 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPGA11DV / EAVX16S18D(6V/9W)(G)

Configure model	
Model name	EPGA11DV / EAVX16S18D(6V/9W)(G)
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.10 kW	15.84 kW
El input	2.16 kW	5.17 kW
COP	5.15	3.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	3.30 kW
Cooling capacity	10.66
EER	3.23

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	10.7 kW
SEER	5.1
P _{dc} T _j = 35°C	10.66 kW
EER T _j = 35°C	3.23
P _{dc} T _j = 30°C	7.87 kW
EER T _j = 30°C	4.32
C _{dc}	1
P _{dc} T _j = 25°C	5.16 kW
EER T _j = 25°C	6.16
C _{dc}	1
P _{dc} T _j = 20°C	7.86 kW
EER T _j = 20°C	6.65
C _{dc}	1
P _{off}	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Q _{ce}	1260 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	130 %
Prated	11.00 kW	13.00 kW
SCOP	4.44	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.70 kW	11.50 kW
COP Tj = -7°C	3.07	2.25
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	6.30 kW	6.50 kW
COP Tj = +2°C	4.15	3.14
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.50 kW	4.60 kW
COP Tj = +7°C	5.86	4.27
Cdh Tj = +7 °C	0.95	0.96

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.30 kW	5.20 kW
COP Tj = 12°C	7.88	5.75
Cdh Tj = +12 °C	0.94	0.95
Pdh Tj = Tbiv	11.00 kW	12.50 kW
COP Tj = Tbiv	2.80	2.11
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.00 kW	12.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	2.11
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5112 kWh	7768 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	104 %
COP	2.51
Heating up time	0:57 h:min
Standby power input	32.8 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPGA11DV / EAVZ16S18D(6V/9W)

Configure model	
Model name	EPGA11DV / EAVZ16S18D(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.10 kW	15.84 kW
El input	2.16 kW	5.17 kW
COP	5.15	3.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	3.30 kW
Cooling capacity	10.66
EER	3.23

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	10.7 kW
SEER	5.1
P _{dc} T _j = 35°C	10.66 kW
EER T _j = 35°C	3.23
P _{dc} T _j = 30°C	7.87 kW
EER T _j = 30°C	4.32
C _{dc}	1
P _{dc} T _j = 25°C	5.16 kW
EER T _j = 25°C	6.16
C _{dc}	1
P _{dc} T _j = 20°C	7.86 kW
EER T _j = 20°C	6.65
C _{dc}	1
P _{off}	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Q _{ce}	1260 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	172 %	129 %
Prated	11.00 kW	13.00 kW
SCOP	4.38	3.29
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.70 kW	11.50 kW
COP Tj = -7°C	3.07	2.25
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	6.30 kW	6.50 kW
COP Tj = +2°C	4.15	3.14
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.50 kW	4.60 kW
COP Tj = +7°C	5.86	4.27
Cdh Tj = +7 °C	0.95	0.96

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.30 kW	5.20 kW
COP Tj = 12°C	7.88	5.75
Cdh Tj = +12 °C	0.94	0.95
Pdh Tj = Tbiv	11.00 kW	12.50 kW
COP Tj = Tbiv	2.80	2.11
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.00 kW	12.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	2.11
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5189 kWh	7845 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	104 %
COP	2.51
Heating up time	0:57 h:min
Standby power input	32.8 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPGA11DV / EABH16D(6V/9W) + cooling kit

Configure model	
Model name	EPGA11DV / EABH16D(6V/9W) + cooling kit
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.10 kW	15.84 kW
El input	2.16 kW	5.17 kW
COP	5.15	3.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	3.30 kW
Cooling capacity	10.66
EER	3.23

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	10.7 kW
SEER	5.1
P _{dc} T _j = 35°C	10.66 kW
EER T _j = 35°C	3.23
P _{dc} T _j = 30°C	7.87 kW
EER T _j = 30°C	4.32
C _{dc}	1
P _{dc} T _j = 25°C	5.16 kW
EER T _j = 25°C	6.16
C _{dc}	1
P _{dc} T _j = 20°C	7.86 kW
EER T _j = 20°C	6.65
C _{dc}	1
P _{off}	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Q _{ce}	1260 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	130 %
Prated	11.00 kW	13.00 kW
SCOP	4.44	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.70 kW	11.50 kW
COP Tj = -7°C	3.07	2.25
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	6.30 kW	6.50 kW
COP Tj = +2°C	4.15	3.14
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.50 kW	4.60 kW
COP Tj = +7°C	5.86	4.27
Cdh Tj = +7 °C	0.95	0.96

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.30 kW	5.20 kW
COP Tj = 12°C	7.88	5.75
Cdh Tj = +12 °C	0.94	0.95
Pdh Tj = Tbiv	11.00 kW	12.50 kW
COP Tj = Tbiv	2.80	2.11
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.00 kW	12.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	2.11
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5112 kWh	7768 kWh

Model: EPGA11DV / EAVH16S18D(6V/9W)(G) + cooling kit

Configure model	
Model name	EPGA11DV / EAVH16S18D(6V/9W)(G) + cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.10 kW	15.84 kW
El input	2.16 kW	5.17 kW
COP	5.15	3.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	3.30 kW
Cooling capacity	10.66
EER	3.23

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	10.7 kW
SEER	5.1
P _{dc} T _j = 35°C	10.66 kW
EER T _j = 35°C	3.23
P _{dc} T _j = 30°C	7.87 kW
EER T _j = 30°C	4.32
C _{dc}	1
P _{dc} T _j = 25°C	5.16 kW
EER T _j = 25°C	6.16
C _{dc}	1
P _{dc} T _j = 20°C	7.86 kW
EER T _j = 20°C	6.65
C _{dc}	1
P _{off}	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Q _{ce}	1260 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	130 %
Prated	11.00 kW	13.00 kW
SCOP	4.44	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.70 kW	11.50 kW
COP Tj = -7°C	3.07	2.25
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	6.30 kW	6.50 kW
COP Tj = +2°C	4.15	3.14
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.50 kW	4.60 kW
COP Tj = +7°C	5.86	4.27
Cdh Tj = +7 °C	0.95	0.96

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.30 kW	5.20 kW
COP Tj = 12°C	7.88	5.75
Cdh Tj = +12 °C	0.94	0.95
Pdh Tj = Tbiv	11.00 kW	12.50 kW
COP Tj = Tbiv	2.80	2.11
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.00 kW	12.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	2.11
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5112 kWh	7768 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	104 %
COP	2.51
Heating up time	0:57 h:min
Standby power input	32.8 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPGA11DV / EAVZ16S18D(6V/9W) + cooling kit

Configure model	
Model name	EPGA11DV / EAVZ16S18D(6V/9W) + cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.10 kW	15.84 kW
El input	2.16 kW	5.17 kW
COP	5.15	3.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	3.30 kW
Cooling capacity	10.66
EER	3.23

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	10.7 kW
SEER	5.1
P _{dc} T _j = 35°C	10.66 kW
EER T _j = 35°C	3.23
P _{dc} T _j = 30°C	7.87 kW
EER T _j = 30°C	4.32
C _{dc}	1
P _{dc} T _j = 25°C	5.16 kW
EER T _j = 25°C	6.16
C _{dc}	1
P _{dc} T _j = 20°C	7.86 kW
EER T _j = 20°C	6.65
C _{dc}	1
P _{off}	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Q _{ce}	1260 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	130 %
Prated	11.00 kW	13.00 kW
SCOP	4.44	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.70 kW	11.50 kW
COP Tj = -7°C	3.07	2.25
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	6.30 kW	6.50 kW
COP Tj = +2°C	4.15	3.14
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.50 kW	4.60 kW
COP Tj = +7°C	5.86	4.27
Cdh Tj = +7 °C	0.95	0.96

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.30 kW	5.20 kW
COP Tj = 12°C	7.88	5.75
Cdh Tj = +12 °C	0.94	0.95
Pdh Tj = Tbiv	11.00 kW	12.50 kW
COP Tj = Tbiv	2.80	2.11
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.00 kW	12.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	2.11
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5112 kWh	7768 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	104 %
COP	2.51
Heating up time	0:57 h:min
Standby power input	32.8 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPGA11DV / EAVH16SU18D6V

Configure model	
Model name	EPGA11DV / EAVH16SU18D6V
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.10 kW	15.84 kW
El input	2.16 kW	5.17 kW
COP	5.15	3.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	3.30 kW
Cooling capacity	10.66
EER	3.23

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	10.7 kW
SEER	5.1
P _{dc} T _j = 35°C	10.66 kW
EER T _j = 35°C	3.23
P _{dc} T _j = 30°C	7.87 kW
EER T _j = 30°C	4.32
C _{dc}	1
P _{dc} T _j = 25°C	5.16 kW
EER T _j = 25°C	6.16
C _{dc}	1
P _{dc} T _j = 20°C	7.86 kW
EER T _j = 20°C	6.65
C _{dc}	1
P _{off}	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Q _{ce}	1260 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	172 %	129 %
Prated	11.00 kW	13.00 kW
SCOP	4.38	3.29
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.70 kW	11.50 kW
COP Tj = -7°C	3.07	2.25
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	6.30 kW	6.50 kW
COP Tj = +2°C	4.15	3.14
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	4.50 kW	4.60 kW
COP Tj = +7°C	5.86	4.27
Cdh Tj = +7 °C	0.95	0.96

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.30 kW	5.20 kW
COP Tj = 12°C	7.88	5.75
Cdh Tj = +12 °C	0.94	0.95
Pdh Tj = Tbiv	11.00 kW	12.50 kW
COP Tj = Tbiv	2.80	2.11
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.00 kW	12.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	2.11
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5189 kWh	7845 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	104 %
COP	2.51
Heating up time	0:57 h:min
Standby power input	32.8 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPGA11DV7 / EABH16D(6V/9W)7

Configure model

Model name	EPGA11DV7 / EABH16D(6V/9W)7
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.10 kW	15.84 kW
El input	2.16 kW	5.17 kW
COP	5.15	3.06

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	3.30 kW
Cooling capacity	10.66
EER	3.23

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	10.7 kW
SEER	5.1
P _{dc} T _j = 35°C	10.66 kW
EER T _j = 35°C	3.23
P _{dc} T _j = 30°C	7.87 kW
EER T _j = 30°C	4.32
C _{dc}	1
P _{dc} T _j = 25°C	5.16 kW
EER T _j = 25°C	6.16
C _{dc}	1
P _{dc} T _j = 20°C	7.86 kW
EER T _j = 20°C	6.65
C _{dc}	1
P _{off}	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Q _{ce}	1260 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	172 %	129 %
Prated	11.00 kW	13.00 kW
SCOP	4.38	3.29
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.70 kW	11.50 kW
COP Tj = -7°C	3.07	2.25
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	6.30 kW	6.50 kW
COP Tj = +2°C	4.15	3.14
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.50 kW	4.60 kW
COP Tj = +7°C	5.86	4.27
Cdh Tj = +7 °C	0.95	0.96

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.30 kW	5.20 kW
COP Tj = 12°C	7.88	5.75
Cdh Tj = +12 °C	0.94	0.95
Pdh Tj = Tbiv	11.00 kW	12.50 kW
COP Tj = Tbiv	2.80	2.11
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.00 kW	12.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	2.11
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5189 kWh	7845 kWh

Model: EPGA11DV7 / EABX16D(6V/9W)7

Configure model

Model name	EPGA11DV7 / EABX16D(6V/9W)7
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.10 kW	15.84 kW
El input	2.16 kW	5.17 kW
COP	5.15	3.06

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	3.30 kW
Cooling capacity	10.66
EER	3.23

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	10.7 kW
SEER	5.1
P _{dc} T _j = 35°C	10.66 kW
EER T _j = 35°C	3.23
P _{dc} T _j = 30°C	7.87 kW
EER T _j = 30°C	4.32
C _{dc}	1
P _{dc} T _j = 25°C	5.16 kW
EER T _j = 25°C	6.16
C _{dc}	1
P _{dc} T _j = 20°C	7.86 kW
EER T _j = 20°C	6.65
C _{dc}	1
P _{off}	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Q _{ce}	1260 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	130 %
Prated	11.00 kW	13.00 kW
SCOP	4.44	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.70 kW	11.50 kW
COP Tj = -7°C	3.07	2.25
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	6.30 kW	6.50 kW
COP Tj = +2°C	4.15	3.14
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.50 kW	4.60 kW
COP Tj = +7°C	5.86	4.27
Cdh Tj = +7 °C	0.95	0.96

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.30 kW	5.20 kW
COP Tj = 12°C	7.88	5.75
Cdh Tj = +12 °C	0.94	0.95
Pdh Tj = Tbiv	11.00 kW	12.50 kW
COP Tj = Tbiv	2.80	2.11
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.00 kW	12.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	2.11
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5112 kWh	7768 kWh

Model: EPGA11DV7 / EAVH16S18D(6V/9W)7

Configure model

Model name	EPGA11DV7 / EAVH16S18D(6V/9W)7
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.10 kW	15.84 kW
El input	2.16 kW	5.17 kW
COP	5.15	3.06

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	3.30 kW
Cooling capacity	10.66
EER	3.23

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	10.7 kW
SEER	5.1
P _{dc} T _j = 35°C	10.66 kW
EER T _j = 35°C	3.23
P _{dc} T _j = 30°C	7.87 kW
EER T _j = 30°C	4.32
C _{dc}	1
P _{dc} T _j = 25°C	5.16 kW
EER T _j = 25°C	6.16
C _{dc}	1
P _{dc} T _j = 20°C	7.86 kW
EER T _j = 20°C	6.65
C _{dc}	1
P _{off}	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Q _{ce}	1260 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	172 %	129 %
Prated	11.00 kW	13.00 kW
SCOP	4.38	3.29
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.70 kW	11.50 kW
COP Tj = -7°C	3.07	2.25
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	6.30 kW	6.50 kW
COP Tj = +2°C	4.15	3.14
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.50 kW	4.60 kW
COP Tj = +7°C	5.86	4.27
Cdh Tj = +7 °C	0.95	0.96

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.30 kW	5.20 kW
COP Tj = 12°C	7.88	5.75
Cdh Tj = +12 °C	0.94	0.95
Pdh Tj = Tbiv	11.00 kW	12.50 kW
COP Tj = Tbiv	2.80	2.11
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.00 kW	12.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	2.11
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5189 kWh	7845 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	104 %
COP	2.51
Heating up time	0:57 h:min
Standby power input	32.8 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPGA11DV7 / EAVX16S18D(6V/9W)7

Configure model	
Model name	EPGA11DV7 / EAVX16S18D(6V/9W)7
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.10 kW	15.84 kW
El input	2.16 kW	5.17 kW
COP	5.15	3.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	3.30 kW
Cooling capacity	10.66
EER	3.23

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	10.7 kW
SEER	5.1
P _{dc} T _j = 35°C	10.66 kW
EER T _j = 35°C	3.23
P _{dc} T _j = 30°C	7.87 kW
EER T _j = 30°C	4.32
C _{dc}	1
P _{dc} T _j = 25°C	5.16 kW
EER T _j = 25°C	6.16
C _{dc}	1
P _{dc} T _j = 20°C	7.86 kW
EER T _j = 20°C	6.65
C _{dc}	1
P _{off}	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Q _{ce}	1260 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	130 %
Prated	11.00 kW	13.00 kW
SCOP	4.44	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.70 kW	11.50 kW
COP Tj = -7°C	3.07	2.25
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	6.30 kW	6.50 kW
COP Tj = +2°C	4.15	3.14
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.50 kW	4.60 kW
COP Tj = +7°C	5.86	4.27
Cdh Tj = +7 °C	0.95	0.96

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.30 kW	5.20 kW
COP Tj = 12°C	7.88	5.75
Cdh Tj = +12 °C	0.94	0.95
Pdh Tj = Tbiv	11.00 kW	12.50 kW
COP Tj = Tbiv	2.80	2.11
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.00 kW	12.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	2.11
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5112 kWh	7768 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	104 %
COP	2.51
Heating up time	0:57 h:min
Standby power input	32.8 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPGA11DV7 / EAVZ16S18D6V7

Configure model	
Model name	EPGA11DV7 / EAVZ16S18D6V7
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.10 kW	15.84 kW
El input	2.16 kW	5.17 kW
COP	5.15	3.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	3.30 kW
Cooling capacity	10.66
EER	3.23

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	10.7 kW
SEER	5.1
P _{dc} T _j = 35°C	10.66 kW
EER T _j = 35°C	3.23
P _{dc} T _j = 30°C	7.87 kW
EER T _j = 30°C	4.32
C _{dc}	1
P _{dc} T _j = 25°C	5.16 kW
EER T _j = 25°C	6.16
C _{dc}	1
P _{dc} T _j = 20°C	7.86 kW
EER T _j = 20°C	6.65
C _{dc}	1
P _{off}	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Q _{ce}	1260 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	172 %	129 %
Prated	11.00 kW	13.00 kW
SCOP	4.38	3.29
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.70 kW	11.50 kW
COP Tj = -7°C	3.07	2.25
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	6.30 kW	6.50 kW
COP Tj = +2°C	4.15	3.14
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.50 kW	4.60 kW
COP Tj = +7°C	5.86	4.27
Cdh Tj = +7 °C	0.95	0.96

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.30 kW	5.20 kW
COP Tj = 12°C	7.88	5.75
Cdh Tj = +12 °C	0.94	0.95
Pdh Tj = Tbiv	11.00 kW	12.50 kW
COP Tj = Tbiv	2.80	2.11
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.00 kW	12.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	2.11
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5189 kWh	7845 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	104 %
COP	2.51
Heating up time	0:57 h:min
Standby power input	32.8 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPGA11DV7 / EABH16D(6V/9W)7 + cooling kit

Configure model	
Model name	EPGA11DV7 / EABH16D(6V/9W)7 + cooling kit
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.10 kW	15.84 kW
El input	2.16 kW	5.17 kW
COP	5.15	3.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	3.30 kW
Cooling capacity	10.66
EER	3.23

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	10.7 kW
SEER	5.1
P _{dc} T _j = 35°C	10.66 kW
EER T _j = 35°C	3.23
P _{dc} T _j = 30°C	7.87 kW
EER T _j = 30°C	4.32
C _{dc}	1
P _{dc} T _j = 25°C	5.16 kW
EER T _j = 25°C	6.16
C _{dc}	1
P _{dc} T _j = 20°C	7.86 kW
EER T _j = 20°C	6.65
C _{dc}	1
P _{off}	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Q _{ce}	1260 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	130 %
Prated	11.00 kW	13.00 kW
SCOP	4.44	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.70 kW	11.50 kW
COP Tj = -7°C	3.07	2.25
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	6.30 kW	6.50 kW
COP Tj = +2°C	4.15	3.14
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.50 kW	4.60 kW
COP Tj = +7°C	5.86	4.27
Cdh Tj = +7 °C	0.95	0.96

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.30 kW	5.20 kW
COP Tj = 12°C	7.88	5.75
Cdh Tj = +12 °C	0.94	0.95
Pdh Tj = Tbiv	11.00 kW	12.50 kW
COP Tj = Tbiv	2.80	2.11
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.00 kW	12.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	2.11
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5112 kWh	7768 kWh

Model: EPGA11DV7 / EAVH16S18D(6V/9W)7 + cooling kit

Configure model	
Model name	EPGA11DV7 / EAVH16S18D(6V/9W)7 + cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.10 kW	15.84 kW
El input	2.16 kW	5.17 kW
COP	5.15	3.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	3.30 kW
Cooling capacity	10.66
EER	3.23

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	10.7 kW
SEER	5.1
P _{dc} T _j = 35°C	10.66 kW
EER T _j = 35°C	3.23
P _{dc} T _j = 30°C	7.87 kW
EER T _j = 30°C	4.32
C _{dc}	1
P _{dc} T _j = 25°C	5.16 kW
EER T _j = 25°C	6.16
C _{dc}	1
P _{dc} T _j = 20°C	7.86 kW
EER T _j = 20°C	6.65
C _{dc}	1
P _{off}	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Q _{ce}	1260 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	130 %
Prated	11.00 kW	13.00 kW
SCOP	4.44	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.70 kW	11.50 kW
COP Tj = -7°C	3.07	2.25
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	6.30 kW	6.50 kW
COP Tj = +2°C	4.15	3.14
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.50 kW	4.60 kW
COP Tj = +7°C	5.86	4.27
Cdh Tj = +7 °C	0.95	0.96

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.30 kW	5.20 kW
COP Tj = 12°C	7.88	5.75
Cdh Tj = +12 °C	0.94	0.95
Pdh Tj = Tbiv	11.00 kW	12.50 kW
COP Tj = Tbiv	2.80	2.11
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.00 kW	12.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	2.11
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5112 kWh	7768 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	104 %
COP	2.51
Heating up time	0:57 h:min
Standby power input	32.8 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPGA11DV7 / EAVZ16S18D6V7 + cooling kit

Configure model	
Model name	EPGA11DV7 / EAVZ16S18D6V7 + cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	11.10 kW	15.84 kW
El input	2.16 kW	5.17 kW
COP	5.15	3.06

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	3.30 kW
Cooling capacity	10.66
EER	3.23

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	10.7 kW
SEER	5.1
P _{dc} T _j = 35°C	10.66 kW
EER T _j = 35°C	3.23
P _{dc} T _j = 30°C	7.87 kW
EER T _j = 30°C	4.32
C _{dc}	1
P _{dc} T _j = 25°C	5.16 kW
EER T _j = 25°C	6.16
C _{dc}	1
P _{dc} T _j = 20°C	7.86 kW
EER T _j = 20°C	6.65
C _{dc}	1
P _{off}	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Q _{ce}	1260 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	175 %	130 %
Prated	11.00 kW	13.00 kW
SCOP	4.44	3.32
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.70 kW	11.50 kW
COP Tj = -7°C	3.07	2.25
Cdh Tj = -7 °C	1.00	1.00
Pdh Tj = +2°C	6.30 kW	6.50 kW
COP Tj = +2°C	4.15	3.14
Cdh Tj = +2 °C	1.00	1.00
Pdh Tj = +7°C	4.50 kW	4.60 kW
COP Tj = +7°C	5.86	4.27
Cdh Tj = +7 °C	0.95	0.96

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.30 kW	5.20 kW
COP Tj = 12°C	7.88	5.75
Cdh Tj = +12 °C	0.94	0.95
Pdh Tj = Tbiv	11.00 kW	12.50 kW
COP Tj = Tbiv	2.80	2.11
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.00 kW	12.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	2.11
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5112 kWh	7768 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	104 %
COP	2.51
Heating up time	0:57 h:min
Standby power input	32.8 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPGA11DV7 / EAVH16SU18D6V7

Configure model

Model name	EPGA11DV7 / EAVH16SU18D6V7
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	11.10 kW	15.84 kW
El input	2.16 kW	5.17 kW
COP	5.15	3.06

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	3.30 kW
Cooling capacity	10.66
EER	3.23

EN 14825

This information was generated by the HP KEYMARK database on 18 Mar 2022

	+7°C/+12°C
P _{designc}	10.7 kW
SEER	5.1
P _{dc} T _j = 35°C	10.66 kW
EER T _j = 35°C	3.23
P _{dc} T _j = 30°C	7.87 kW
EER T _j = 30°C	4.32
C _{dc}	1
P _{dc} T _j = 25°C	5.16 kW
EER T _j = 25°C	6.16
C _{dc}	1
P _{dc} T _j = 20°C	7.86 kW
EER T _j = 20°C	6.65
C _{dc}	1
P _{off}	21 W
PTO	41 W
PSB	21 W
PCK	0 W
Annual energy consumption Q _{ce}	1260 kWh

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	44 dB(A)	44 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	172 %	129 %
Prated	11.00 kW	13.00 kW
SCOP	4.38	3.29
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	9.70 kW	11.50 kW
COP Tj = -7°C	3.07	2.25
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	6.30 kW	6.50 kW
COP Tj = +2°C	4.15	3.14
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	4.50 kW	4.60 kW
COP Tj = +7°C	5.86	4.27
Cdh Tj = +7 °C	0.95	0.96

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	5.30 kW	5.20 kW
COP Tj = 12°C	7.88	5.75
Cdh Tj = +12 °C	0.94	0.95
Pdh Tj = Tbiv	11.00 kW	12.50 kW
COP Tj = Tbiv	2.80	2.11
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.00 kW	12.50 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	2.11
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	41 W	41 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	5189 kWh	7845 kWh

Domestic Hot Water (DHW)

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	104 %
COP	2.51
Heating up time	0:57 h:min
Standby power input	32.8 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l