

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	DAIKIN ALTHERMA 3 R F 8KW (180L) /A		Reg. No.	011-1W0251
Certificate Holder				
Name	DAIKIN Europe N.V.			
Address	Zandvoordestraat 300		Zip	B-8400
City	Oostende		Country	Belgium
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH			
Name of testing laboratory	Danish Technological Institute			
Subtype title	DAIKIN ALTHERMA 3 R F 8KW (180L) /A			
Heat Pump Type	Outdoor Air/Water			
Refrigerant	R32			
Mass Of Refrigerant	1.5 kg			
Certification Date	27.03.2018			
Testing basis	HP KEYMARK certification scheme rules rev. 7			

## Model: ERGA08DVA / EHVH08S18D6V(G)

### General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

### EN 14511-2

	Low temperature	Medium temperature
Heat output	7.50 kW	7.50 kW
El input	1.63 kW	2.78 kW
COP	4.60	2.70
Indoor water flow rate	1.29 m <sup>3</sup> /h	0.92 m <sup>3</sup> /h

## Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	179 %	128 %
Prated	8.00 kW	7.50 kW
SCOP	4.56	3.27
Tbiv	-8 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.00 kW	5.90 kW
COP Tj = -7°C	2.77	1.98
Cdh		1.00
Pdh Tj = +2°C	4.20 kW	4.10 kW
COP Tj = +2°C	4.35	3.18
Cdh	1.00	1.00
Pdh Tj = +7°C	3.30 kW	3.00 kW
COP Tj = +7°C	6.49	4.54
Cdh	1.00	1.00

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	3.90 kW	3.70 kW
COP Tj = 12°C	8.52	6.16
Cdh	1.00	1.00
Pdh Tj = Tbiv	7.50 kW	6.40 kW
COP Tj = Tbiv	2.66	2.18
Pdh Tj = TOL	6.90 kW	4.50 kW
COP Tj = TOL	2.41	1.43
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	1.00 kW	3.00 kW
Annual energy consumption Qhe	3625 kWh	4731 kWh

## Domestic Hot Water (DHW)

### Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

<b>EN 16147</b>	
Declared load profile	L
Efficiency $\eta_{DHW}$	125 %
COP	3.10
Heating up time	1:34 h:min
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	238 l

# Model: ERGA08DVA / EHVH08S18D9W(G)

## General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

### EN 14511-2

	Low temperature	Medium temperature
Heat output	7.50 kW	7.50 kW
El input	1.63 kW	2.78 kW
COP	4.60	2.70
Indoor water flow rate	1.29 m <sup>3</sup> /h	0.92 m <sup>3</sup> /h

## Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	179 %	128 %
Prated	8.00 kW	7.50 kW
SCOP	4.56	3.27
Tbiv	-8 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.00 kW	5.90 kW
COP Tj = -7°C	2.77	1.98
Cdh		1.00
Pdh Tj = +2°C	4.20 kW	4.10 kW
COP Tj = +2°C	4.35	3.18
Cdh	1.00	1.00
Pdh Tj = +7°C	3.30 kW	3.00 kW
COP Tj = +7°C	6.49	4.54
Cdh	1.00	1.00

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	3.90 kW	3.70 kW
COP Tj = 12°C	8.52	6.16
Cdh	1.00	1.00
Pdh Tj = Tbiv	7.50 kW	6.40 kW
COP Tj = Tbiv	2.66	2.18
Pdh Tj = TOL	6.90 kW	4.50 kW
COP Tj = TOL	2.41	1.43
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	1.00 kW	3.00 kW
Annual energy consumption Qhe	3625 kWh	4731 kWh

## Domestic Hot Water (DHW)

### Average Climate



This information was generated by the HP KEYMARK database on 17 Dec 2020

<b>EN 16147</b>	
Declared load profile	L
Efficiency $\eta_{DHW}$	125 %
COP	3.10
Heating up time	1:34 h:min
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	238 l

## Model: ERGA08DVA / EHVX08S18D6V(G)

### General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

### EN 14511-2

	Low temperature	Medium temperature
Heat output	7.50 kW	7.50 kW
El input	1.63 kW	2.78 kW
COP	4.60	2.70
Indoor water flow rate	1.29 m <sup>3</sup> /h	0.92 m <sup>3</sup> /h

## Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	181 %	129 %
Prated	8.00 kW	7.50 kW
SCOP	4.61	3.30
Tbiv	-8 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.00 kW	5.90 kW
COP Tj = -7°C	2.77	1.98
Cdh		1.00
Pdh Tj = +2°C	4.20 kW	4.10 kW
COP Tj = +2°C	4.35	3.18
Cdh	1.00	1.00
Pdh Tj = +7°C	3.30 kW	3.00 kW
COP Tj = +7°C	6.49	4.54
Cdh	1.00	1.00

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	3.90 kW	3.70 kW
COP Tj = 12°C	8.52	6.16
Cdh	1.00	1.00
Pdh Tj = Tbiv	7.50 kW	6.40 kW
COP Tj = Tbiv	2.66	2.18
Pdh Tj = TOL	6.90 kW	4.50 kW
COP Tj = TOL	2.41	1.43
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	1.00 kW	3.00 kW
Annual energy consumption Qhe	3588 kWh	4694 kWh

## Cooling

This information was generated by the HP KEYMARK database on 17 Dec 2020

**EN 14511-2**

	<b>+7°C/+12°C</b>
El input	1.73 kW
Indoor water flow rate	0.94 m³/h
Cooling capacity	5.44
EER	3.14

**EN 14825**

This information was generated by the HP KEYMARK database on 17 Dec 2020

	<b>+7°C/+12°C</b>
P <sub>designc</sub>	5.40 kW
SEER	5.71
P <sub>dc</sub> T <sub>j</sub> = 35°C	5.44 kW
EER T <sub>j</sub> = 35°C	3.14
P <sub>dc</sub> T <sub>j</sub> = 30°C	4.02 kW
EER T <sub>j</sub> = 30°C	4.84
C <sub>dc</sub>	1.0
P <sub>dc</sub> T <sub>j</sub> = 25°C	2.47 kW
EER T <sub>j</sub> = 25°C	6.86
C <sub>dc</sub>	1.0
P <sub>dc</sub> T <sub>j</sub> = 20°C	2.54 kW
EER T <sub>j</sub> = 20°C	8.47
C <sub>dc</sub>	1.0
P <sub>off</sub>	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Q <sub>ce</sub>	571 kWh

## Domestic Hot Water (DHW)

### Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

<b>EN 16147</b>	
Declared load profile	L
Efficiency $\eta_{DHW}$	125 %
COP	3.10
Heating up time	1:34 h:min
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	238 l

# Model: ERGA08DVA / EHVX08S18D9W(G)

## General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

### EN 14511-2

	Low temperature	Medium temperature
Heat output	7.50 kW	7.50 kW
El input	1.63 kW	2.78 kW
COP	4.60	2.70
Indoor water flow rate	1.29 m <sup>3</sup> /h	0.92 m <sup>3</sup> /h

## Average Climate



This information was generated by the HP KEYMARK database on 17 Dec 2020

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	181 %	129 %
Prated	8.00 kW	7.50 kW
SCOP	4.61	3.30
Tbiv	-8 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.00 kW	5.90 kW
COP Tj = -7°C	2.77	1.98
Cdh		1.00
Pdh Tj = +2°C	4.20 kW	4.10 kW
COP Tj = +2°C	4.35	3.18
Cdh	1.00	1.00
Pdh Tj = +7°C	3.30 kW	3.00 kW
COP Tj = +7°C	6.49	4.54
Cdh	1.00	1.00

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	3.90 kW	3.70 kW
COP Tj = 12°C	8.52	6.16
Cdh	1.00	1.00
Pdh Tj = Tbiv	7.50 kW	7.50 kW
COP Tj = Tbiv	2.66	1.90
Pdh Tj = TOL	6.90 kW	4.50 kW
COP Tj = TOL	2.41	1.43
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	1.00 kW	3.00 kW
Annual energy consumption Qhe	3588 kWh	4694 kWh

## Domestic Hot Water (DHW)

### Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

<b>EN 16147</b>	
Declared load profile	L
Efficiency $\eta_{DHW}$	125 %
COP	3.10
Heating up time	1:34 h:min
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	238 l

## Model: ERGA08EVA / EHVX08S18E6V(G)

### General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

### EN 14511-2

	Low temperature	Medium temperature
Heat output	7.50 kW	7.50 kW
El input	1.63 kW	2.78 kW
COP	4.60	2.70
Indoor water flow rate	1.29 m <sup>3</sup> /h	0.92 m <sup>3</sup> /h

## Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	181 %	129 %
Prated	8.00 kW	7.50 kW
SCOP	4.61	3.30
Tbiv	-8 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.00 kW	5.90 kW
COP Tj = -7°C	2.77	1.98
Cdh		1.00
Pdh Tj = +2°C	4.20 kW	4.10 kW
COP Tj = +2°C	4.35	3.18
Cdh	1.00	1.00
Pdh Tj = +7°C	3.30 kW	3.00 kW
COP Tj = +7°C	6.49	4.54
Cdh	1.00	1.00

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	3.90 kW	3.70 kW
COP Tj = 12°C	8.52	6.16
Cdh	1.00	1.00
Pdh Tj = Tbiv	7.50 kW	6.40 kW
COP Tj = Tbiv	2.66	2.18
Pdh Tj = TOL	6.90 kW	4.50 kW
COP Tj = TOL	2.41	1.43
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	1.00 kW	3.00 kW
Annual energy consumption Qhe	3588 kWh	4694 kWh

## Cooling

This information was generated by the HP KEYMARK database on 17 Dec 2020

### EN 14511-2

	<b>+7°C/+12°C</b>
El input	1.73 kW
Indoor water flow rate	0.94 m³/h
Cooling capacity	5.44
EER	3.14

### EN 14825

This information was generated by the HP KEYMARK database on 17 Dec 2020

	<b>+7°C/+12°C</b>
P <sub>designc</sub>	5.40 kW
SEER	5.71
P <sub>dc</sub> T <sub>j</sub> = 35°C	5.44 kW
EER T <sub>j</sub> = 35°C	3.14
P <sub>dc</sub> T <sub>j</sub> = 30°C	4.02 kW
EER T <sub>j</sub> = 30°C	4.84
C <sub>dc</sub>	1.0
P <sub>dc</sub> T <sub>j</sub> = 25°C	2.47 kW
EER T <sub>j</sub> = 25°C	6.86
C <sub>dc</sub>	1.0
P <sub>dc</sub> T <sub>j</sub> = 20°C	2.54 kW
EER T <sub>j</sub> = 20°C	8.47
C <sub>dc</sub>	1.0
P <sub>off</sub>	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Q <sub>ce</sub>	571 kWh

## Domestic Hot Water (DHW)

### Average Climate



This information was generated by the HP KEYMARK database on 17 Dec 2020

<b>EN 16147</b>	
Declared load profile	L
Efficiency $\eta_{DHW}$	125 %
COP	3.10
Heating up time	1:34 h:min
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	238 l

## Model: ERGA08EVA / EHVX08S18E9W

### General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

### EN 14511-2

	Low temperature	Medium temperature
Heat output	7.50 kW	7.50 kW
El input	1.63 kW	2.78 kW
COP	4.60	2.70
Indoor water flow rate	1.29 m <sup>3</sup> /h	0.92 m <sup>3</sup> /h

## Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	181 %	129 %
Prated	8.00 kW	7.50 kW
SCOP	4.61	3.30
Tbiv	-8 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.00 kW	5.90 kW
COP Tj = -7°C	2.77	1.98
Cdh		1.00
Pdh Tj = +2°C	4.20 kW	4.10 kW
COP Tj = +2°C	4.35	3.18
Cdh	1.00	1.00
Pdh Tj = +7°C	3.30 kW	3.00 kW
COP Tj = +7°C	6.49	4.54
Cdh	1.00	1.00

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	3.90 kW	3.70 kW
COP Tj = 12°C	8.52	6.16
Cdh	1.00	1.00
Pdh Tj = Tbiv	7.50 kW	6.40 kW
COP Tj = Tbiv	2.66	2.18
Pdh Tj = TOL	6.90 kW	4.50 kW
COP Tj = TOL	2.41	1.43
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	1.00 kW	3.00 kW
Annual energy consumption Qhe	3588 kWh	4694 kWh

## Cooling

This information was generated by the HP KEYMARK database on 17 Dec 2020

**EN 14511-2**

	<b>+7°C/+12°C</b>
El input	1.73 kW
Indoor water flow rate	0.94 m³/h
Cooling capacity	5.44
EER	3.14

**EN 14825**

This information was generated by the HP KEYMARK database on 17 Dec 2020

	<b>+7°C/+12°C</b>
P <sub>designc</sub>	5.40 kW
SEER	5.71
P <sub>dc</sub> T <sub>j</sub> = 35°C	5.44 kW
EER T <sub>j</sub> = 35°C	3.14
P <sub>dc</sub> T <sub>j</sub> = 30°C	4.02 kW
EER T <sub>j</sub> = 30°C	4.84
C <sub>dc</sub>	1.0
P <sub>dc</sub> T <sub>j</sub> = 25°C	2.47 kW
EER T <sub>j</sub> = 25°C	6.86
C <sub>dc</sub>	1.0
P <sub>dc</sub> T <sub>j</sub> = 20°C	2.54 kW
EER T <sub>j</sub> = 20°C	8.47
C <sub>dc</sub>	1.0
P <sub>off</sub>	10 W
PTO	10 W
PSB	10 W
PCK	0 W
Annual energy consumption Q <sub>ce</sub>	571 kWh

## Domestic Hot Water (DHW)

### Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

<b>EN 16147</b>	
Declared load profile	L
Efficiency $\eta_{DHW}$	125 %
COP	3.10
Heating up time	1:34 h:min
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	238 l

## Model: ERGA08EVA / EHVH08S18E6V

### General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

### EN 14511-2

	Low temperature	Medium temperature
Heat output	7.50 kW	7.50 kW
El input	1.63 kW	2.78 kW
COP	4.60	2.70
Indoor water flow rate	1.29 m <sup>3</sup> /h	0.92 m <sup>3</sup> /h

## Average Climate



This information was generated by the HP KEYMARK database on 17 Dec 2020

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	179 %	128 %
Prated	8.00 kW	7.50 kW
SCOP	4.56	3.27
Tbiv	-8 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.00 kW	5.90 kW
COP Tj = -7°C	2.77	1.98
Cdh		1.00
Pdh Tj = +2°C	4.20 kW	4.10 kW
COP Tj = +2°C	4.35	3.18
Cdh	1.00	1.00
Pdh Tj = +7°C	3.30 kW	3.00 kW
COP Tj = +7°C	6.49	4.54
Cdh	1.00	1.00

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	3.90 kW	3.70 kW
COP Tj = 12°C	8.52	6.16
Cdh	1.00	1.00
Pdh Tj = Tbiv	7.50 kW	6.40 kW
COP Tj = Tbiv	2.66	2.18
Pdh Tj = TOL	6.90 kW	4.50 kW
COP Tj = TOL	2.41	1.43
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	1.00 kW	3.00 kW
Annual energy consumption Qhe	3625 kWh	4731 kWh

## Domestic Hot Water (DHW)

### Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

<b>EN 16147</b>	
Declared load profile	L
Efficiency $\eta_{DHW}$	125 %
COP	3.10
Heating up time	1:34 h:min
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	238 l

# Model: ERGA08EVA / EHVH08S18E9W

## General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

### EN 14511-2

	Low temperature	Medium temperature
Heat output	7.50 kW	7.50 kW
El input	1.63 kW	2.78 kW
COP	4.60	2.70
Indoor water flow rate	1.29 m <sup>3</sup> /h	0.92 m <sup>3</sup> /h

## Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	179 %	128 %
Prated	8.00 kW	7.50 kW
SCOP	4.56	3.27
Tbiv	-8 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.00 kW	5.90 kW
COP Tj = -7°C	2.77	1.98
Cdh		1.00
Pdh Tj = +2°C	4.20 kW	4.10 kW
COP Tj = +2°C	4.35	3.18
Cdh	1.00	1.00
Pdh Tj = +7°C	3.30 kW	3.00 kW
COP Tj = +7°C	6.49	4.54
Cdh	1.00	1.00

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	3.90 kW	3.70 kW
COP Tj = 12°C	8.52	6.16
Cdh	1.00	1.00
Pdh Tj = Tbiv	7.50 kW	6.40 kW
COP Tj = Tbiv	2.66	2.18
Pdh Tj = TOL	6.90 kW	4.50 kW
COP Tj = TOL	2.41	1.43
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	1.00 kW	3.00 kW
Annual energy consumption Qhe	3625 kWh	4731 kWh

## Domestic Hot Water (DHW)

### Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

<b>EN 16147</b>	
Declared load profile	L
Efficiency $\eta_{DHW}$	125 %
COP	3.10
Heating up time	1:34 h:min
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	238 l

## Model: ERGA08EVA / EHVH08SU18E6V

### General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

### EN 14511-2

	Low temperature	Medium temperature
Heat output	7.50 kW	7.50 kW
El input	1.63 kW	2.78 kW
COP	4.60	2.70
Indoor water flow rate	1.29 m <sup>3</sup> /h	0.92 m <sup>3</sup> /h

## Average Climate



This information was generated by the HP KEYMARK database on 17 Dec 2020

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	42 dB(A)	42 dB(A)
Sound power level outdoor	62 dB(A)	62 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	179 %	128 %
Prated	8.00 kW	7.50 kW
SCOP	4.56	3.27
Tbiv	-8 °C	-6 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.00 kW	5.90 kW
COP Tj = -7°C	2.77	1.98
Cdh		1.00
Pdh Tj = +2°C	4.20 kW	4.10 kW
COP Tj = +2°C	4.35	3.18
Cdh	1.00	1.00
Pdh Tj = +7°C	3.30 kW	3.00 kW
COP Tj = +7°C	6.49	4.54
Cdh	1.00	1.00

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = 12°C	3.90 kW	3.70 kW
COP Tj = 12°C	8.52	6.16
Cdh	1.00	1.00
Pdh Tj = Tbiv	7.50 kW	6.40 kW
COP Tj = Tbiv	2.66	2.18
Pdh Tj = TOL	6.90 kW	4.50 kW
COP Tj = TOL	2.41	1.43
Cdh	1.00	1.00
WTOL	35 °C	55 °C
Poff	10 W	10 W
PTO	10 W	10 W
PSB	10 W	10 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electrical	Electrical
Supplementary Heater: PSUP	1.00 kW	3.00 kW
Annual energy consumption Qhe	3625 kWh	4731 kWh

## Domestic Hot Water (DHW)

### Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

<b>EN 16147</b>	
Declared load profile	L
Efficiency $\eta_{DHW}$	125 %
COP	3.10
Heating up time	1:34 h:min
Standby power input	28.0 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	238 l