

This information was generated by the HP KEYMARK database on 23 Jun 2022

[Login](#)

Summary of	Acond PRO-R	Reg. No.	037-0076-22
Certificate Holder			
Name	Acond a.s.		
Address	Štěrboholská 1434/102a	Zip	102 00
City	Hostivař, Praha	Country	Czech Republic
Certification Body	SZU - Strojirensky zkusebni ustav (Engineering Test Institute, Public Enterprise)		
Subtype title	Acond PRO-R		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R290		
Mass of Refrigerant	2.75 kg		
Certification Date	17.03.2022		
Testing basis	HP Keymark scheme rules rev. no. 9		

## Model: Acond PRO-R SP

### Configure model

Model name	Acond PRO-R SP
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

### General Data

Power supply	1x230V 50Hz
--------------	-------------

## Heating

### EN 14511-2

	Low temperature	Medium temperature
Heat output	6.77 kW	7.41 kW
El input	1.30 kW	2.25 kW
COP	5.22	3.29

### EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

## Average Climate

This information was generated by the HP KEYMARK database on 23 Jun 2022

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	0 dB(A)
Sound power level outdoor	dB(A)	49 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	199 %	154 %
Prated	10.38 kW	10.17 kW
SCOP	5.05	3.93
Tbiv	-10 °C	-10 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	9.23 kW	9.00 kW
COP Tj = -7°C	3.24	2.50
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.46 kW	5.53 kW
COP Tj = +2°C	5.03	3.87
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.81 kW	3.52 kW
COP Tj = +7°C	6.33	4.97
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	4.05 kW	3.88 kW
COP Tj = 12°C	7.42	6.14
Cdh Tj = +12 °C	0.970	0.970
Pdh Tj = Tbiv	10.38 kW	10.17 kW
COP Tj = Tbiv	2.76	2.08
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.38 kW	10.17 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	2.08
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	70 °C	70 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	4246 kWh	5351 kWh

## Model: Acond PRO-R

Configure model	
Model name	Acond PRO-R
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

### Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.77 kW	7.41 kW
El input	1.30 kW	2.25 kW
COP	5.22	3.29

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

### Average Climate

This information was generated by the HP KEYMARK database on 23 Jun 2022

### EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	dB(A)	0 dB(A)
Sound power level outdoor	dB(A)	49 dB(A)

### EN 14825

	Low temperature	Medium temperature
$\eta_s$	199 %	154 %
Prated	10.38 kW	10.17 kW
SCOP	5.05	3.93
Tbiv	-10 °C	-10 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	9.23 kW	9.00 kW
COP Tj = -7°C	3.24	2.50
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	5.46 kW	5.53 kW
COP Tj = +2°C	5.03	3.87
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	3.81 kW	3.52 kW
COP Tj = +7°C	6.33	4.97
Cdh Tj = +7 °C	0.900	0.900

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	4.05 kW	3.88 kW
COP Tj = 12°C	7.42	6.14
Cdh Tj = +12 °C	0.970	0.970
Pdh Tj = Tbiv	10.38 kW	10.17 kW
COP Tj = Tbiv	2.76	2.08
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.38 kW	10.17 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.76	2.08
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	70 °C	70 °C
Poff	16 W	16 W
PTO	16 W	16 W
PSB	16 W	16 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	4246 kWh	5351 kWh