Login

Summary of	Bosch Compress 7800i LW 6 and 8	Reg. No.	011-1W0431
Certificate Holder			
Name	Bosch Thermotechnik GmbH		
Address	Junkersstraße 20 - 24	Zip	73249
City	Wernau	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	Bosch Compress 7800i LW 6 and 8		
Heat Pump Type	Brine/Water		
Refrigerant	R410A		
Mass of Refrigerant	1.35 kg		
Certification Date	08.12.2020		
Testing basis	HP KEYMARK certification scheme rules rev. 7		

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: CS7800iLW 6 M (+MF)

Configure model	
Model name	CS7800iLW 6 M (+MF)
Application	Heating + DHW + low temp
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz
Off-peak product	No

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	5.85 kW	5.23 kW
El input	1.34 kW	1.90 kW
COP	4.36	2.76

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	35 dB(A)	35 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	211 %	147 %
Prated	6.00 kW	5.00 kW
SCOP	5.47	3.87
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.17 kW	4.63 kW
COP Tj = -7°C	4.70	3.01
Pdh Tj = +2°C	3.15 kW	2.82 kW
COP Tj = +2°C	5.56	3.91
Pdh Tj = +7°C	2.02 kW	1.81 kW
COP Tj = +7°C	6.20	4.59
Pdh Tj = 12°C	2.12 kW	1.97 kW
COP Tj = 12°C	6.09	4.63
Pdh Tj = Tbiv	5.85 kW	5.23 kW
COP Tj = Tbiv	4.36	2.76

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.85 kW	5.23 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.36	2.76
WTOL	67 °C	67 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Qhe	2166 kWh	2749 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	35 dB(A)	35 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	222 %	154 %
Prated	6.00 kW	5.00 kW
SCOP	5.76	4.04

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	3.60 kW	3.17 kW
COP Tj = -7°C	5.57	3.75
Pdh Tj = +2°C	2.15 kW	1.93 kW
COP Tj = +2°C	6.25	4.44
Pdh Tj = +7°C	2.13 kW	1.98 kW
COP Tj = +7°C	6.29	4.77
Pdh Tj = 12°C	2.11 kW	2.00 kW
COP Tj = 12°C	5.95	5.04
Pdh Tj = Tbiv	5.85 kW	5.23 kW
COP Tj = Tbiv	4.36	2.76
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.85 kW	5.23 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.36	2.76
WTOL	67 °C	67 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Annual energy consumption Qhe	2477 kWh	3165 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	35 dB(A)	35 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	206 %	143 %
Prated	6.00 kW	5.00 kW
SCOP	5.35	3.77
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.85 kW	5.23 kW
COP Tj = +2°C	4.36	2.76
Pdh Tj = +7°C	3.76 kW	3.36 kW
COP Tj = +7°C	5.24	3.54
Pdh Tj = 12°C	2.12 kW	1.97 kW
COP Tj = 12°C	6.14	4.49
Pdh Tj = Tbiv	5.85 kW	5.23 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = Tbiv	4.36	2.76
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.85 kW	5.23 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.36	2.76
WTOL	67 °C	67 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Qhe	1402 kWh	1793 kWh

Domestic Hot Water (DHW)

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 16147	
Declared load profile	XL
Efficiency ηDHW	135 %
COP	3.27
Heating up time	01:34 h:min
Standby power input	30.9 W
Reference hot water temperature	47.6 °C
Mixed water at 40°C	211 l

Colder Climate

EN 16147	
Declared load profile	XL
Efficiency ηDHW	135 %
COP	3.27
Heating up time	01:34 h:min
Standby power input	30.9 W
Reference hot water temperature	47.6 °C
Mixed water at 40°C	211 l

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 16147

Declared load profile	XL
Efficiency ηDHW	135 %
COP	3.27
Heating up time	01:34 h:min
Standby power input	30.9 W
Reference hot water temperature	47.6 °C
Mixed water at 40°C	211 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: CS7800iLW 6 (+F)

Configure model	
Model name	CS7800iLW 6 (+F)
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	5.85 kW	5.23 kW
El input	1.34 kW	1.90 kW
COP	4.36	2.76

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	35 dB(A)	35 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	211 %	147 %
Prated	6.00 kW	5.00 kW
SCOP	5.47	3.87
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.17 kW	4.63 kW
COP Tj = -7°C	4.70	3.01
Pdh Tj = +2°C	3.15 kW	2.82 kW
COP Tj = +2°C	5.56	3.91
Pdh Tj = +7°C	2.02 kW	1.81 kW
COP Tj = +7°C	6.20	4.59
Pdh Tj = 12°C	2.12 kW	1.97 kW
COP Tj = 12°C	6.09	4.63
Pdh Tj = Tbiv	5.85 kW	5.23 kW
COP Tj = Tbiv	4.36	2.76

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.85 kW	5.23 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.36	2.76
WTOL	67 °C	67 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Qhe	2166 kWh	2749 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	35 dB(A)	35 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	222 %	154 %
Prated	6.00 kW	5.00 kW
SCOP	5.76	4.04

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	3.60 kW	3.17 kW
COP Tj = -7°C	5.57	3.75
Pdh Tj = +2°C	2.15 kW	1.93 kW
COP Tj = +2°C	6.25	4.44
Pdh Tj = +7°C	2.13 kW	1.98 kW
COP Tj = +7°C	6.29	4.77
Pdh Tj = 12°C	2.11 kW	2.00 kW
COP Tj = 12°C	5.95	5.04
Pdh Tj = Tbiv	5.85 kW	5.23 kW
COP Tj = Tbiv	4.36	2.76
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.85 kW	5.23 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.36	2.76
WTOL	67 °C	67 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Annual energy consumption Qhe	2477 kWh	3165 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	35 dB(A)	35 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	206 %	143 %
Prated	6.00 kW	5.00 kW
SCOP	5.35	3.77
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.85 kW	5.23 kW
COP Tj = +2°C	4.36	2.76
Pdh Tj = +7°C	3.76 kW	3.36 kW
COP Tj = +7°C	5.24	3.54
Pdh Tj = 12°C	2.12 kW	1.97 kW
COP Tj = 12°C	6.14	4.49
Pdh Tj = Tbiv	5.85 kW	5.23 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = Tbiv	4.36	2.76
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.85 kW	5.23 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.36	2.76
WTOL	67 °C	67 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Qhe	1402 kWh	1793 kWh

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: CS7800iLW 8 M (+MF)

Configure model	
Model name	CS7800iLW 8 M (+MF)
Application	Heating + DHW + low temp
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz
Off-peak product	No

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	7.61 kW	6.73 kW
El input	1.85 kW	2.56 kW
COP	4.11	2.63

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	36 dB(A)	36 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	207 %	152 %
Prated	7.61 kW	6.73 kW
SCOP	5.38	3.99
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.04 kW	5.86 kW
COP Tj = -7°C	4.33	2.95
Pdh Tj = +2°C	4.22 kW	3.75 kW
COP Tj = +2°C	5.46	4.04
Pdh Tj = +7°C	2.66 kW	2.52 kW
COP Tj = +7°C	6.15	4.77
Pdh Tj = 12°C	2.10 kW	1.99 kW
COP Tj = 12°C	6.26	4.95
Pdh Tj = Tbiv	7.61 kW	6.73 kW
COP Tj = Tbiv	4.11	2.63

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.61 kW	6.73 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.11	2.63
WTOL	67 °C	67 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Qhe	2923 kWh	3482 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	36 dB(A)	36 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	220 %	158 %
Prated	7.61 kW	6.73 kW
SCOP	5.70	4.16

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.58 kW	4.21 kW
COP Tj = -7°C	5.43	3.79
Pdh Tj = +2°C	3.01 kW	2.50 kW
COP Tj = +2°C	6.16	4.63
Pdh Tj = +7°C	2.13 kW	2.01 kW
COP Tj = +7°C	6.51	5.08
Pdh Tj = 12°C	2.10 kW	2.01 kW
COP Tj = 12°C	6.17	5.13
Pdh Tj = Tbiv	7.61 kW	6.73 kW
COP Tj = Tbiv	4.11	2.63
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.61 kW	6.73 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.11	2.63
WTOL	67 °C	67 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Annual energy consumption Qhe	3289 kWh	3988 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	36 dB(A)	36 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	206 %	153 %
Prated	7.61 kW	6.73 kW
SCOP	5.35	4.02
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	7.61 kW	6.73 kW
COP Tj = +2°C	4.11	2.63
Pdh Tj = +7°C	5.23 kW	4.14 kW
COP Tj = +7°C	5.10	3.59
Pdh Tj = 12°C	2.66 kW	2.00 kW
COP Tj = 12°C	6.20	4.98
Pdh Tj = Tbiv	7.61 kW	6.73 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = Tbiv	4.11	2.63
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.61 kW	6.73 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.11	2.63
WTOL	67 °C	67 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Qhe	1899 kWh	2237 kWh

Domestic Hot Water (DHW)

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 16147	
Declared load profile	XL
Efficiency ηDHW	124 %
COP	3.01
Heating up time	01:31 h:min
Standby power input	34.9 W
Reference hot water temperature	47.6 °C
Mixed water at 40°C	211 l

Colder Climate

EN 16147	
Declared load profile	XL
Efficiency ηDHW	124 %
COP	3.01
Heating up time	01:31 h:min
Standby power input	34.9 W
Reference hot water temperature	47.6 °C
Mixed water at 40°C	211 l

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 16147	
Declared load profile	XL
Efficiency ηDHW	124 %
COP	3.01
Heating up time	01:31 h:min
Standby power input	34.9 W
Reference hot water temperature	47.6 °C
Mixed water at 40°C	211 l

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: CS7800iLW 8 (+F)

Configure model	
Model name	CS7800iLW 8 (+F)
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	7.61 kW	6.73 kW
El input	1.85 kW	2.56 kW
COP	4.11	2.63

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	36 dB(A)	36 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	207 %	152 %
Prated	7.61 kW	6.73 kW
SCOP	5.38	3.99
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.04 kW	5.86 kW
COP Tj = -7°C	4.33	2.95
Pdh Tj = +2°C	4.22 kW	3.75 kW
COP Tj = +2°C	5.46	4.04
Pdh Tj = +7°C	2.66 kW	2.52 kW
COP Tj = +7°C	6.15	4.77
Pdh Tj = 12°C	2.10 kW	1.99 kW
COP Tj = 12°C	6.26	4.95
Pdh Tj = Tbiv	7.61 kW	6.73 kW
COP Tj = Tbiv	4.11	2.63

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.61 kW	6.73 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.11	2.63
WTOL	67 °C	67 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Qhe	2923 kWh	3482 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	36 dB(A)	36 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	220 %	158 %
Prated	7.61 kW	6.73 kW
SCOP	5.70	4.16

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Tbiv	-22 °C	-22 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.58 kW	4.21 kW
COP Tj = -7°C	5.43	3.79
Pdh Tj = +2°C	3.01 kW	2.50 kW
COP Tj = +2°C	6.16	4.63
Pdh Tj = +7°C	2.13 kW	2.01 kW
COP Tj = +7°C	6.51	5.08
Pdh Tj = 12°C	2.10 kW	2.01 kW
COP Tj = 12°C	6.17	5.13
Pdh Tj = Tbiv	7.61 kW	6.73 kW
COP Tj = Tbiv	4.11	2.63
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.61 kW	6.73 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.11	2.63
WTOL	67 °C	67 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Annual energy consumption Qhe	3289 kWh	3988 kWh

Warmer Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	36 dB(A)	36 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	206 %	153 %
Prated	7.61 kW	6.73 kW
SCOP	5.35	4.02
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	7.61 kW	6.73 kW
COP Tj = +2°C	4.11	2.63
Pdh Tj = +7°C	5.23 kW	4.14 kW
COP Tj = +7°C	5.10	3.59
Pdh Tj = 12°C	2.66 kW	2.00 kW
COP Tj = 12°C	6.20	4.98
Pdh Tj = Tbiv	7.61 kW	6.73 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = Tbiv	4.11	2.63
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.61 kW	6.73 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	4.11	2.63
WTOL	67 °C	67 °C
Poff	11 W	11 W
PTO	11 W	11 W
PSB	11 W	11 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0 kW	0 kW
Annual energy consumption Qhe	1899 kWh	2237 kWh

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.