Login

Summary of	WPL 17 I(K)CS classic	Reg. No.	011-1W0224
Certificate Holder			
Name	STIEBEL ELTRON GmbH & Co KG		
Address	Dr. Stiebel Straße 33	Zip	37603
City	Holzminden	Country	Germany
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	WPL 17 I(K)CS classic		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	2.6 kg		
Certification Date	04.09.2019		
Testing basis	HP KEYMARK certification scheme rules rev. no. 5		

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: WPL 17 IKCS classic

Configure model	
Model name	WPL 17 IKCS classic
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.22 kW	3.75 kW
El input	0.92 kW	1.49 kW
COP	4.60	2.51

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	44 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	207 %	142 %
Prated	4.95 kW	4.30 kW
SCOP	5.24	3.63
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	4.95 kW	4.34 kW
COP Tj = +2°C	3.70	2.21
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.21 kW	3.96 kW
COP Tj = +7°C	4.90	3.21
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.31 kW	2.98 kW
COP Tj = 12°C	7.35	5.30
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	4.95 kW	4.34 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = Tbiv	3.70	2.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	4.95 kW	4.34 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.70	2.21
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	56 W	56 W
PTO	21 W	21 W
PSB	56 W	56 W
PCK	26 W	26 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1262 kWh	1584 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	43 dB(A)	48 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	126 %	105 %

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Prated	13.20 kW	12.70 kW
SCOP	3.23	2.69
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	7.96 kW	7.69 kW
COP Tj = -7°C	2.73	2.26
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	5.29 kW	4.89 kW
COP Tj = +2°C	4.24	3.49
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.19 kW	4.21 kW
COP Tj = +7°C	5.45	4.82
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.39 kW	3.23 kW
COP Tj = 12°C	8.03	6.75
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.96 kW	7.69 kW
COP Tj = Tbiv	2.73	2.26
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.13 kW	5.24 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.27	1.00
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

WTOL	60 °C	60 °C
Poff	56 W	56 W
PTO	21 W	21 W
PSB	56 W	56 W
PCK	26 W	26 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	7.38 kW	6.79 kW
Annual energy consumption Qhe	10074 kWh	11651 kWh
Pdh Tj = -15°C (if TOL<-20°C)	6.21	6.18
COP Tj = -15°C (if TOL<-20°C)	2.43	1.48
Cdh Tj = -15 °C	0.90	0.90

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	40 dB(A)	44 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	161 %	126 %
Prated	9.20 kW	7.10 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

SCOP	4.11	3.21
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.93 kW	6.28 kW
COP Tj = -7°C	2.61	2.13
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	5.16 kW	4.73 kW
COP Tj = +2°C	4.03	3.04
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.20 kW	4.20 kW
COP Tj = +7°C	5.25	4.44
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.39 kW	3.14 kW
COP Tj = 12°C	8.03	6.21
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.93 kW	6.28 kW
COP Tj = Tbiv	2.61	2.13
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.29 kW	2.77 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.55	1.83
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Poff	56 W	56 W
PTO	21 W	21 W
PSB	56 W	56 W
PCK	26 W	26 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.91 kW	4.43 kW
Annual energy consumption Qhe	4621 kWh	4564 kWh

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Model: WPL 17 ICS classic

Configure model	
Model name	WPL 17 ICS classic
Application	Heating (medium temp)
Units	Indoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	**Medium temperature**
Heat output	4.27 kW	3.81 kW
El input	0.90 kW	1.48 kW
COP	4.74	2.58

Warmer Climate

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	43 dB(A)	48 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	212 %	145 %
Prated	5.02 kW	4.40 kW
SCOP	5.38	3.69
Tbiv	2 °C	2 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	5.02 kW	4.42 kW
COP Tj = +2°C	3.83	2.27
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.27 kW	4.02 kW
COP Tj = +7°C	5.06	3.30
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.35 kW	3.01 kW
COP Tj = 12°C	7.50	5.35
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	5.02 kW	4.42 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

COP Tj = Tbiv	3.83	2.27
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.02 kW	4.42 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.83	2.27
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C
Poff	56 W	56 W
PTO	21 W	21 W
PSB	56 W	56 W
PCK	26 W	26 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW
Annual energy consumption Qhe	1247 kWh	1592 kWh

Colder Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	43 dB(A)	48 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	130 %	112 %

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Prated	13.40 kW	13.00 kW
SCOP	3.33	2.86
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-20 °C
Pdh Tj = -7°C	8.13 kW	7.84 kW
COP Tj = -7°C	2.81	2.31
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	5.39 kW	4.96 kW
COP Tj = +2°C	4.42	3.61
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.26 kW	4.27 kW
COP Tj = +7°C	5.65	4.98
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.43 kW	3.26 kW
COP Tj = 12°C	8.21	6.88
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	8.13 kW	7.84 kW
COP Tj = Tbiv	2.81	2.31
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	5.24 kW	5.24 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.33	2.33
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

WTOL	60 °C	60 °C
Poff	56 W	56 W
PTO	21 W	21 W
PSB	56 W	56 W
PCK	26 W	26 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	7.45 kW	7.08 kW
Annual energy consumption Qhe	9919 kWh	11197 kWh
Pdh Tj = -15°C (if TOL<-20°C)	6.29	6.24
COP Tj = -15°C (if TOL<-20°C)	2.47	2.32
Cdh Tj = -15 °C	0.90	0.90

Average Climate

EN 12102-1		
	Low temperature	**Medium temperature**
Sound power level indoor	43 dB(A)	48 dB(A)

EN 14825		
	Low temperature	**Medium temperature**
η_s	167 %	129 %
Prated	9.00 kW	7.20 kW

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

SCOP	4.24	3.30
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.98 kW	6.39 kW
COP Tj = -7°C	2.65	2.17
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	5.25 kW	4.81 kW
COP Tj = +2°C	4.19	3.14
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.26 kW	4.25 kW
COP Tj = +7°C	5.44	4.56
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.43 kW	3.18 kW
COP Tj = 12°C	8.21	6.33
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.98 kW	6.39 kW
COP Tj = Tbiv	2.65	2.17
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.35 kW	2.77 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.59	1.83
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	60 °C	60 °C

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.

Poff	56 W	56 W
PTO	21 W	21 W
PSB	56 W	56 W
PCK	26 W	26 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.65 kW	4.43 kW
Annual energy consumption Qhe	4387 kWh	4506 kWh

Disclaimer: this document is a summary of the certified performance.
The authoritative source of this information is the heat pump certificate as executed by the certification body and the related technical data.