

This information was generated by the HP KEYMARK database on 17 Dec 2020

Summary of	Jäspi Inverter Nordic 8	Reg. No.	012-SC0653-18
Certificate Holder			
Name	Kaukora		
Address	Tuotekatu 11	Zip	FI-21200
City	Raisio	Country	Finland
Certification Body	RISE CERT		
Name of testing laboratory	DTI		
Subtype title	Jäspi Inverter Nordic 8		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410a		
Mass Of Refrigerant	2.4 kg		

Model: Jäspi Inverter Nordic 8 (1-phase)

General Data

Power supply	1x230V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	3.57 kW	3.75 kW
El input	0.78 kW	1.23 kW
COP	4.57	3.05
Indoor water flow rate	0.61 m ³ /h	0.40 m ³ /h

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	189 %	147 %
Prated	5.90 kW	6.30 kW
SCOP	4.80	3.67
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.20 kW	5.50 kW
COP Tj = -7°C	3.25	2.48
Pdh Tj = +2°C	4.00 kW	4.10 kW
COP Tj = +2°C	4.91	3.80
Pdh Tj = +7°C	2.90 kW	2.90 kW
COP Tj = +7°C	5.60	4.45
Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	6.40	5.26
Pdh Tj = Tbiv	5.20 kW	5.50 kW
COP Tj = Tbiv	3.25	2.48

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	5.30 kW	5.70 kW
COP Tj = TOL	3.12	2.34
Cdh	0.99	0.99
WTOL	65 °C	65 °C
Poff	25 W	25 W
PTO	10 W	10 W
PSB	25 W	25 W
PCK	37 W	37 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.60 kW	0.60 kW
Annual energy consumption Qhe	4182 kWh	5524 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	158 %	130 %
Prated	6.80 kW	7.40 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

SCOP	4.02	3.32
Tbiv	-12 °C	-12 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.10 kW	4.50 kW
COP Tj = -7°C	3.30	2.74
Pdh Tj = +2°C	2.60 kW	2.70 kW
COP Tj = +2°C	5.20	4.10
Pdh Tj = +7°C	2.90 kW	2.90 kW
COP Tj = +7°C	5.52	4.65
Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	6.25	5.31
Pdh Tj = Tbiv	5.00 kW	5.50 kW
COP Tj = Tbiv	3.00	2.50
Pdh Tj = TOL	3.80 kW	4.30 kW
COP Tj = TOL	2.30	1.85
Cdh	0.99	0.99
WTOL	65 °C	65 °C
Poff	25 W	25 W
PTO	10 W	10 W
PSB	25 W	25 W
PCK	37 W	37 W

This information was generated by the HP KEYMARK database on 17 Dec 2020

Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	3.10 kW	3.10 kW
Annual energy consumption Q _{he}	4182 kWh	5524 kWh

Model: Jäspi Inverter Nordic 8 (3-phase)

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-2

	Low temperature	Medium temperature
Heat output	3.57 kW	3.75 kW
El input	0.78 kW	1.23 kW
COP	4.57	3.05
Indoor water flow rate	0.61 m ³ /h	0.40 m ³ /h

EN 14511-4

Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

Average Climate

This information was generated by the HP KEYMARK database on 17 Dec 2020

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	189 %	147 %
Prated	5.90 kW	6.30 kW
SCOP	4.80	3.67
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	5.20 kW	5.50 kW
COP Tj = -7°C	3.25	2.48
Pdh Tj = +2°C	4.00 kW	4.10 kW
COP Tj = +2°C	4.91	3.80
Pdh Tj = +7°C	2.90 kW	2.90 kW
COP Tj = +7°C	5.60	4.45
Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	6.40	5.26
Pdh Tj = Tbiv	5.20 kW	5.50 kW
COP Tj = Tbiv	3.25	2.48

This information was generated by the HP KEYMARK database on 17 Dec 2020

Pdh Tj = TOL	5.30 kW	5.70 kW
COP Tj = TOL	3.12	2.34
Cdh	0.99	0.99
WTOL	65 °C	65 °C
Poff	25 W	25 W
PTO	10 W	10 W
PSB	25 W	25 W
PCK	37 W	37 W
Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	0.60 kW	0.60 kW
Annual energy consumption Qhe	4182 kWh	5524 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	53 dB(A)	53 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	158 %	130 %
Prated	6.80 kW	7.40 kW

This information was generated by the HP KEYMARK database on 17 Dec 2020

SCOP	4.02	3.32
Tbiv	-12 °C	-12 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	4.10 kW	4.50 kW
COP Tj = -7°C	3.30	2.74
Pdh Tj = +2°C	2.60 kW	2.70 kW
COP Tj = +2°C	5.20	4.10
Pdh Tj = +7°C	2.90 kW	2.90 kW
COP Tj = +7°C	5.52	4.65
Pdh Tj = 12°C	3.30 kW	3.30 kW
COP Tj = 12°C	6.25	5.31
Pdh Tj = Tbiv	5.00 kW	5.50 kW
COP Tj = Tbiv	3.00	2.50
Pdh Tj = TOL	3.80 kW	4.30 kW
COP Tj = TOL	2.30	1.85
Cdh	0.99	0.99
WTOL	65 °C	65 °C
Poff	25 W	25 W
PTO	10 W	10 W
PSB	25 W	25 W
PCK	37 W	37 W

This information was generated by the HP KEYMARK database on 17 Dec 2020

Supplementary Heater: Type of energy input	electricity	electricity
Supplementary Heater: PSUP	3.10 kW	3.10 kW
Annual energy consumption Qhe	4182 kWh	5524 kWh