

Page 1 of 11

This information was generated by the HP KEYMARK database on 18 Mar 2022

<u>Login</u>

Summary of	i-32V514	Reg. No.	ICIM-PDC-000075-00
Certificate Holder	Certificate Holder		
Name	Advantix S.p.A.		
Address	Via San Giuseppe Lavoratore, 24	Zip	37040
City	Arcole Verona	Country	Italy
Certification Body	ICIM S.p.A.		
Subtype title	i-32V514		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	3.6 kg		
Certification Date	26.05.2020		
Testing basis	Testing basis HP KEYMARK certification scheme rules rev. no. 7		



Model: i-32V514

Configure model		
Model name	i-32V514	
Application	Heating (medium temp)	
Units	Outdoor	
Climate Zone	n/a	
Reversibility	Yes	
Cooling mode application (optional)	+7°C/12°C	

General Data		
Power supply 1x230V 50Hz		

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.10 kW	13.44 kW
El input	2.91 kW	4.35 kW
СОР	4.85	3.09

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Average Climate



	EN 12102-1	
	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	66 dB(A)	66 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	176 %	130 %
Prated	12.00 kW	12.00 kW
SCOP	4.48	3.31
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-15 °C
Pdh Tj = -7°C	10.70 kW	10.30 kW
COP Tj = -7°C	2.98	2.10
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	6.50 kW	6.20 kW
COP Tj = +2°C	4.20	3.21
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	5.80 kW	5.70 kW
COP Tj = +7°C	5.98	4.19
Cdh Tj = +7 °C	0.980	0.986

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



\bigcirc	
	CEN heat pump
5	KEYMARK

Pdh Tj = 12°C	6.70 kW	6.60 kW
COP Tj = 12°C	8.16	6.17
Cdh Tj = +12 °C	0.977	0.982
Pdh Tj = Tbiv	10.70 kW	10.30 kW
COP Tj = Tbiv	2.98	2.10
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.50 kW	10.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.69	1.96
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	19 W	19 W
PTO	22 W	22 W
PSB	19 W	19 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	1.50 kW	1.80 kW
Annual energy consumption Qhe	5583 kWh	7259 kWh


Cooling





EN 14511-2	
	+7°C/+12°C
El input	3.53 kW
Cooling capacity	11.48
EER	3.25

EN 14825





This information was generated by the Hir KL	
	+7°C/+12°C
Pdesignc	11.48 kW
SEER	4.77
Pdc Tj = 35°C	11.48 kW
EER Tj = 35°C	3.25
Pdc Tj = 30°C	8.47 kW
EER Tj = 30°C	4.31
Cdc	1.000
Pdc Tj = 25°C	5.41 kW
EER Tj = 25°C	4.91
Cdc	0.983
Pdc Tj = 20°C	5.53 kW
EER Tj = 20°C	6.72
Cdc	0.977
Poff	22 W
РТО	0 W
PSB	28 W
PCK	o w
Annual energy consumption Qce	1444 kWh



Model: i-32V514T

Configure model		
Model name	i-32V514T	
Application	Heating (medium temp)	
Units	Outdoor	
Climate Zone	n/a	
Reversibility	Yes	
Cooling mode application (optional)	+7°C/12°C	

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.10 kW	13.44 kW
El input	2.91 kW	4.35 kW
СОР	4.85	3.09

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed


Average Climate



EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	dB(A)	dB(A)
Sound power level outdoor	66 dB(A)	66 dB(A)


EN 14825		
	Low temperature	Medium temperature
η_{s}	176 %	130 %
Prated	12.00 kW	12.00 kW
SCOP	4.48	3.31
Tbiv	-7 °C	-7 °C
TOL	-20 °C	-15 °C
Pdh Tj = -7°C	10.70 kW	10.30 kW
COP Tj = -7°C	2.98	2.10
Cdh Tj = -7 °C	1.000	1.000
Pdh Tj = +2°C	6.50 kW	6.20 kW
COP Tj = +2°C	4.20	3.21
Cdh Tj = +2 °C	1.000	1.000
Pdh Tj = +7°C	5.80 kW	5.70 kW
COP Tj = +7°C	5.98	4.19
Cdh Tj = +7 °C	0.980	0.986

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Pdh Tj = 12°C	6.70 kW	6.60 kW
COP Tj = 12°C	8.16	6.17
Cdh Tj = +12 °C	0.977	0.982
Pdh Tj = Tbiv	10.70 kW	10.30 kW
COP Tj = Tbiv	2.98	2.10
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.50 kW	10.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.69	1.96
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	60 °C	60 °C
Poff	19 W	19 W
РТО	22 W	22 W
PSB	19 W	19 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	n/a	n/a
Supplementary Heater: PSUP	1.50 kW	1.80 kW
Annual energy consumption Qhe	5583 kWh	7259 kWh

Cooling





EN 14511-2	
	+7°C/+12°C
El input	3.53 kW
Cooling capacity	11.48
EER	3.25

EN 14825



Page 11 of 11 This information was generated by the HP KEYMARK database on 18 Mar 2022

This information was genera	ited by the HP KETMARK database on 16 Mai 2022
	+7°C/+12°C
Pdesignc	11.48 kW
SEER	4.77
Pdc Tj = 35°C	11.48 kW
EER Tj = 35°C	3.25
Pdc Tj = 30°C	8.47 kW
EER Tj = 30°C	4.31
Cdc	1.000
Pdc Tj = 25°C	5.41 kW
EER Tj = 25°C	4.91
Cdc	0.983
Pdc Tj = 20°C	5.53 kW
EER Tj = 20°C	6.72
Cdc	0.977
Poff	22 W
РТО	o w
PSB	28 W
PCK	o w
Annual energy consumption Qce	1444 kWh