

This information was generated by the HP KEYMARK database on 18 Mar 2022

[Login](#)

Summary of	Prima 12-16GT	Reg. No.	041-K013-03
Certificate Holder			
Name	Galmet Sp. z o.o. Sp. K.		
Address	ul. Raciborska 36	Zip	48-100
City	Głubczyce	Country	Poland
Certification Body	BRE Global Limited		
Subtype title	Prima 12-16GT		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	1.84 kg		
Certification Date	14.04.2021		
Testing basis	HP Keymark Scheme Rules Rev 08		

Model: Prima S 12GT

Configure model	
Model name	Prima S 12GT
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	12.10 kW	12.00 kW
El input	2.44 kW	3.87 kW
COP	4.95	3.10

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	189 %	135 %
Prated	12.00 kW	11.58 kW
SCOP	4.81	3.45
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.61 kW	10.25 kW
COP Tj = -7°C	2.88	2.01
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	6.69 kW	6.52 kW
COP Tj = +2°C	4.65	3.44
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.44 kW	4.36 kW
COP Tj = +7°C	6.62	4.59
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.74 kW	3.30 kW
COP Tj = 12°C	8.47	6.05
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	10.61 kW	10.25 kW
COP Tj = Tbiv	2.88	2.01
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.75 kW	9.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.77	1.79
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.26 kW	2.50 kW
Annual energy consumption Qhe	5152 kWh	6927 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825

	Low temperature	Medium temperature
η_s	256 %	174 %
Prated	11.11 kW	12.51 kW
SCOP	6.53	4.43
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.11 kW	12.08 kW
COP Tj = +2°C	3.59	2.31
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	7.14 kW	8.04 kW
COP Tj = +7°C	5.87	3.86
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.56 kW	3.75 kW
COP Tj = 12°C	7.94	5.70
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	7.14 kW	8.04 kW
COP Tj = Tbiv	5.87	3.86
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.11 kW	12.08 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.59	2.31
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		

This information was generated by the HP KEYMARK database on 18 Mar 2022

WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.44 kW
Annual energy consumption Qhe	2292 kWh	3776 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	160 %	118 %
Prated	11.38 kW	10.32 kW
SCOP	4.08	3.02
Tbiv	-15 °C	-15 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

TOL	-22 °C	-22 °C
Pdh Tj = -7°C	7.05 kW	6.63 kW
COP Tj = -7°C	3.48	2.63
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.68 kW	4.07 kW
COP Tj = +2°C	4.96	3.60
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.14 kW	2.78 kW
COP Tj = +7°C	6.10	4.54
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.57 kW	3.33 kW
COP Tj = 12°C	7.87	6.25
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	9.28 kW	8.42 kW
COP Tj = Tbiv	2.59	1.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.01 kW	4.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.98	1.13
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W

This information was generated by the HP KEYMARK database on 18 Mar 2022

PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.37 kW	6.12 kW
Annual energy consumption Q _{he}	6870 kWh	8419 kWh
P _{dh} T _j = -15°C (if TOL<-20°C)	9.28	8.42
COP T _j = -15°C (if TOL<-20°C)	2.59	1.84
C _{dh} T _j = -15 °C	0.90	0.90

Model: Prima S 16GT

Configure model	
Model name	Prima S 16GT
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	16.00 kW	16.00 kW
El input	3.56 kW	5.52 kW
COP	4.50	2.90

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	182 %	133 %
Prated	15.21 kW	13.02 kW
SCOP	4.62	3.41
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	13.45 kW	11.52 kW
COP Tj = -7°C	2.72	1.99
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	8.57 kW	7.18 kW
COP Tj = +2°C	4.41	3.34
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.70 kW	4.68 kW
COP Tj = +7°C	6.56	4.61
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.78 kW	3.32 kW
COP Tj = 12°C	8.51	6.07
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	13.45 kW	11.52 kW
COP Tj = Tbiv	2.72	1.99
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.52 kW	10.33 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.48	1.80
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.68 kW	2.67 kW
Annual energy consumption Qhe	6804 kWh	7895 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825

	Low temperature	Medium temperature
η_s	249 %	176 %
Prated	13.09 kW	13.78 kW
SCOP	6.33	4.48
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	13.09 kW	13.38 kW
COP Tj = +2°C	3.35	2.29
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	8.42 kW	8.86 kW
COP Tj = +7°C	5.36	3.84
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.88 kW	4.06 kW
COP Tj = 12°C	8.11	5.86
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	8.42 kW	8.86 kW
COP Tj = Tbiv	5.36	3.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.09 kW	13.38 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.35	2.29
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		

This information was generated by the HP KEYMARK database on 18 Mar 2022

WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.40 kW
Annual energy consumption Qhe	2781 kWh	4112 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	158 %	122 %
Prated	13.76 kW	11.79 kW
SCOP	4.02	3.12
Tbiv	-15 °C	-15 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

TOL	-22 °C	-22 °C
Pdh Tj = -7°C	8.31 kW	7.64 kW
COP Tj = -7°C	3.37	2.65
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	5.27 kW	4.43 kW
COP Tj = +2°C	4.86	3.79
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.62 kW	2.98 kW
COP Tj = +7°C	6.49	4.81
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.35 kW	3.43 kW
COP Tj = 12°C	7.40	6.29
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	11.22 kW	9.62 kW
COP Tj = Tbiv	2.43	1.86
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.89 kW	5.22 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.97	1.23
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W

This information was generated by the HP KEYMARK database on 18 Mar 2022

PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.87 kW	6.57 kW
Annual energy consumption Q _{he}	8431 kWh	9309 kWh
P _{dh} T _j = -15°C (if TOL<-20°C)	11.22	9.62
COP T _j = -15°C (if TOL<-20°C)	2.43	1.86
C _{dh} T _j = -15 °C	0.90	0.90

Model: Prima 12GT

Configure model	
Model name	Prima 12GT
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	12.10 kW	11.90 kW
El input	2.44 kW	3.90 kW
COP	4.95	3.05

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	189 %	135 %
Prated	12.00 kW	11.58 kW
SCOP	4.81	3.45
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.61 kW	10.25 kW
COP Tj = -7°C	2.88	2.01
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	6.69 kW	6.52 kW
COP Tj = +2°C	4.65	3.44
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.44 kW	4.36 kW
COP Tj = +7°C	6.62	4.59
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.74 kW	3.30 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = 12°C	8.47	6.05
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	10.61 kW	10.25 kW
COP Tj = Tbiv	2.88	2.01
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.75 kW	9.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.77	1.79
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.26 kW	2.50 kW
Annual energy consumption Qhe	5152 kWh	6927 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825		
	Low temperature	Medium temperature

This information was generated by the HP KEYMARK database on 18 Mar 2022

η_s	256 %	174 %
Prated	11.11 kW	12.51 kW
SCOP	6.53	4.43
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.11 kW	12.08 kW
COP Tj = +2°C	3.59	2.31
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	7.14 kW	8.04 kW
COP Tj = +7°C	5.87	3.86
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.56 kW	3.75 kW
COP Tj = 12°C	7.94	5.70
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	7.14 kW	8.04 kW
COP Tj = Tbiv	5.87	3.86
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.11 kW	12.08 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.59	2.31
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	65 °C	65 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.44 kW
Annual energy consumption Qhe	2292 kWh	3776 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	160 %	118 %
Prated	11.38 kW	10.32 kW
SCOP	4.08	3.02
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	7.05 kW	6.63 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = -7°C	3.48	2.63
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.68 kW	4.07 kW
COP Tj = +2°C	4.96	3.60
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.14 kW	2.78 kW
COP Tj = +7°C	6.10	4.54
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.57 kW	3.33 kW
COP Tj = 12°C	7.87	6.25
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	9.28 kW	8.42 kW
COP Tj = Tbiv	2.59	1.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.01 kW	4.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.98	1.13
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity

This information was generated by the HP KEYMARK database on 18 Mar 2022

Supplementary Heater: PSUP	4.37 kW	6.12 kW
Annual energy consumption Q_{he}	6870 kWh	8419 kWh
$P_{dh} T_j = -15^{\circ}\text{C}$ (if $TOL < -20^{\circ}\text{C}$)	9.28	8.42
$COP T_j = -15^{\circ}\text{C}$ (if $TOL < -20^{\circ}\text{C}$)	2.59	1.84
$C_{dh} T_j = -15^{\circ}\text{C}$	0.90	0.90

Model: Prima 14GT

Configure model	
Model name	Prima 14GT
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.50 kW	13.80 kW
El input	3.15 kW	4.68 kW
COP	4.60	2.95

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	186 %	136 %
Prated	13.73 kW	12.08 kW
SCOP	4.72	3.47
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.14 kW	10.69 kW
COP Tj = -7°C	2.79	2.01
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	7.95 kW	6.86 kW
COP Tj = +2°C	4.52	3.43
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.20 kW	4.64 kW
COP Tj = +7°C	6.68	4.66
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.76 kW	3.32 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = 12°C	8.52	6.13
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	12.14 kW	10.69 kW
COP Tj = Tbiv	2.79	2.01
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.48 kW	9.19 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.59	1.76
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.23 kW	2.91 kW
Annual energy consumption Qhe	6012 kWh	7202 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825		
	Low temperature	Medium temperature

This information was generated by the HP KEYMARK database on 18 Mar 2022

η_s	260 %	177 %
Prated	12.11 kW	13.74 kW
SCOP	6.63	4.49
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	12.04 kW	13.05 kW
COP Tj = +2°C	3.44	2.20
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	7.78 kW	8.83 kW
COP Tj = +7°C	5.84	3.91
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.75 kW	4.09 kW
COP Tj = 12°C	8.25	5.90
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.78 kW	8.83 kW
COP Tj = Tbiv	5.84	3.91
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.04 kW	13.05 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.44	2.20
WTOL	65 °C	65 °C
Poff	14 W	14 W

This information was generated by the HP KEYMARK database on 18 Mar 2022

PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.07 kW	0.69 kW
Annual energy consumption Q _{he}	2457 kWh	4088 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	160 %	119 %
Prated	12.64 kW	10.97 kW
SCOP	4.07	3.05
T _{biv}	-15 °C	-15 °C
TOL	-22 °C	-22 °C
P _{dh} T _j = -7°C	7.97 kW	6.89 kW
COP T _j = -7°C	3.44	2.66

This information was generated by the HP KEYMARK database on 18 Mar 2022

Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	5.05 kW	4.32 kW
COP Tj = +2°C	4.92	3.66
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.16 kW	3.06 kW
COP Tj = +7°C	6.11	4.72
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.58 kW	3.33 kW
COP Tj = 12°C	7.82	6.25
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	10.31 kW	8.95 kW
COP Tj = Tbiv	2.53	1.79
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.57 kW	4.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.92	1.13
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.07 kW	6.77 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

Annual energy consumption Q_{he}	7667 kWh	8866 kWh
$P_{dh} T_j = -15^{\circ}\text{C}$ (if $TOL < -20^{\circ}\text{C}$)	10.31	8.95
$COP T_j = -15^{\circ}\text{C}$ (if $TOL < -20^{\circ}\text{C}$)	2.53	1.79
$C_{dh} T_j = -15^{\circ}\text{C}$	0.90	0.90

Model: Prima 16GT

Configure model	
Model name	Prima 16GT
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	15.90 kW	16.00 kW
El input	3.53 kW	5.61 kW
COP	4.50	2.85

Average Climate

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	182 %	133 %
Prated	15.21 kW	13.02 kW
SCOP	4.62	3.41
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	13.45 kW	11.52 kW
COP Tj = -7°C	2.72	1.99
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	8.57 kW	7.18 kW
COP Tj = +2°C	4.41	3.34
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.70 kW	4.68 kW
COP Tj = +7°C	6.56	4.61
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.78 kW	3.32 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = 12°C	8.51	6.07
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	13.45 kW	11.52 kW
COP Tj = Tbiv	2.72	1.99
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.52 kW	10.33 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.48	1.80
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.68 kW	2.67 kW
Annual energy consumption Qhe	6804 kWh	7895 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825		
	Low temperature	Medium temperature

This information was generated by the HP KEYMARK database on 18 Mar 2022

η_s	249 %	176 %
Prated	13.09 kW	13.78 kW
SCOP	6.33	4.48
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	13.09 kW	13.38 kW
COP Tj = +2°C	3.35	2.29
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	8.42 kW	8.86 kW
COP Tj = +7°C	5.36	3.84
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.88 kW	4.06 kW
COP Tj = 12°C	8.11	5.86
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	8.42 kW	8.86 kW
COP Tj = Tbiv	5.36	3.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.09 kW	13.38 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.35	2.29
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	65 °C	65 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.40 kW
Annual energy consumption Qhe	2781 kWh	4112 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	158 %	122 %
Prated	13.76 kW	11.79 kW
SCOP	4.02	3.12
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	8.31 kW	7.64 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = -7°C	3.37	2.65
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	5.27 kW	4.43 kW
COP Tj = +2°C	4.86	3.79
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.62 kW	2.98 kW
COP Tj = +7°C	6.49	4.81
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.35 kW	3.43 kW
COP Tj = 12°C	7.40	6.29
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	11.22 kW	9.62 kW
COP Tj = Tbiv	2.43	1.86
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.89 kW	5.22 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.97	1.23
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity

This information was generated by the HP KEYMARK database on 18 Mar 2022

Supplementary Heater: PSUP	4.87 kW	6.57 kW
Annual energy consumption Q_{he}	8431 kWh	9309 kWh
$P_{dh} T_j = -15^{\circ}\text{C}$ (if $TOL < -20^{\circ}\text{C}$)	11.22	9.62
$COP T_j = -15^{\circ}\text{C}$ (if $TOL < -20^{\circ}\text{C}$)	2.43	1.86
$C_{dh} T_j = -15^{\circ}\text{C}$	0.90	0.90

Model: Prima S3F 12GT

Configure model	
Model name	Prima S3F 12GT
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	12.10 kW	12.00 kW
El input	2.44 kW	3.87 kW
COP	4.95	3.10

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	189 %	135 %
Prated	12.00 kW	11.58 kW
SCOP	4.81	3.45
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.61 kW	10.25 kW
COP Tj = -7°C	2.88	2.01
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	6.69 kW	6.52 kW
COP Tj = +2°C	4.65	3.44
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.44 kW	4.36 kW
COP Tj = +7°C	6.62	4.59
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.74 kW	3.30 kW
COP Tj = 12°C	8.47	6.05
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	10.61 kW	10.25 kW
COP Tj = Tbiv	2.88	2.01
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.75 kW	9.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.77	1.79
WTOL	65 °C	65 °C
Poff	20 W	20 W
PTO	30 W	30 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.26 kW	2.50 kW
Annual energy consumption Qhe	5153 kWh	6928 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825

	Low temperature	Medium temperature
η_s	256 %	174 %
Prated	11.11 kW	12.51 kW
SCOP	6.53	4.42
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.11 kW	12.08 kW
COP Tj = +2°C	3.59	2.31
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	7.14 kW	8.04 kW
COP Tj = +7°C	5.87	3.86
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.56 kW	3.75 kW
COP Tj = 12°C	7.94	5.70
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	7.14 kW	8.04 kW
COP Tj = Tbiv	5.87	3.86
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.11 kW	12.08 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.59	2.31
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		

This information was generated by the HP KEYMARK database on 18 Mar 2022

WTOL	65 °C	65 °C
Poff	20 W	20 W
PTO	30 W	30 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.44 kW
Annual energy consumption Qhe	2296 kWh	3780 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	64 dB(A)	64 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	160 %	118 %
Prated	11.38 kW	10.32 kW
SCOP	4.08	3.02
Tbiv	-15 °C	-15 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

TOL	-22 °C	-22 °C
Pdh Tj = -7°C	7.05 kW	6.63 kW
COP Tj = -7°C	3.48	2.63
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.68 kW	4.07 kW
COP Tj = +2°C	4.96	3.60
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.14 kW	2.78 kW
COP Tj = +7°C	6.10	4.54
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.57 kW	3.33 kW
COP Tj = 12°C	7.87	6.25
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	9.28 kW	8.42 kW
COP Tj = Tbiv	2.59	1.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.01 kW	4.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.98	1.13
WTOL	65 °C	65 °C
Poff	20 W	20 W
PTO	30 W	30 W
PSB	20 W	20 W

This information was generated by the HP KEYMARK database on 18 Mar 2022

PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.37 kW	6.12 kW
Annual energy consumption Q _{he}	6871 kWh	8420 kWh
P _{dh} T _j = -15°C (if TOL<-20°C)	9.28	8.42
COP T _j = -15°C (if TOL<-20°C)	2.59	1.84
C _{dh} T _j = -15 °C	0.90	0.90

Model: Prima S3F 14GT

Configure model	
Model name	Prima S3F 14GT
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.50 kW	13.80 kW
El input	3.09 kW	4.60 kW
COP	4.70	3.00

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	186 %	136 %
Prated	13.73 kW	12.08 kW
SCOP	4.72	3.47
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.14 kW	10.69 kW
COP Tj = -7°C	2.79	2.01
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	7.95 kW	6.86 kW
COP Tj = +2°C	4.52	3.43
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.20 kW	4.64 kW
COP Tj = +7°C	6.68	4.66
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.76 kW	3.32 kW
COP Tj = 12°C	8.52	6.13
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	12.14 kW	10.69 kW
COP Tj = Tbiv	2.79	2.01
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.48 kW	9.19 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.59	1.76
WTOL	65 °C	65 °C
Poff	20 W	20 W
PTO	30 W	30 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.23 kW	2.91 kW
Annual energy consumption Qhe	6013 kWh	7203 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825

	Low temperature	Medium temperature
η_s	260 %	176 %
Prated	12.11 kW	13.74 kW
SCOP	6.63	4.48
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	12.04 kW	13.05 kW
COP Tj = +2°C	3.44	2.20
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	7.78 kW	8.83 kW
COP Tj = +7°C	5.84	3.91
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.75 kW	4.09 kW
COP Tj = 12°C	8.25	5.90
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	7.78 kW	8.83 kW
COP Tj = Tbiv	5.84	3.91
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.04 kW	13.05 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.44	2.20
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		

This information was generated by the HP KEYMARK database on 18 Mar 2022

WTOL	65 °C	65 °C
Poff	20 W	20 W
PTO	30 W	30 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.07 kW	0.69 kW
Annual energy consumption Qhe	2462 kWh	4092 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	160 %	119 %
Prated	12.64 kW	10.97 kW
SCOP	4.06	3.05
Tbiv	-15 °C	-15 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

TOL	-22 °C	-22 °C
Pdh Tj = -7°C	7.97 kW	6.89 kW
COP Tj = -7°C	3.44	2.66
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	5.05 kW	4.32 kW
COP Tj = +2°C	4.92	3.66
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.16 kW	3.06 kW
COP Tj = +7°C	6.11	4.72
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.58 kW	3.33 kW
COP Tj = 12°C	7.82	6.25
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	10.31 kW	8.95 kW
COP Tj = Tbiv	2.53	1.79
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.57 kW	4.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.92	1.13
WTOL	65 °C	65 °C
Poff	20 W	20 W
PTO	30 W	30 W
PSB	20 W	20 W

This information was generated by the HP KEYMARK database on 18 Mar 2022

PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.07 kW	6.77 kW
Annual energy consumption Q _{he}	7667 kWh	8867 kWh
P _{dh} T _j = -15°C (if TOL<-20°C)	10.31	8.95
COP T _j = -15°C (if TOL<-20°C)	2.53	1.79
C _{dh} T _j = -15 °C	0.90	0.90

Model: Prima S3F 16GT

Configure model	
Model name	Prima S3F 16GT
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	16.00 kW	16.00 kW
El input	3.56 kW	5.52 kW
COP	4.50	2.90

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	182 %	133 %
Prated	15.21 kW	13.02 kW
SCOP	4.62	3.41
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	13.45 kW	11.52 kW
COP Tj = -7°C	2.72	1.99
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	8.57 kW	7.18 kW
COP Tj = +2°C	4.41	3.34
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.70 kW	4.68 kW
COP Tj = +7°C	6.56	4.61
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.78 kW	3.32 kW
COP Tj = 12°C	8.51	6.07
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	13.45 kW	11.52 kW
COP Tj = Tbiv	2.72	1.99
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.52 kW	10.33 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.48	1.80
WTOL	65 °C	65 °C
Poff	20 W	20 W
PTO	30 W	30 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.68 kW	2.67 kW
Annual energy consumption Qhe	6805 kWh	7896 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825

	Low temperature	Medium temperature
η_s	248 %	176 %
Prated	13.09 kW	13.78 kW
SCOP	6.33	4.47
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	13.09 kW	13.38 kW
COP Tj = +2°C	3.35	2.29
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	8.42 kW	8.86 kW
COP Tj = +7°C	5.36	3.84
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.88 kW	4.06 kW
COP Tj = 12°C	8.11	5.86
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	8.42 kW	8.86 kW
COP Tj = Tbiv	5.36	3.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.09 kW	13.38 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.35	2.29
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		

This information was generated by the HP KEYMARK database on 18 Mar 2022

WTOL	65 °C	65 °C
Poff	20 W	20 W
PTO	30 W	30 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.40 kW
Annual energy consumption Qhe	2786 kWh	4116 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	158 %	122 %
Prated	13.76 kW	11.79 kW
SCOP	4.02	3.12
Tbiv	-15 °C	-15 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

TOL	-22 °C	-22 °C
Pdh Tj = -7°C	8.31 kW	7.64 kW
COP Tj = -7°C	3.37	2.65
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	5.27 kW	4.43 kW
COP Tj = +2°C	4.86	3.79
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.62 kW	2.98 kW
COP Tj = +7°C	6.49	4.81
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.35 kW	3.43 kW
COP Tj = 12°C	7.40	6.29
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	11.22 kW	9.62 kW
COP Tj = Tbiv	2.43	1.86
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.89 kW	5.22 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.97	1.23
WTOL	65 °C	65 °C
Poff	20 W	20 W
PTO	30 W	30 W
PSB	20 W	20 W

This information was generated by the HP KEYMARK database on 18 Mar 2022

PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.87 kW	6.57 kW
Annual energy consumption Q _{he}	8431 kWh	9310 kWh
P _{dh} T _j = -15°C (if TOL<-20°C)	11.22	9.62
COP T _j = -15°C (if TOL<-20°C)	2.43	1.86
C _{dh} T _j = -15 °C	0.90	0.90

Model: Prima 3F 12GT

Configure model

Model name	Prima 3F 12GT
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data

Power supply	3x400V 50Hz
--------------	-------------

Heating

EN 14511-4

Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2

	Low temperature	Medium temperature
Heat output	12.10 kW	11.90 kW
El input	2.44 kW	3.90 kW
COP	4.95	3.05

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	189 %	135 %
Prated	12.00 kW	11.58 kW
SCOP	4.81	3.45
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	10.61 kW	10.25 kW
COP Tj = -7°C	2.88	2.01
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	6.69 kW	6.52 kW
COP Tj = +2°C	4.65	3.44
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	4.44 kW	4.36 kW
COP Tj = +7°C	6.62	4.59
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.74 kW	3.30 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = 12°C	8.47	6.05
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	10.61 kW	10.25 kW
COP Tj = Tbiv	2.88	2.01
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.75 kW	9.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.77	1.79
WTOL	65 °C	65 °C
Poff	20 W	20 W
PTO	30 W	30 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.26 kW	2.50 kW
Annual energy consumption Qhe	5153 kWh	6928 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825		
	Low temperature	Medium temperature

This information was generated by the HP KEYMARK database on 18 Mar 2022

η_s	256 %	174 %
Prated	11.11 kW	12.51 kW
SCOP	6.53	4.42
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	11.11 kW	12.08 kW
COP Tj = +2°C	3.59	2.31
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	7.14 kW	8.04 kW
COP Tj = +7°C	5.87	3.86
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.56 kW	3.75 kW
COP Tj = 12°C	7.94	5.70
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	7.14 kW	8.04 kW
COP Tj = Tbiv	5.87	3.86
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.11 kW	12.08 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.59	2.31
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	65 °C	65 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

Poff	20 W	20 W
PTO	30 W	30 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.44 kW
Annual energy consumption Qhe	2296 kWh	3780 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	160 %	118 %
Prated	11.38 kW	10.32 kW
SCOP	4.08	3.02
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	7.05 kW	6.63 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = -7°C	3.48	2.63
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	4.68 kW	4.07 kW
COP Tj = +2°C	4.96	3.60
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.14 kW	2.78 kW
COP Tj = +7°C	6.10	4.54
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.57 kW	3.33 kW
COP Tj = 12°C	7.87	6.25
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	9.28 kW	8.42 kW
COP Tj = Tbiv	2.59	1.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.01 kW	4.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.98	1.13
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	30 W	30 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity

This information was generated by the HP KEYMARK database on 18 Mar 2022

Supplementary Heater: PSUP	4.37 kW	6.12 kW
Annual energy consumption Q_{he}	6871 kWh	8420 kWh
$P_{dh} T_j = -15^{\circ}\text{C}$ (if $TOL < -20^{\circ}\text{C}$)	9.28	8.42
$COP T_j = -15^{\circ}\text{C}$ (if $TOL < -20^{\circ}\text{C}$)	2.59	1.84
$C_{dh} T_j = -15^{\circ}\text{C}$	0.90	0.90

Model: Prima 3F 14GT

Configure model	
Model name	Prima 3F 14GT
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.50 kW	13.80 kW
El input	3.15 kW	4.68 kW
COP	4.60	2.95

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	186 %	136 %
Prated	13.73 kW	12.08 kW
SCOP	4.72	3.47
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.14 kW	10.69 kW
COP Tj = -7°C	2.79	2.01
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	7.95 kW	6.86 kW
COP Tj = +2°C	4.52	3.43
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.20 kW	4.64 kW
COP Tj = +7°C	6.68	4.66
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.76 kW	3.32 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = 12°C	8.52	6.13
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	12.14 kW	10.69 kW
COP Tj = Tbiv	2.79	2.01
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.48 kW	9.19 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.59	1.76
WTOL	65 °C	65 °C
Poff	20 W	20 W
PTO	30 W	30 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.23 kW	2.91 kW
Annual energy consumption Qhe	6013 kWh	7203 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825		
	Low temperature	Medium temperature

This information was generated by the HP KEYMARK database on 18 Mar 2022

η_s	260 %	176 %
Prated	12.11 kW	13.74 kW
SCOP	6.63	4.48
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	12.04 kW	13.05 kW
COP Tj = +2°C	3.44	2.20
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	7.78 kW	8.83 kW
COP Tj = +7°C	5.84	3.91
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.75 kW	4.09 kW
COP Tj = 12°C	8.25	5.90
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	7.78 kW	8.83 kW
COP Tj = Tbiv	5.84	3.91
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.04 kW	13.05 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.44	2.20
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	65 °C	65 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

Poff	20 W	20 W
PTO	30 W	30 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.07 kW	0.69 kW
Annual energy consumption Qhe	2462 kWh	4092 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	160 %	119 %
Prated	12.64 kW	10.97 kW
SCOP	4.06	3.05
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	7.97 kW	6.89 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = -7°C	3.44	2.66
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	5.05 kW	4.32 kW
COP Tj = +2°C	4.92	3.66
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.16 kW	3.06 kW
COP Tj = +7°C	6.11	4.72
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.58 kW	3.33 kW
COP Tj = 12°C	7.82	6.25
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	10.31 kW	8.95 kW
COP Tj = Tbiv	2.53	1.79
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.57 kW	4.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.92	1.13
WTOL	65 °C	65 °C
Poff	20 W	20 W
PTO	30 W	30 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity

This information was generated by the HP KEYMARK database on 18 Mar 2022

Supplementary Heater: PSUP	5.07 kW	6.77 kW
Annual energy consumption Q_{he}	7667 kWh	8867 kWh
$P_{dh} T_j = -15^{\circ}\text{C}$ (if $TOL < -20^{\circ}\text{C}$)	10.31	8.95
$COP T_j = -15^{\circ}\text{C}$ (if $TOL < -20^{\circ}\text{C}$)	2.53	1.79
$C_{dh} T_j = -15^{\circ}\text{C}$	0.90	0.90

Model: Prima 3F 16GT

Configure model	
Model name	Prima 3F 16GT
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	15.90 kW	16.00 kW
El input	3.53 kW	5.61 kW
COP	4.50	2.85

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	182 %	133 %
Prated	15.21 kW	13.02 kW
SCOP	4.62	3.41
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	13.45 kW	11.52 kW
COP Tj = -7°C	2.72	1.99
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	8.57 kW	7.18 kW
COP Tj = +2°C	4.41	3.34
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.70 kW	4.68 kW
COP Tj = +7°C	6.56	4.61
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.78 kW	3.32 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = 12°C	8.51	6.07
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	13.45 kW	11.52 kW
COP Tj = Tbiv	2.72	1.99
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.52 kW	10.33 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.48	1.80
WTOL	65 °C	65 °C
Poff	20 W	20 W
PTO	30 W	30 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.68 kW	2.67 kW
Annual energy consumption Qhe	6805 kWh	7896 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825		
	Low temperature	Medium temperature

This information was generated by the HP KEYMARK database on 18 Mar 2022

η_s	248 %	176 %
Prated	13.09 kW	13.78 kW
SCOP	6.33	4.47
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	13.09 kW	13.38 kW
COP Tj = +2°C	3.35	2.29
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	8.42 kW	8.86 kW
COP Tj = +7°C	5.36	3.84
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	3.88 kW	4.06 kW
COP Tj = 12°C	8.11	5.86
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	8.42 kW	8.86 kW
COP Tj = Tbiv	5.36	3.84
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	13.09 kW	13.38 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.35	2.29
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh		
WTOL	65 °C	65 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

Poff	20 W	20 W
PTO	30 W	30 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.40 kW
Annual energy consumption Qhe	2786 kWh	4116 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level outdoor	68 dB(A)	68 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	158 %	122 %
Prated	13.76 kW	11.79 kW
SCOP	4.02	3.12
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	8.31 kW	7.64 kW

This information was generated by the HP KEYMARK database on 18 Mar 2022

COP Tj = -7°C	3.37	2.65
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	5.27 kW	4.43 kW
COP Tj = +2°C	4.86	3.79
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.62 kW	2.98 kW
COP Tj = +7°C	6.49	4.81
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.35 kW	3.43 kW
COP Tj = 12°C	7.40	6.29
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	11.22 kW	9.62 kW
COP Tj = Tbiv	2.43	1.86
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.89 kW	5.22 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.97	1.23
WTOL	65 °C	65 °C
Poff	20 W	20 W
PTO	30 W	30 W
PSB	20 W	20 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity

This information was generated by the HP KEYMARK database on 18 Mar 2022

Supplementary Heater: PSUP	4.87 kW	6.57 kW
Annual energy consumption Q _{he}	8431 kWh	9310 kWh
P _{dh} T _j = -15°C (if TOL<-20°C)	11.22	9.62
COP T _j = -15°C (if TOL<-20°C)	2.43	1.86
C _{dh} T _j = -15 °C	0.90	0.90

Model: Prima S 14GT

Configure model	
Model name	Prima S 14GT
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	Colder Climate + Warmer Climate
Reversibility	Yes
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	14.50 kW	13.80 kW
El input	3.09 kW	4.60 kW
COP	4.70	3.00

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	186 %	136 %
Prated	13.73 kW	12.08 kW
SCOP	4.72	3.47
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.14 kW	10.69 kW
COP Tj = -7°C	2.79	2.01
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	7.95 kW	6.86 kW
COP Tj = +2°C	4.52	3.43
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	5.20 kW	4.64 kW
COP Tj = +7°C	6.68	4.66
Cdh Tj = +7 °C	0.90	0.90

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = 12°C	3.76 kW	3.32 kW
COP Tj = 12°C	8.52	6.13
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	12.14 kW	10.69 kW
COP Tj = Tbiv	2.79	2.01
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	11.48 kW	9.19 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.59	1.76
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.23 kW	2.91 kW
Annual energy consumption Qhe	6012 kWh	7202 kWh

Warmer Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

This information was generated by the HP KEYMARK database on 18 Mar 2022

EN 14825

	Low temperature	Medium temperature
η_s	260 %	177 %
Prated	12.11 kW	13.74 kW
SCOP	6.63	4.49
Tbiv	7 °C	7 °C
TOL	2 °C	2 °C
Pdh Tj = +2°C	12.04 kW	13.05 kW
COP Tj = +2°C	3.44	2.20
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	7.78 kW	8.83 kW
COP Tj = +7°C	5.84	3.91
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.75 kW	4.09 kW
COP Tj = 12°C	8.25	5.90
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	7.78 kW	8.83 kW
COP Tj = Tbiv	5.84	3.91
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	12.04 kW	13.05 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	3.44	2.20
WTOL	65 °C	65 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.07 kW	0.69 kW
Annual energy consumption Qhe	2457 kWh	4088 kWh

Colder Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	43 dB(A)	43 dB(A)
Sound power level outdoor	65 dB(A)	65 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	160 %	119 %
Prated	12.64 kW	10.97 kW
SCOP	4.07	3.05
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C

This information was generated by the HP KEYMARK database on 18 Mar 2022

Pdh Tj = -7°C	7.97 kW	6.89 kW
COP Tj = -7°C	3.44	2.66
Cdh Tj = -7 °C	0.90	0.90
Pdh Tj = +2°C	5.05 kW	4.32 kW
COP Tj = +2°C	4.92	3.66
Cdh Tj = +2 °C	0.90	0.90
Pdh Tj = +7°C	3.16 kW	3.06 kW
COP Tj = +7°C	6.11	4.72
Cdh Tj = +7 °C	0.90	0.90
Pdh Tj = 12°C	3.58 kW	3.33 kW
COP Tj = 12°C	7.82	6.25
Cdh Tj = +12 °C	0.90	0.90
Pdh Tj = Tbiv	10.31 kW	8.95 kW
COP Tj = Tbiv	2.53	1.79
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	7.57 kW	4.20 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	1.92	1.13
WTOL	65 °C	65 °C
Poff	14 W	14 W
PTO	24 W	24 W
PSB	14 W	14 W
PCK	0 W	0 W

This information was generated by the HP KEYMARK database on 18 Mar 2022

Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	5.07 kW	6.77 kW
Annual energy consumption Q _{he}	7667 kWh	8866 kWh
P _{dh} T _j = -15°C (if TOL<-20°C)	10.31	8.95
COP T _j = -15°C (if TOL<-20°C)	2.53	1.79
C _{dh} T _j = -15 °C	0.90	0.90