

This information was generated by the HP KEYMARK database on 7 Jul 2022

[Login](#)

Summary of	DAIKIN ALTHERMA LT MONOBLOC 16kW	Reg. No.	011-1W0261
Certificate Holder			
Name	DAIKIN Europe N.V.		
Address	Zandvoordestraat 300	Zip	B-8400
City	Oostende	Country	Belgium
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	DAIKIN ALTHERMA LT MONOBLOC 16kW		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R410A		
Mass of Refrigerant	3.4 kg		

Model: EDLQ016CV3

Configure model	
Model name	EDLQ016CV3
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	16.00 kW	15.04 kW
El input	3.76 kW	5.37 kW
COP	4.26	2.80

Average Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	66 dB(A)	66 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	149 %	119 %
Prated	16.00 kW	14.00 kW
SCOP	3.80	3.06
Tbiv	-4 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.40 kW	12.20 kW
COP Tj = -7°C	2.33	1.78
Pdh Tj = +2°C	8.60 kW	7.60 kW
COP Tj = +2°C	3.74	3.12
Pdh Tj = +7°C	5.70 kW	4.80 kW
COP Tj = +7°C	6.77	4.40
Pdh Tj = 12°C	6.50 kW	5.40 kW
COP Tj = 12°C	8.97	6.36
Pdh Tj = Tbiv	12.10 kW	12.20 kW
COP Tj = Tbiv	2.56	1.78

This information was generated by the HP KEYMARK database on 7 Jul 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	11.70 kW	13.30 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	2.05	1.71
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	1.00	1.00
WTOL	35 °C	55 °C
Poff	55 W	55 W
PTO	57 W	57 W
PSB	55 W	55 W
PCK	55 W	55 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.40 kW	0.90 kW
Annual energy consumption Q_{he}	8270 kWh	8970 kWh

Model: EBLQ016CV3

Configure model	
Model name	EBLQ016CV3
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	16.00 kW	15.04 kW
El input	3.76 kW	5.37 kW
COP	4.26	2.80

Average Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	66 dB(A)	66 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	149 %	119 %
Prated	16.00 kW	14.00 kW
SCOP	3.80	3.06
Tbiv	-4 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.40 kW	12.20 kW
COP Tj = -7°C	2.33	1.78
Pdh Tj = +2°C	8.60 kW	7.60 kW
COP Tj = +2°C	3.74	3.12
Pdh Tj = +7°C	5.70 kW	4.80 kW
COP Tj = +7°C	6.77	4.40
Pdh Tj = 12°C	6.50 kW	5.40 kW
COP Tj = 12°C	8.97	6.36
Pdh Tj = Tbiv	12.10 kW	12.20 kW
COP Tj = Tbiv	2.56	1.78

This information was generated by the HP KEYMARK database on 7 Jul 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	11.70 kW	13.30 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	2.05	1.71
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	1.00	1.00
WTOL	35 °C	55 °C
Poff	55 W	55 W
PTO	57 W	57 W
PSB	55 W	55 W
PCK	55 W	55 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.40 kW	0.90 kW
Annual energy consumption Q_{he}	8270 kWh	8970 kWh

Model: EBLQ016C3V3

Configure model	
Model name	EBLQ016C3V3
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	16.00 kW	15.04 kW
El input	3.76 kW	5.37 kW
COP	4.26	2.80

Average Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	66 dB(A)	66 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	149 %	119 %
Prated	16.00 kW	14.00 kW
SCOP	3.80	3.06
Tbiv	-4 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.40 kW	12.20 kW
COP Tj = -7°C	2.33	1.78
Pdh Tj = +2°C	8.60 kW	7.60 kW
COP Tj = +2°C	3.74	3.12
Pdh Tj = +7°C	5.70 kW	4.80 kW
COP Tj = +7°C	6.77	4.40
Pdh Tj = 12°C	6.50 kW	5.40 kW
COP Tj = 12°C	8.97	6.36
Pdh Tj = Tbiv	12.10 kW	12.20 kW
COP Tj = Tbiv	2.56	1.78

This information was generated by the HP KEYMARK database on 7 Jul 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	11.70 kW	13.30 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	2.05	1.71
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	1.00	1.00
WTOL	35 °C	55 °C
Poff	55 W	55 W
PTO	57 W	57 W
PSB	55 W	55 W
PCK	55 W	55 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.40 kW	0.90 kW
Annual energy consumption Q_{he}	8270 kWh	8970 kWh

Model: EBLQ016CW1

Configure model	
Model name	EBLQ016CW1
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	16.00 kW	15.04 kW
El input	3.76 kW	5.37 kW
COP	4.26	2.80

Average Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	66 dB(A)	66 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	149 %	119 %
Prated	16.00 kW	14.00 kW
SCOP	3.80	3.06
Tbiv	-4 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.40 kW	12.20 kW
COP Tj = -7°C	2.33	1.78
Pdh Tj = +2°C	8.60 kW	7.60 kW
COP Tj = +2°C	3.74	3.12
Pdh Tj = +7°C	5.70 kW	4.80 kW
COP Tj = +7°C	6.77	4.40
Pdh Tj = 12°C	6.50 kW	5.40 kW
COP Tj = 12°C	8.97	6.36
Pdh Tj = Tbiv	12.10 kW	12.20 kW
COP Tj = Tbiv	2.56	1.78

This information was generated by the HP KEYMARK database on 7 Jul 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	11.70 kW	13.30 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	2.05	1.71
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	1.00	1.00
WTOL	35 °C	55 °C
Poff	55 W	55 W
PTO	57 W	57 W
PSB	55 W	55 W
PCK	55 W	55 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.40 kW	0.90 kW
Annual energy consumption Q_{he}	8270 kWh	8970 kWh

Model: EBLQ016C3W1

Configure model	
Model name	EBLQ016C3W1
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	16.00 kW	15.04 kW
El input	3.76 kW	5.37 kW
COP	4.26	2.80

Average Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	66 dB(A)	66 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	149 %	119 %
Prated	16.00 kW	14.00 kW
SCOP	3.80	3.06
Tbiv	-4 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.40 kW	12.20 kW
COP Tj = -7°C	2.33	1.78
Pdh Tj = +2°C	8.60 kW	7.60 kW
COP Tj = +2°C	3.74	3.12
Pdh Tj = +7°C	5.70 kW	4.80 kW
COP Tj = +7°C	6.77	4.40
Pdh Tj = 12°C	6.50 kW	5.40 kW
COP Tj = 12°C	8.97	6.36
Pdh Tj = Tbiv	12.10 kW	12.20 kW
COP Tj = Tbiv	2.56	1.78

This information was generated by the HP KEYMARK database on 7 Jul 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	11.70 kW	13.30 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	2.05	1.71
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	1.00	1.00
WTOL	35 °C	55 °C
Poff	55 W	55 W
PTO	57 W	57 W
PSB	55 W	55 W
PCK	55 W	55 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.40 kW	0.90 kW
Annual energy consumption Q_{he}	8270 kWh	8970 kWh

Model: EDLQ016C3V3

Configure model	
Model name	EDLQ016C3V3
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	16.00 kW	15.04 kW
El input	3.76 kW	5.37 kW
COP	4.26	2.80

Average Climate

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	66 dB(A)	66 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	149 %	119 %
Prated	16.00 kW	14.00 kW
SCOP	3.80	3.06
Tbiv	-4 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.40 kW	12.20 kW
COP Tj = -7°C	2.33	1.78
Pdh Tj = +2°C	8.60 kW	7.60 kW
COP Tj = +2°C	3.74	3.12
Pdh Tj = +7°C	5.70 kW	4.80 kW
COP Tj = +7°C	6.77	4.40
Pdh Tj = 12°C	6.50 kW	5.40 kW
COP Tj = 12°C	8.97	6.36
Pdh Tj = Tbiv	12.10 kW	12.20 kW
COP Tj = Tbiv	2.56	1.78

This information was generated by the HP KEYMARK database on 7 Jul 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	11.70 kW	13.30 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	2.05	1.71
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	1.00	1.00
WTOL	35 °C	55 °C
Poff	55 W	55 W
PTO	57 W	57 W
PSB	55 W	55 W
PCK	55 W	55 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.40 kW	0.90 kW
Annual energy consumption Q_{he}	8270 kWh	8970 kWh

Model: EDLQ016CW1

Configure model	
Model name	EDLQ016CW1
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	16.00 kW	15.04 kW
El input	3.76 kW	5.37 kW
COP	4.26	2.80

Average Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	66 dB(A)	66 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	149 %	119 %
Prated	16.00 kW	14.00 kW
SCOP	3.80	3.06
Tbiv	-4 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.40 kW	12.20 kW
COP Tj = -7°C	2.33	1.78
Pdh Tj = +2°C	8.60 kW	7.60 kW
COP Tj = +2°C	3.74	3.12
Pdh Tj = +7°C	5.70 kW	4.80 kW
COP Tj = +7°C	6.77	4.40
Pdh Tj = 12°C	6.50 kW	5.40 kW
COP Tj = 12°C	8.97	6.36
Pdh Tj = Tbiv	12.10 kW	12.20 kW
COP Tj = Tbiv	2.56	1.78

This information was generated by the HP KEYMARK database on 7 Jul 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	11.70 kW	13.30 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	2.05	1.71
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	1.00	1.00
WTOL	35 °C	55 °C
Poff	55 W	55 W
PTO	57 W	57 W
PSB	55 W	55 W
PCK	55 W	55 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.40 kW	0.90 kW
Annual energy consumption Q_{he}	8270 kWh	8970 kWh

Model: EDLQ016C3W1

Configure model	
Model name	EDLQ016C3W1
Application	Heating (medium temp)
Units	Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-4	
Operating range outdoor exchanger/indoor exchanger lower limit/lower limit	passed
Operating range outdoor exchanger/indoor exchanger upper limit/upper limit	passed
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed

EN 14511-2		
	Low temperature	Medium temperature
Heat output	16.00 kW	15.04 kW
El input	3.76 kW	5.37 kW
COP	4.26	2.80

Average Climate

This information was generated by the HP KEYMARK database on 7 Jul 2022

EN 12102-1

	Low temperature	Medium temperature
Sound power level outdoor	66 dB(A)	66 dB(A)

EN 14825

	Low temperature	Medium temperature
η_s	149 %	119 %
Prated	16.00 kW	14.00 kW
SCOP	3.80	3.06
Tbiv	-4 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	12.40 kW	12.20 kW
COP Tj = -7°C	2.33	1.78
Pdh Tj = +2°C	8.60 kW	7.60 kW
COP Tj = +2°C	3.74	3.12
Pdh Tj = +7°C	5.70 kW	4.80 kW
COP Tj = +7°C	6.77	4.40
Pdh Tj = 12°C	6.50 kW	5.40 kW
COP Tj = 12°C	8.97	6.36
Pdh Tj = Tbiv	12.10 kW	12.20 kW
COP Tj = Tbiv	2.56	1.78

This information was generated by the HP KEYMARK database on 7 Jul 2022

$P_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	11.70 kW	13.30 kW
$COP T_j = TOL$ or $COP T_j = T_{designh}$ if $TOL < T_{designh}$	2.05	1.71
$C_{dh} T_j = TOL$ or $P_{dh} T_j = T_{designh}$ if $TOL < T_{designh}$	1.00	1.00
WTOL	35 °C	55 °C
Poff	55 W	55 W
PTO	57 W	57 W
PSB	55 W	55 W
PCK	55 W	55 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	4.40 kW	0.90 kW
Annual energy consumption Q_{he}	8270 kWh	8970 kWh