

Page 1 of 8

This information was generated by the HP KEYMARK database on 22 Jun 2022

Login

Summary of	TERRA 11 HPLA	Reg. No.	011-1W0418		
Certificate Holder	Certificate Holder				
Name	Ochsner Wärmepumpen Gmb	ρΗ			
Address	Krackowizerstraße 4	Zip	4020		
City	Linz	Country	Austria		
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH				
Subtype title	TERRA 11 HPLA				
Heat Pump Type	Brine/Water				
Refrigerant	R410A				
Mass of Refrigerant	2.03 kg				
Certification Date	30.09.2020	30.09.2020			
Testing basis	HP KEYMARK certification scheme rules rev. 7				



Model: TERRA 11 HPLA

Configure model		
Model name	TERRA 11 HPLA	
Application	Heating (medium temp)	
Units	Indoor	
Climate Zone	Colder Climate + Warmer Climate	
Reversibility	No	
Cooling mode application (optional)	n/a	

General Data		
Power supply	3x400V 50Hz	

Heating

EN 14511-2				
Low temperature Medium temperature				
Heat output	10.31 kW	9.28 kW		
El input	2.05 kW	3.18 kW		
СОР	5.02	2.91		

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Shutting on the heat transfer medium now	passeu
Complete power supply failure	passed
Starting and operating test	passed

Warmer Climate



This information was generated by the HP KEYMARK database on 22 Jun 2022

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	0 dB(A)	0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_{s}	215 %	136 %
Prated	10.00 kW	9.00 kW
SCOP	5.59	3.60
Tbiv	2 °C	2 °C
TOL	0 °C	0 °C
Pdh Tj = -7°C	0.00 kW	0.00 kW
COP Tj = -7°C	0.00	0.00
Pdh Tj = +2°C	10.30 kW	9.10 kW
COP Tj = +2°C	5.03	2.83
Pdh Tj = +7°C	10.40 kW	9.50 kW
COP Tj = +7°C	5.43	3.28
Pdh Tj = 12°C	10.60 kW	10.00 kW
COP Tj = 12°C	6.10	4.21
Pdh Tj = Tbiv	10.30 kW	9.10 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com





This information was generated by the HP KEYMARK database on 22 Jun 2022 COP Tj = Tbiv5.03 2.83 Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh 10.30 kW 91.00 kW COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh 5.03 2.83 Rated airflow rate $0 \text{ m}^3/\text{h}$ 0 m³/h Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh 0.90 0.90 WTOL 65 °C 65 °C 0 W Poff 0 W PTO 84 W 84 W 9 W **PSB** 9 W **PCK** 0 W 0 W Supplementary Heater: Type of energy input Electricity Electricity Supplementary Heater: PSUP 0.00 kW 0.00 kW

Colder Climate

Annual energy consumption Qhe

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	48 dB(A)	48 dB(A)
Sound power level outdoor	0 dB(A)	0 dB(A)

2466 kWh

3367 kWh

EN 14825		
	Low temperature Medium temperature	





This information was generated by the HP KEYMARK database on 22 Jun 2022

η_{s}	224 %	224 %
Prated	13.00 kW	13.00 kW
SCOP	5.81	5.80
Tbiv	-15 °C	-15 °C
TOL	-22 °C	-22 °C
Pdh Tj = -7°C	10.50 kW	10.50 kW
COP Tj = -7°C	5.75	5.74
Pdh Tj = +2°C	10.60 kW	10.60 kW
COP Tj = +2°C	6.07	6.07
Pdh Tj = +7°C	10.70 kW	10.70 kW
$COP Tj = +7^{\circ}C$	6.36	6.36
Pdh Tj = 12°C	10.70 kW	10.70 kW
COP Tj = 12°C	6.40	6.40
Pdh Tj = Tbiv	10.50 kW	10.50 kW
COP Tj = Tbiv	5.60	5.60
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	10.50 kW	10.30 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	5.60	5.03
Rated airflow rate	0 m³/h	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	65 °C	65 °C





This information was generated by the HP KEYMARK database on 22 Jun 20		
Poff	o w	o w
РТО	84 W	84 W
PSB	9 W	9 W
PCK	o w	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	2.55 kW	2.55 kW
Annual energy consumption Qhe	5457 kWh	5457 kWh

Average Climate

EN 12102-1			
Low temperature Medium temperature			
Sound power level indoor	48 dB(A)	48 dB(A)	
Sound power level outdoor	0 dB(A)	0 dB(A)	

EN 14825			
	Low temperature	Medium temperature	
η_{s}	216 %	137 %	
Prated	10.00 kW	9.00 kW	
SCOP	5.61	3.63	
Tbiv	-10 °C	-10 °C	
TOL	-20 °C	-10 °C	





This information was generated by the HP KEYMARK database on 22 Jun 2022

This information was gener	acca by the in Reimin	int database on 22 jan 202
Pdh Tj = -7°C	9.20 kW	9.20 kW
COP Tj = -7°C	2.97	2.97
Pdh Tj = +2°C	9.60 kW	9.60 kW
COP Tj = +2°C	3.56	3.56
Pdh Tj = $+7^{\circ}$ C	9.90 kW	9.90 kW
$COP Tj = +7^{\circ}C$	4.03	4.03
Pdh Tj = 12°C	10.10 kW	10.10 kW
COP Tj = 12°C	4.60	4.60
Pdh Tj = Tbiv	10.30 kW	9.10 kW
COP Tj = Tbiv	5.03	2.83
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	9.10 kW	9.10 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.83	2.83
Rated airflow rate	0 m³/h	0 m³/h
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.90	0.90
WTOL	65 °C	65 °C
Poff	o w	0 W
PTO	84 W	84 W
PSB	9 W	9 W
PCK	0 W	o w
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.00 kW	0.00 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



 $$\operatorname{\textit{Page}}8 of 8 This information was generated by the HP KEYMARK database on 22 Jun 2022

Annual energy consumption Qhe	3799 kWh	5167 kWh
-------------------------------	----------	----------